

Lead in Water Testing Results
South Washington County Schools
Crestview Elementary

On December 29th, 2018 Crestview Elementary School's drinking water was tested for concentration of lead.

The following water sources tested less than 20 parts-per-billion.

No action was taken at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Nurse's Office	SINK	7.1
Media Center Workroom	SINK	5.7
Staff Lounge	SINK	6.3
Hallway (outside gym)	FOUNTAIN	2.0
Gym A	FOUNTAIN	5.6
Gym B	FOUNTAIN	1.2
Cafeteria	FOUNTAIN	0
Cafeteria	BOTTLE FILLER	0
Kitchen (1)	SINK	5.1
Kitchen (2)	SINK	1.9
Kitchen (3)	SINK	1.8
Room 101	SINK	4.4
Room 101	FOUNTAIN	1.4
Room 102	SINK	15.3
Room 103	SINK	8.6
Room 103	FOUNTAIN	1.6

Room 104	SINK	6.0
Room 104	FOUNTAIN	2.1
Room 105	SINK	5.0
Room 106	FOUNTAIN	1.7
Hallway (outside 106)	FOUNTAIN	6.2
Room 107	SINK	4.1
Room 107	FOUNTAIN	3.0
Room 108	SINK	3.8
Room 108	FOUNTAIN	2.0
Room 109	SINK	6.9
Room 109	FOUNTAIN	4.8
Room 110	SINK	8.1
Room 110	FOUNTAIN	5.2
Room 111	SINK	5.9
Room 111	FOUNTAIN	2.9
Room 112	SINK	9.3
Room 112	FOUNTAIN	5.7
Room 113	SINK	6.1
Room 113	FOUNTAIN	2.9
Room 114	SINK	9.4
Room 114	FOUNTAIN	4.6
Room 115	SINK	8.5
Room 115	FOUNTAIN	2.3
Room 116	SINK	3.4
Room 116	FOUNTAIN	1.3

Hallway (outside 116, left)	FOUNTAIN	.91
Hallway (outside 116, right)	FOUNTAIN	.65
Room 117	SINK	2.4
Room 117	FOUNTAIN	1.9
Room 118	SINK	14.1
Room 118	FOUNTAIN	3.4
Room 202	SINK	4.0
Room 202	FOUNTAIN	1.3
Room 203	SINK	9.4
Room 203	FOUNTAIN	4.8
Room 204	SINK	4.2
Room 204	FOUNTAIN	3.0
Room 205	SINK	5.4
Room 205	FOUNTAIN	4.1
Room 206	SINK	9.0
Room 206	FOUNTAIN	3.1
Room 207	SINK	6.1
Room 207	FOUNTAIN	1.8
Room 208	SINK	4.1
Room 208	FOUNTAIN	1.5
Room 209	SINK	4.4
Room 209	FOUNTAIN	2.4
Room 210	SINK	5.3
Room 210	FOUNTAIN	2.8
Hallway (outside 210)	FOUNTAIN	2.2

Room 211	SINK	5.8
Room 211	FOUNTAIN	3.6
Room 212	SINK	9.3
Room 212	FOUNTAIN	2.9
Room 214	SINK	9.7
Room 215	SINK	6.9
Room 216	SINK	10.2

The following water sources tested with results of the concentration to be over 20 parts-per-billion. The fixtures of these water sources were replaced, and a re-test was administered. Results of the initial test and retest are below. No water sources re-tested over 20 parts-per-billion and no further action will be taken at this time.

LOCATION	SOURCE	INITIAL RESULTS (in ug/L)	RE-TEST RESULTS
Room 105	FOUNTAIN	221	4.1
Room 106	SINK	27.1	6.9