

Lead in Water Testing Results
South Washington County Schools
Hillside Elementary

On December 29th, 2018 Hillside Elementary School's drinking water was tested for concentration of lead.

The following water sources tested less than 20 parts-per-billion.

No action was taken at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Nurse's Office	SINK	5.6
Hallway (outside gym)	FOUNTAIN	1.8
Gym	FOUNTAIN	4.8
Media Center Workroom	SINK	4.1
Cafeteria	FOUNTAIN	0
Cafeteria	BOTTLE FILLER	0
Kitchen (1)	SINK	6.0
Kitchen (2)	SPRAYER	8.8
Kitchen (3)	SINK	4.8
Kitchen (4)	SINK	3.9
Staff Lounge	SINK	4.1
Room 101	SINK	6.5
Room 101	FOUNTAIN	3.8
Room 103	SINK	7.5
Room 104	SINK	5.7
Room 104	FOUNTAIN	1.2

Room 105	SINK	5.4
Room 105	FOUNTAIN	3.9
Room 106	SINK	3.5
Room 106	FOUNTAIN	3.1
Hallway (outside 106)	FOUNTAIN	3.4
Room 107	SINK	3.4
Room 107	FOUNTAIN	2.1
Room 108	SINK	4.5
Room 108	FOUNTAIN	1.8
Room 109	SINK	5.7
Room 109	FOUNTAIN	4.7
Room 110	SINK	7.0
Room 110	FOUNTAIN	3.1
Room 111	SINK	9.1
Room 111	FOUNTAIN	3.1
Room 112	SINK	4.0
Room 112	FOUNTAIN	3.4
Room 113	SINK	4.7
Room 113	FOUNTAIN	1.5
Room 114	SINK	3.1
Room 114	FOUNTAIN	1.7
Room 202	SINK	5.0
Room 202	FOUNTAIN	1.9
Room 203	SINK	5.6
Room 203	FOUNTAIN	1.7

Room 204	SINK	5.4
Room 204	FOUNTAIN	4.7
Room 206	SINK	3.5
Room 205	SINK	4.1
Room 205	FOUNTAIN	2.6
Room 206	FOUNTAIN	1.9
Room 207	SINK	6.2
Room 207	FOUNTAIN	2.1
Room 208	SINK	7.0
Room 208	FOUNTAIN	3.7
Room 209	SINK	5.7
Room 209	FOUNTAIN	1.0
Room 210	SINK	2.3
Room 210	FOUNTAIN	1.3
Room 211	SINK	6.9
Room 211	FOUNTAIN	2.6
Room 212	SINK	3.3
Room 212	FOUNTAIN	1.7
Hallway (outside 212)	FOUNTAIN	2.2
Room 213	SINK	3.8
Room 213	FOUNTAIN	2.0
Room 215	SINK	7.5
Room 216	SINK	12.3
Room 217	SINK	8.1

The following water sources tested with results of the concentration to be over 20 parts-per-billion. The fixtures of these water sources were replaced, and a re-test was administered. Results of the initial test and retest are below. No water sources re-tested over 20 parts-per-billion and no further action will be taken at this time.

LOCATION	SOURCE	INITIAL RESULTS (in ug/L)	RE-TEST RESULTS
Room 214	SINK	26.7	2.4