

Lead in Water Testing Results
South Washington County Schools
Cottage Grove Middle

On December 28th, 2019 Cottage Grove Middle School's drinking water was tested for concentration of lead.

**All water sources tested less than our current action level of 20 parts-per-billion.
No action was taken to these sources at this time.**

LOCATION	SOURCE	RESULTS (in ug/L)
Office Work Room	SINK	1.1
Nurse's Office	SINK	.69
Staff Work Room	SINK	2.5
Staff Work Room	FILTERED	0
AV Work Room	SINK	17.9
Hallway (1, left)	FOUNTAIN	0
Hallway (1, right)	FOUNTAIN	0
Pool (2)	FOUNTAIN	.39
Hallway (3)	FOUNTAIN	0
Hallway (3)	BOTTLE FILLER	0
Hallway (4, left)	FOUNTAIN	.59
Hallway (5)	FOUNTAIN	0
Hallway (5)	BOTTLE FILLER	0
Hallway (7)	FOUNTAIN	0
Hallway (8)	FOUTNAIN	.28
Hallway (10)	FOUNTAIN	0
Hallway (10)	BOTTLE FILLER	0
Hallway (12)	FOUNTAIN	0

Hallway (12)	BOTTLE FILLER	0
Hallway (14)	FOUNTAIN	0
Hallway (15)	FOUNTAIN	0
Hallway (15)	BOTTLE FILLER	0
Concessions	SINK	3.8
Kitchen (1)	SPRAYER	13.5
Kitchen (2)	SPRAYER	5.4
Kitchen (3)	SPRAYER	7.5
Kitchen (1)	SINK	1.1
Room G106 (backroom)	SINK	3.0
Room A106 (1)	SINK	1.6
Room A106 (2)	SINK	9.8
Room A106 (3)	SINK	7.1
Room A110 (1)	SINK	7.8
Room A110 (2)	SINK	9.6
Room A110 (3)	SINK	1.7
Room A116	SINK	.24
Room A141	SINK	4.8
Room A144	SINK	18.5
Room B114	SINK	6.5
Room B115	SINK	3.7
Room C124	SINK	2.8
Room C125	SINK	12.4
Room H103	SINK	2.4
Room H107	SINK	1.3