

Lead in Water Testing Results  
South Washington County Schools  
Liberty Ridge Elementary – Site II

On December 22nd, 2019 Liberty Ridge Elementary – Site II - School's drinking water was tested for concentration of lead.

**All water sources tested less than our current action level of 20 parts-per-billion.**

**No action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Hallway (1)	FOUNTAIN	.42
Hallway (2)	FOUNTAIN	.46
Room 105	SINK	5.3
Room 110	SINK	4.8
Room 111	SINK	.50
Room 112	SINK	.71
Room 113	SINK	10.9
Music Room	SINK	9.2
Room 127 (left)	SINK	1.8
Room 127 (right)	SINK	1.2
Room 127	FOUNTAIN	.64
Room 128 (left)	SINK	1.2
Room 128 (right)	SINK	2.9
Room 128	FOUNTAIN	1.1
Hallway (outside 128)	FOUNTAIN	0
Hallway (outside 128)	BOTTLE FILLER	0
Staff Room	SINK	.41

Room 129 (left)	SINK	6.1
Room 129 (right)	SINK	1.0
Room 129	FOUNTAIN	.44
Room 131 (left)	SINK	1.5
Room 131 (right)	SINK	1.5
Room 131	FOUNTAIN	.64
Room 132 (left)	SINK	1.2
Room 132 (right)	SINK	2.9
Room 132	FOUNTAIN	.48
Cafeteria (left)	FOUNTAIN	.41
Cafeteria (right)	FOUNTAIN	.53
Cafeteria	BOTTLE FILLER	.51
Kitchen (left)	SINK	3.4
Kitchen (right)	SINK	2.0
Kitchen	SPRAYER	.17