

Lead in Water Testing Results  
South Washington County Schools  
Newport Elementary

On December 28th, 2019 Newport Elementary School's drinking water was tested for concentration of lead.

**The following water sources tested less than our current action level of 20 parts-per-billion.**

**No action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Nurse's Office	SINK	15.9
Nurse's Office (bathroom)	SINK	17.7
Staff Lounge	SINK	6.9
Hallway (outside 103, left)	FOUNTAIN	.13
Hallway (outside 103, right)	FOUNTAIN	.13
Kitchen	SPRAYER	3.4
Kitchen (left)	SINK	2.2
Kitchen (right)	SINK	5.7
Outside Gym	FOUNTAIN	1.1
Hallway (outside 125)	FOUNTAIN	.11
Hallway (outside 125)	BOTTLE FILLER	.16
Hallway (outside 120)	FOUNTAIN	.14
Hallway (outside 116, left)	FOUNTAIN	9.7
Hallway (outside 116, right)	FOUNTAIN	12.2
Room 101	SINK	1.5
Room 103	SINK	2.9
Room 106	SINK	9.7

Room 107	SINK	8.1
Room 108	SINK	12.3
Room 109	SINK	7.3
Room 110	SINK	7.1
Room 110	FOUNTAIN	.68
Room 111	SINK	4.2
Room 111	FOUNTAIN	.63
Room 112	SINK	3.5
Room 112	FOUNTAIN	.74
Room 113	SINK	10.8
Room 113	FOUNTAIN	.88
Room 115	SINK	5.6
Room 116	SINK	5.2
Room 116	FOUNTAIN	1.1
Room 117	SINK	11.4
Room 122	SINK	17.3
Room 123	SINK	17.7
Room 124	SINK	13.9
Room 125	SINK	18.4
Room 126	SINK	17.5
Room 127	SINK	9.6

**The following water sources tested with results of the concentration to be over 20 parts-per-billion. The fixtures of these water sources were replaced, and a re-test was administered. Results of the initial test and retest are below. No water sources re-tested over 20 parts-per-billion and no further action will be taken at this time.**

LOCATION	SOURCE	INITIAL RESULTS (in ug/L)	RE-TEST RESULTS
Room 114	SINK	39.0	7.4