

Lead in Water Testing Results
South Washington County Schools
Red Rock Elementary

On December 28th, 2019 Red Rock Elementary School's drinking water was tested for concentration of lead.

All water sources tested less than our current action level of 20 parts-per-billion.

No action was taken at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Nurse's Office	SINK	.42
Staff Lounge	SINK	2.1
Kitchen (right)	SINK	3.0
Kitchen (left)	SINK	1.6
Kitchen	SPRAYER	3.7
Hallway (1)	FOUNTAIN	0
Hallway (2)	BOTTLE FILLER	0
Hallway (3)	FOUNTAIN	.13
Hallway (4)	FOUNTAIN	.64
Hallway (5)	FOUNTAIN	.11
Room B115 (1)	SINK	9.9
Room B115 (2)	SINK	9.6
Room B115 (3)	SINK	4.2
Room B115 (4)	SINK	2.3
Hallway (6)	FOUNTAIN	0
Hallway (6)	BOTTLE FILLER	0
Hallway (7)	FOUNTAIN	.60

Room E101	SINK	.86
Room E101	FOUNTAIN	.67
Room E116	SINK	1.1
Room E116	FOUNTAIN	1.0
Hallway (outside E115)	SINK	.36
Hallway (outside E115)	FOUNTAIN	1.9
Room E115	SINK	1.2
Room E115	FOUNTAIN	.77
Room E114	SINK	1.2
Room E114	FOUNTAIN	.56
Room E112	SINK	1.1
Room E112	FOUNTAIN	.93
Room E119	SINK	1.5
Room E119	FOUNTAIN	1.6
Room E118	SINK	.61
Room E118	FOUNTAIN	1.6
Room E103	SINK	1.9
Room E103	FOUNTAIN	.75
Room E104	SINK	1.2
Room E104	FOUNTAIN	.39
Room E111	SINK	3.8
Room E111	FOUNTAIN	1.0
Room E109	SINK	.82
Room E109	FOUNTAIN	2.1
Room E108	SINK	3.5

Room E108	FOUNTAIN	.94
Hallway (outside E108)	SINK	1.6
Room E107	SINK	2.0
Room E107	FOUNTAIN	1.6
Room E106	SINK	1.1
Room E106	FOUNTAIN	1.1
Hallway (8)	FOUNTAIN	.38
Hallway (9)	FOUNTAIN	.25
Room D116	SINK	2.9
Room D116	FOUNTAIN	.66
Room D116 (bathroom)	SINK	.78
Room D108	SINK	2.8
Room D108	FOUNTAIN	.63
Room D108 (bathroom)	SINK	1.3
Room D103	SINK	2.3
Room D103	FOUNTAIN	.64
Room D103 (bathroom)	SINK	.73
Hallway (10)	FOUNTAIN	.44
Hallway (11)	FOUNTAIN	.23
Room C106	SINK	.84
Room C106	FOUNTAIN	2.4
Room C107	SINK	1.4
Room C107	FOUNTAIN	3.4
Hallway (outside C108)	SINK	2.2
Hallway (outside C108)	FOUNTAIN	1.2

Room C108	SINK	1.6
Room C108	FOUNTAIN	2.5
Room C109	SINK	1.3
Room C109	FOUNTAIN	1.3
Room C111	SINK	.75
Room C111	FOUNTAIN	1.8
Room C118	SINK	2.8
Room C118	FOUNTAIN	1.1
Room C119	SINK	1.3
Room C119	FOUNTAIN	4.9
Room C104	SINK	1.3
Room C104	FOUNTAIN	2.3
Media Work Room	SINK	1.7
Room C103	SINK	1.2
Room C103	FOUNTAIN	2.0
Room C112	SINK	.79
Room C112	FOUNTAIN	2.6
Room C114	SINK	2.0
Room C114	FOUNTAIN	.85
Room C115	SINK	.99
Room C115	FOUNTAIN	1.0
Hallway (outside C115)	SINK	2.5
Hallway (outside C115)	FOUNTAIN	2.5
Room C116	SINK	1.1
Room C116	FOUNTAIN	1.0

Room C101	SINK	1.5
Hallway (12)	FOUNTAIN	.48
Hallway (13)	FOUNTAIN	0
Hallway (13)	BOTTLE FILLER	0