

Lead in Water Testing Results  
South Washington County Schools

Next Step

On December 22nd, 2019 Next Step's drinking water was tested for concentration of lead.

**The following water sources tested less than our action level of 20 parts-per-billion.**

**No action was taken to these sources at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Kitchen	SINK	1.4
Staff Room	SINK	.24
Nurse Bathroom	SINK	1.4

**The following water sources tested with results of the concentration to be over 20 parts-per-billion. The filter was added to these fixtures and a re-test was administered. Results of the initial test and retest are below. No water sources re-tested over 20 parts-per-billion and no further action will be taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>INITIAL RESULTS (in ug/L)</b>	<b>RE-TEST RESULTS</b>
Main Area (left)	FOUNTAIN	40.6	0
Main Area (right)	FOUNTAIN	22.0	0