

Lead in Water Testing Results
South Washington County Schools
East Ridge High School

On December 22nd, 2019 East Ridge High School's drinking water was tested for concentration of lead.

All water sources tested less than our current action level of 20 parts-per-billion.

No action was taken on these sources at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Nurse's Office	SINK	2.4
Nurse's Office (bathroom)	SINK	4.8
Special Ed Kitchen	SINK	10.0
Room 1007 (teacher's)	SINK	3.8
Room 1017	SINK	6.6
Room 1018	SINK	5.9
Hallway (1)	FOUNTAIN	.12
Hallway (2)	FOUNTAIN	.19
Hallway (3)	FOUNTAIN	.19
Hallway (4)	FOUNTAIN	.20
Room 1020 (teacher's)	SINK	9.4
Room 1027	SINK	3.9
Hallway (5)	FOUNTAIN	.14
Hallway (6)	FOUNTAIN	.24
Room 1028 (1)	SINK	6.2
Room 1028 (2)	SINK	7.9
Room 1028 (3)	SINK	4.8

Room 1028 (4)	SINK	7.2
Room 1028 (5)	SINK	5.7
Room 1028 (6)	SINK	4.1
Room 1028 (7)	SINK	10.8
Room 1028 (8)	SINK	3.7
Room 1030	SINK	11.7
Room 1038 (left)	SINK	1.5
Room 1038 (right)	SINK	1.4
Room 1039 (1)	SINK	4.9
Room 1039 (2)	SINK	5.6
Room 1040 (left)	SINK	3.1
Room 1040 (right)	SINK	5.2
Cafeteria (north)	FOUNTAIN	.17
Cafeteria (north)	BOTTLE FILLER	.21
Kitchen (1)	SINK	5.8
Kitchen (1)	SPRAYER	3.8
Kitchen (2)	SINK	3.3
Kitchen (2)	SPRAYER	4.2
Hallway (7)	FOUNTAIN	.33
Hallway (8)	FOUNTAIN	.38
Hallway (9)	FOUNTAIN	0
Hallway (10)	FOUNTAIN	0
Hallway (11)	FOUNTAIN	.17
Hallway (12)	FOUNTAIN	0
Hallway (12)	BOTTLE FILLER	0

Room 1053 (left)	SINK	6.7
Room 1053 (right)	SINK	6.8
Room 1055	FOUNTAIN	.21
Room 1056	FOUNTAIN	.32
Room 1057	FOUNTAIN	.42
Hallway (13)	FOUNTAIN	.27
Hallway (14)	FOUNTAIN	.18
Office (in hallway)	FOUNTAIN	0
Office (workroom)	SINK	1.8
Office (workroom, with filter)	SINK	0
Room 2007B	SINK	12.2
Room 2017	SINK	2.2
Room 2018B	SINK	6.5
Hallway (2 nd floor, 1)	FOUNTAIN	.16
Hallway (2 nd floor, 2)	FOUNTAIN	.26
Hallway (2 nd floor, 3)	FOUNTAIN	.15
Hallway (2 nd floor, 4)	FOUNTAIN	0
Hallway (2 nd floor, 4)	BOTTLE FILLER	0
Room 2027	SINK	3.8
Room 2028B	SINK	13.6
Hallway (2 nd floor, 5)	FOUNTAIN	.12
Hallway (2 nd floor, 6)	FOUNTAIN	.21
Room 2037	SINK	1.9