

Lead in Water Testing Results
South Washington County Schools
Park High School

On December 22nd, 2019 Park High School's drinking water was tested for concentration of lead.

All water sources tested less than our current action level of 20 parts-per-billion.

No action was taken at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Hallway (1)	FOUNTAIN	3.9
Room 101	SINK	1.2
Hallway (2)	FOUNTAIN	2.2
Hallway (3)	FOUNTAIN	1.9
Hallway (4)	FOUNTAIN	.29
Hallway (5)	FOUNTAIN	3.0
Hallway (6)	FOUNTAIN	1.9
Room 117 (teacher's)	SINK	6.0
Room 115 (teacher's)	SINK	4.5
Room 131 (teacher's)	SINK	9.1
Room 133 (teacher's)	SINK	17.1
Room 135 (left, 1)	SINK	.23
Room 135 (right, 1)	SINK	.16
Room 135 (left, 2)	SINK	.44
Room 135 (right, 2)	SINK	.73
Hallway (7)	FOUNTAIN	0
Hallway (7)	BOTTLE FILLER	0

Room 164 (left)	SINK	2.3
Room 164 (right)	SINK	1.5
Room 165 (left)	SINK	.31
Room 178	SINK	4.2
Hallway (8)	FOUNTAIN	6.2
Kitchen (1)	SPRAYER	3.0
Kitchen (2)	SPRAYER	.69
Kitchen (1)	SINK	2.4
Kitchen (2)	SINK	6.4
Kitchen (3)	SINK	2.5
Hallway (9)	FOUNTAIN	0
Hallway (10)	FOUNTAIN	0
Hallway (10)	BOTTLE FILLER	0
Nurse's Office	SINK	3.2
Copy Room	SINK	3.4
Media WR	SINK	4.3
Hallway (2 nd floor, 1)	FOUNTAIN	3.1
Hallway (2 nd floor, 2)	FOUNTAIN	2.9
Hallway (2 nd floor, 3)	FOUNTAIN	0
Hallway (2 nd floor, 3)	BOTTLE FILLER	0
Hallway (2 nd floor, 5)	FOUNTAIN	2.6
Hallway (2 nd floor, 6)	FOUNTAIN	3.4
Hallway (2 nd floor, 7)	FOUNTAIN	6.1
Hallway (2 nd floor, 8)	FOUNTAIN	4.5
Hallway (outside gym)	FOUNTAIN	.12

Hallway (outside gym)	BOTTLE FILLER	.17
Concessions (left)	SINK	.46
Concessions (right)	SINK	1.0
Little Gym	SINK	1.7
Big Gym (1)	FOUNTAIN	.36
Big Gym (2)	FOUNTAIN	.51
Big Gym (4)	FOUNTAIN	.45
Big Gym (5)	FOUNTAIN	.60
Big Gym (6)	FOUNTAIN	.72
Big Gym (7)	FOUNTAIN	.59
Big Gym (8)	FOUNTAIN	.72