



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Jeferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: W. Sher

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 07/06/2016 12:30
Reported: 07/28/2016 22:17

Analytical Testing Parameters

Client Sample ID: 27-1
Lab Sample ID: J6G0288-01
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1731

Analytical Testing Parameters

Client Sample ID: 27-2
Lab Sample ID: J6G0288-02
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.015, 0.015, 0.0050, mg/L, G, 07/20/16 1640, 07/22/16 1732

Analytical Testing Parameters

Client Sample ID: 26-1
Lab Sample ID: J6G0288-03
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0068, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1734



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 26-2
Lab Sample ID: J6G0288-04
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1735.

Analytical Testing Parameters

Client Sample ID: 13-1
Lab Sample ID: J6G0288-05
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1737.

Analytical Testing Parameters

Client Sample ID: 13-2
Lab Sample ID: J6G0288-06
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1741.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 7-1
Lab Sample ID: J6G0288-07
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1746

Analytical Testing Parameters

Client Sample ID: 7-2
Lab Sample ID: J6G0288-08
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1748

Analytical Testing Parameters

Client Sample ID: 14-1
Lab Sample ID: J6G0288-09
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1749



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 14-2
Lab Sample ID: J6G0288-10
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 07:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1751

Analytical Testing Parameters

Client Sample ID: 6-1
Lab Sample ID: J6G0288-11
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1752

Analytical Testing Parameters

Client Sample ID: 6-2
Lab Sample ID: J6G0288-12
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1754



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 5-1
Lab Sample ID: J6G0288-13
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1755

Analytical Testing Parameters

Client Sample ID: 5-2
Lab Sample ID: J6G0288-14
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1757

Analytical Testing Parameters

Client Sample ID: 8-1
Lab Sample ID: J6G0288-15
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1758



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 8-2
Lab Sample ID: J6G0288-16
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1806

Analytical Testing Parameters

Client Sample ID: 11-1
Lab Sample ID: J6G0288-17
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1808

Analytical Testing Parameters

Client Sample ID: 11-2
Lab Sample ID: J6G0288-18
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1809



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 3-1
Lab Sample ID: J6G0288-19
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1811.

Analytical Testing Parameters

Client Sample ID: 3-2
Lab Sample ID: J6G0288-20
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0071, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1812.

Analytical Testing Parameters

Client Sample ID: 10-1
Lab Sample ID: J6G0288-21
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1814.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 10-2
Lab Sample ID: J6G0288-22
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1816.

Analytical Testing Parameters

Client Sample ID: 9-1
Lab Sample ID: J6G0288-23
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1817.

Analytical Testing Parameters

Client Sample ID: 9-2
Lab Sample ID: J6G0288-24
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0061, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1819.





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 2-1
Lab Sample ID: J6G0288-25
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1823

Analytical Testing Parameters

Client Sample ID: 2-2
Lab Sample ID: J6G0288-26
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1640, 07/22/16 1828

Analytical Testing Parameters

Client Sample ID: 1-1
Lab Sample ID: J6G0288-27
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 07:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1833



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 1-2
Lab Sample ID: J6G0288-28
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 07:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1834.

Analytical Testing Parameters

Client Sample ID: 21-1
Lab Sample ID: J6G0288-29
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1836.

Analytical Testing Parameters

Client Sample ID: 21-2
Lab Sample ID: J6G0288-30
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1837.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 23-1
Lab Sample ID: J6G0288-31
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1839

Analytical Testing Parameters

Client Sample ID: 23-2
Lab Sample ID: J6G0288-32
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1841

Analytical Testing Parameters

Client Sample ID: 22-1
Lab Sample ID: J6G0288-33
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1842



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 22-2
Lab Sample ID: J6G0288-34
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1844.

Analytical Testing Parameters

Client Sample ID: 12-1
Lab Sample ID: J6G0288-35
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1845.

Analytical Testing Parameters

Client Sample ID: 12-2
Lab Sample ID: J6G0288-36
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1853.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 16-1
Lab Sample ID: J6G0288-37
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1855.

Analytical Testing Parameters

Client Sample ID: 16-2
Lab Sample ID: J6G0288-38
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1856.

Analytical Testing Parameters

Client Sample ID: 17-1
Lab Sample ID: J6G0288-39
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0060, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1858.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 17-2
Lab Sample ID: J6G0288-40
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1859

Analytical Testing Parameters

Client Sample ID: 19-1
Lab Sample ID: J6G0288-41
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.013, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1901

Analytical Testing Parameters

Client Sample ID: 19-2
Lab Sample ID: J6G0288-42
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0053, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1902



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 24-1
Lab Sample ID: J6G0288-43
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1904

Analytical Testing Parameters

Client Sample ID: 24-2
Lab Sample ID: J6G0288-44
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1906

Analytical Testing Parameters

Client Sample ID: 25-1
Lab Sample ID: J6G0288-45
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1910



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 25-2
Lab Sample ID: J6G0288-46
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1915.

Analytical Testing Parameters

Client Sample ID: 15-1
Lab Sample ID: J6G0288-47
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.015, 0.015, 0.0050, mg/L, G, 07/20/16 1643, 07/22/16 1917.

Analytical Testing Parameters

Client Sample ID: 15-2
Lab Sample ID: J6G0288-48
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1918.





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 20-1
Lab Sample ID: J6G0288-49
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1920.

Analytical Testing Parameters

Client Sample ID: 20-2
Lab Sample ID: J6G0288-50
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1921.

Analytical Testing Parameters

Client Sample ID: 18-1
Lab Sample ID: J6G0288-51
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.011, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1929.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0288

Analytical Testing Parameters

Client Sample ID: 18-2
Lab Sample ID: J6G0288-52
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/30/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/20/16 1643, 07/22/16 1931

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
MDL: Minimum Detection Limit
PQL: Practical Quantitation Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes, No, Yes. Items include Custody Seals Intact, COC/Labels Agree, Received on Ice.

Project Requested Certification(s)

Microbac Laboratories, Inc. - Chicagoland
NY Lab ID No: 12006
PA DEP ID: 68-04863
New York State Department of Health
Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Handwritten signature of Michael Fifield

Michael Fifield
Division Manager
07/28/2016 22:17

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Client Information				Billing/Invoice:			
Name: Jefferson-Lewis-Hamilton-Hertimer Onida BOCES				Analysis Requested			
Address: 20104 NYS Route 3				Receiving Info (Lab Use Only)			
Contact: Watertown, NY 13601				Ice: YES NO			
Phone: Ray Filley				Cooler: YES NO			
Project: 315-779-7054				Sample Temp: YES NO			
Quote ID: Lead Testing				Cooler Seal: YES NO			
PO#: _____				Pickup: YES NO			
Rush TAT Bus. Days: <2 2-5 5-7 7-10				Dropoff: C W			
Date Req: _____				Accepted? YES NO			
Release to DOH: Yes				Container Material			
Email Results: Yes				Container size (in MI)			
Fax Results: Yes				Preservative			
Email Results: <u>filley@boCES.com</u>				Comments/Field Data			
Fax Results: <u>fhack@boCES.com</u>							
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix	Type		
1 27-1	6/30/16	6:45	RF	200.8 Lead	P		
2 27-2		6:46		250			
3 26-1		6:40		FRN03			
4 26-2		6:41					
5							
6							
7							
8							



J6G0288

Print Name and Company		Signature	Date/Time	Comments
Sampled: Ray Filley		<i>[Signature]</i>	7/5/16 10:00	
Received: David Thomas		<i>[Signature]</i>	7/5/16 12:30	
Received: Young Walker		<i>[Signature]</i>	7/5/16 12:30	
Received:				
Received:				
Received:				

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

**Client Information**  
 Name: Jefferson-Lewis-Hamilton-Herkimer Oneida BOCES  
 Address: 20104 NYS Route 3  
 Watertown, NY 13601  
 Contact: Ray Filley  
 Phone: 315-779-7054  
 Project: Lead Testing  
 Quote ID: PO#:  
 Rush TAT Bus. Days: <2 2-5 5-7 7-10 Date Req:  
 Release to DOH: Yes  
 Email Results: Yes filley@boces.com / fhack@boes.com  
 Fax Results: Yes

**Billing/Invoice:**  
 MNY Workorder #  
 W. SHER

**Receiving Info (Lab Use Only)**  
 Ice: YES NO  
 Cooler: YES NO  
 Sample Temp: YES NO  
 Cooler Seal: YES NO  
 Pickup: YES NO  
 Dropoff: C W  
 Accepted? YES NO  
 Container Material  
 Container Size(In MI)  
 Preservative

Sample Information	Sample Information				Matrix	Type	Number of Containers for Analysis Requested				Comments/Field Data
	Description/Location	Date	Time	Initial							
1 13-1	6/30/16	6:57	RF		200.8 Lead						
2 13-2		6:58			P						
3 7-1		6:35			250						
4 7-2		6:34			HNO3						
5 14-1		6:57									
6 14-2		7:00									
7 6-1		6:37									
8 6-2		6:38									



J6G0288

Print Name and Company	Signature	Date/Time	Comments
Sampled: Jay Filley	<i>Jay Filley</i>	7/5/16 10:00	
Received: Paul A Thomas	<i>Paul A Thomas</i>	7/5/16 12:20	
Received:			
Received:			
Received:			
Received:			

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

# Microbac Laboratories, Inc. Samples must be returned on ice

## CHAIN OF CUSTODY

MNY Workorder #

W. SHER

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES			Ice:	YES NO	Accepted?	YES NO
Address:	20104 NYS Route 3			Cooler:	YES NO	Container Material	
Contact:	Watertown, NY 13601			Sample Temp:		Container Size (in MI)	
Phone:	Ray Filley			Cooler Seal:	YES NO	Preservative	
Project:	315-779-7054			Pickup:	YES NO	Comments/Field Data	
Quote ID:	Lead Testing			Dropoff:	C W		
Rush TAT Bur. Days:	2-5 5-7 7-10						
Release to DOH: Yes							
Email Results: Yes	rfilley@boces.com						
Fax Results: Yes	rfilley@boces.com						

  

Sample Information			Number of Containers for Analysis Requested		Comments/Field Data
Description/Location	Date	Time	Initial	Type	
1 S-1	6/30/12	7:09	RF		
2 S-2		7:05			
3 8-1		6:35			
4 8-2		6:30			
5 11-1		6:51			
6 11-2		6:52			
7 3-1		6:42			
8 3-2		6:43			

  

Sampled:	Print Name and Company	Signature	Date/Time	Comments
Received:	David Thomas	<i>[Signature]</i>	7/5/12 12:30	
Received:				
Received:				
Received:				
Received:				



J6G0288

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

# Microbac Laboratories, Inc. Samples must be returned on ice

## CHAIN OF CUSTODY

MNY Workorder #

112.5488

Client Information		Billing/Invoices:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES			Ice:	YES NO	Container Material	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601			Cooler:	YES NO	Container Size (in MI)	YES NO
Contact:	Ray Filley			Sample Temp:		Accepted?	YES NO
Phone:	315-779-7054			Cooler Seal:	YES NO	Preervative	
Project:	Lead Testing			Pickup:	YES NO	Comments/Field Data	
Quote ID:				Dropoff:	C W		
Rush TAT Bus. Days:	2-5 5-7 7-10						
Release to DOH: Yes							
Email Results: Yes	rfilley@boces.com						
Fax Results: Yes	rfilley@boces.com						

  

Sample Information			Matrix		Number of Containers for Analysis Requested		Date/Time	
Description/Location	Date	Time	Initial	Type				
1 10-1	6/30/10	6:49	RF					
2 10-2		6:50						
3 9-1		6:31						
4 9-2		6:32						
5 2-1		6:47						
6 2-2		6:48						
7 1-1		7:06						
8 1-2		7:07						

  

Print Name and Company		Signature	Date/Time	Comments
Sampled:	Ray Filley	<i>[Signature]</i>	7/5/10	
Received:	David Thomas	<i>[Signature]</i>	7/6/10 1230	
Received:				
Received:				
Received:				
Received:				



J6G0288

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this notation.

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice  
 MNY Workorder #

W. STEER

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)			
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES	NO				
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES	NO				
Contact:	Ray Filley					Sample Temp:						
Phone:	315-779-7054					Cooler seal:	YES	NO				
Project:	Lead Testing					Pickup:	YES	NO				
Quote ID:		PO#:				Dropoff:	C	W				
Rush TAT Bus. Days:	2-5	5-7	7-10			Accepted?	YES	NO				
Release to DOH: Yes						Container Material						
Email Results: Yes	rfilley@booces.com		/ffrank@booces.com			Container size(in MI)						
Fax Results: Yes						Preervative						
Sample Information			Number of Containers for Analysis Requested			Comments/Field Data						
Description/Location	Date	Time	Initial	Matrix Type								
1 21-1	6/30/02	6:01	RF									
2 21-2		6:02										
3 23-1		6:21										
4 23-2		6:22										
5 22-1		6:05										
6 22-2		6:06										
7 12-1		6:55										
8 12-2		6:56										
Sampled: Ray Filley			Signature: [Signature]			Date/Time: 7/5/02						
Received: David Nolas			Signature: [Signature]			Date/Time: 7/5/02						
Received:			Signature:			Date/Time:						
Received:			Signature:			Date/Time:						
Received:			Signature:			Date/Time:						
Received:			Signature:			Date/Time:						



J6G0288

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive  
 Corland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3416  
 NY #10795, EPA #NY00935

# Microbac Laboratories, Inc. **CHAIN OF CUSTODY**

Samples must be returned on ice  
 MNY Workorder #

W. SHER

Client Information		Billing/Invoices		Analytix Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Heckler, Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:						Dropoff:	C W
Rush FAT Bus. Days:	2-5 5-7 7-10					Accepted?	YES NO
Release to DOH: Yes						Container Material	
Email Results: Yes	filley@boces.com					Container Size(In MI)	
Fax Results: Yes	ffhack@boce.s.com					Preservative	
Sample Information		Matrix		Number of Containers for Analytix Requested		Comments/Field Data	
Description/Location	Date	Time	Initial	Type			
1 16a-1	6/30/16	6:16	RF				
2 16a-2		6:17					
3 17-1		6:14					
4 17-2		6:15					
5 19-1		6:10					
6 19-2		6:11					
7 24-1		6:24					
8 24-2		6:25					
Print Name and Company		Signature		Date/Time		Comments	
Sampled:	Ray Filley			7/5/16 10:30			
Received:	Dana Thomas			7/5/16 12:30			
Received:							
Received:							
Received:							
Received:							



J6G0288

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this notion.



3821 Buck Drive  
 Corland NY 13045  
 Phone:(607)753-3403 Fax:(607)768-3415  
 NY #10796, EPA #NY000935

# Microbac Laboratories, Inc. Samples must be returned on ice

## CHAIN OF CUSTODY

MNY Workorder #

W. Stee

Client Information		Billing/Invoice:		Analyis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES			Ice:	YES NO	Container Material	YES NO
Address:	20104 NYS Route 3			Cooler:	YES NO	Container size (in MI)	YES NO
Contact:	Watertown, NY 13601			Sample Temp:		Preservative	
Phone:	Ray Filley			Cooler Seal:	YES NO	Accepted?	YES NO
Project:	315-779-7054			Pickup:	YES NO		
Quote ID:	Lead Testing			Dropoff:	C W		
Rush TAT Bus. Days:	2-5 5-7 7-10						
Release to DOH:	Yes						
Email Results:	Yes	rfilley@boces.com					
Fax Results:	Yes	rfilley@boces.com / fshack@boces.com					
PO#:							
Date Req.:							

  

Sample Information			Matrix		Number of Containers for Analysis Requested	Comments
Description/Location	Date	Time	Initial	Type		
1 25-1	6/30/10	6:27	RF			
2 25-2		6:28				
3 15-1		6:19				
4 15-2		6:20				
5 20-1		6:07				
6 20-2		6:09				
7 18-1		6:12				
8 18-2		6:13				

  

Print Name and Company	Signature	Date/Time
Sampled: Ray Filley	<i>[Signature]</i>	7/1/10 10:50
Received: David Daniels	<i>[Signature]</i>	7/5/10 12:30
Received:		
Received:		
Received:		
Received:		



J6G0288

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.