



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Jeferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: W. North

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 07/06/2016 00:00
Reported: 07/28/2016 22:18

Analytical Testing Parameters

Client Sample ID: 8-1
Lab Sample ID: J6G0207-01
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.083	0.015	0.0050	mg/L	G	07/19/16 1513	07/22/16 1011

Analytical Testing Parameters

Client Sample ID: 8-2
Lab Sample ID: J6G0207-02
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0050	0.015	0.0050	mg/L		07/19/16 1513	07/22/16 1013

Analytical Testing Parameters

Client Sample ID: 18-1
Lab Sample ID: J6G0207-03
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	<0.0050	0.015	0.0050	mg/L		07/19/16 1513	07/22/16 1014



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 18-2
Lab Sample ID: J6G0207-04
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1016

Analytical Testing Parameters

Client Sample ID: 7-1
Lab Sample ID: J6G0207-05
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.015, 0.015, 0.0050, mg/L, G, 07/19/16 1513, 07/22/16 1017

Analytical Testing Parameters

Client Sample ID: 7-2
Lab Sample ID: J6G0207-06
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1022



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 17-1
Lab Sample ID: J6G0207-07
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1023

Analytical Testing Parameters

Client Sample ID: 17-2
Lab Sample ID: J6G0207-08
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1025

Analytical Testing Parameters

Client Sample ID: 5-1
Lab Sample ID: J6G0207-09
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0071, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1029



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 5-2
Lab Sample ID: J6G0207-10
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1031

Analytical Testing Parameters

Client Sample ID: 3-1
Lab Sample ID: J6G0207-11
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1032

Analytical Testing Parameters

Client Sample ID: 3-2
Lab Sample ID: J6G0207-12
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1034



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 6-1
Lab Sample ID: J6G0207-13
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1035.

Analytical Testing Parameters

Client Sample ID: 6-2
Lab Sample ID: J6G0207-14
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1037.

Analytical Testing Parameters

Client Sample ID: 2-1
Lab Sample ID: J6G0207-15
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0074, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1038.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 2-2
Lab Sample ID: J6G0207-16
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0096, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1043

Analytical Testing Parameters

Client Sample ID: 1-1
Lab Sample ID: J6G0207-17
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1048

Analytical Testing Parameters

Client Sample ID: 1-2
Lab Sample ID: J6G0207-18
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1050



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 4-1
Lab Sample ID: J6G0207-19
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1051

Analytical Testing Parameters

Client Sample ID: 4-2
Lab Sample ID: J6G0207-20
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1513, 07/22/16 1053

Analytical Testing Parameters

Client Sample ID: 16-1
Lab Sample ID: J6G0207-21
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.011, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1054



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 16-2
Lab Sample ID: J6G0207-22
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 05:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.012, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1056

Analytical Testing Parameters

Client Sample ID: 21-1
Lab Sample ID: J6G0207-23
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.031, 0.015, 0.0050, mg/L, G, 07/19/16 1516, 07/22/16 1057

Analytical Testing Parameters

Client Sample ID: 21-2
Lab Sample ID: J6G0207-24
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0055, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1059



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 11-1
Lab Sample ID: J6G0207-25
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1100

Analytical Testing Parameters

Client Sample ID: 11-2
Lab Sample ID: J6G0207-26
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1108

Analytical Testing Parameters

Client Sample ID: 20-1
Lab Sample ID: J6G0207-27
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.027, 0.015, 0.0050, mg/L, G, 07/19/16 1516, 07/22/16 1109



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 20-2
Lab Sample ID: J6G0207-28
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0067, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1111

Analytical Testing Parameters

Client Sample ID: 10-1
Lab Sample ID: J6G0207-29
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.084, 0.015, 0.0050, mg/L, G, 07/19/16 1516, 07/22/16 1112

Analytical Testing Parameters

Client Sample ID: 10-2
Lab Sample ID: J6G0207-30
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0081, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1114



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 12-1
Lab Sample ID: J6G0207-31
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0054, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1115

Analytical Testing Parameters

Client Sample ID: 12-2
Lab Sample ID: J6G0207-32
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1117

Analytical Testing Parameters

Client Sample ID: 9-1
Lab Sample ID: J6G0207-33
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.016, 0.015, 0.0050, mg/L, G, 07/19/16 1516, 07/22/16 1118



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 9-2
Lab Sample ID: J6G0207-34
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1120

Analytical Testing Parameters

Client Sample ID: 15-1
Lab Sample ID: J6G0207-35
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1124

Analytical Testing Parameters

Client Sample ID: 15-2
Lab Sample ID: J6G0207-36
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1129



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 14-1
Lab Sample ID: J6G0207-37
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1130

Analytical Testing Parameters

Client Sample ID: 14-2
Lab Sample ID: J6G0207-38
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0059, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1132

Analytical Testing Parameters

Client Sample ID: 13-1
Lab Sample ID: J6G0207-39
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.018, 0.015, 0.0050, mg/L, G, 07/19/16 1516, 07/22/16 1133



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Analytical Testing Parameters

Client Sample ID: 13-2
Lab Sample ID: J6G0207-40
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1135

Analytical Testing Parameters

Client Sample ID: 19-1
Lab Sample ID: J6G0207-41
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.018, 0.015, 0.0050, mg/L, G, 07/19/16 1516, 07/22/16 1136

Analytical Testing Parameters

Client Sample ID: 19-2
Lab Sample ID: J6G0207-42
Sample Type: Grab

Collected By: RF-Client
Collection Date: 06/29/16
Collection Time: 06:29

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/19/16 1516, 07/22/16 1138

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
MDL: Minimum Detection Limit
PQL: Practical Quantitation Limit
G: Result fails applicable NYS drinking water standards



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0207

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc. - Chicagoland
NY Lab ID No: 12006
PA DEP ID: 68-04863

New York State Department of Health
Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Michael Fifield
Division Manager
07/28/2016 22:18

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at michael.fifield@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

W. NORTH

Microbac Laboratories, Inc.
Samples must be returned on ice
CHAIN OF CUSTODY
MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES		
Address:	20104 NYS Route 3 Watertown, NY 13601		
Contact:	Ray Filley		
Phone:	315-779-7054		
Project:	Lead Testing		
Quote ID:	PO#:		
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Release to DOH:	Yes		
Email Results:	Yes	rfilley@boces.com	fhawk@boces.com
Fax Results:	Yes		

Sample Information			Matrix	
Description/Location	Date	Time	Initial	Type
1 8-1	6/29/16	6:57	RF	
2 8-2	6:58			
3 18-1	6:52			
4 18-2	6:53			
5 7-1	5:59			
6 7-2	6:00			
7 17-1	5:55			
8 17-2	5:56			

Analysis Requested		Receiving Info (Lab Use Only)	
Number of Containers for Analysis Requested	Comments/Field Data	Ice:	YES NO
200.8 Lead		Cooler:	YES NO
P		Sample Temp:	YES NO
250		Cooler Seal:	YES NO
HNO3		Pickup:	YES NO
		Dropoff:	C W
		Accepted?	YES NO
		Container Material	
		Container Size (in MI)	
		Preservative	

Print Name and Company	Signature	Date/Time	Comments
Sampled: Ray Filley	<i>Ray Filley</i>	6/29/16 8:00	
Received: David Daniels	<i>David Daniels</i>	7/5/16 12:30	
Received:	<i>Yankee Walker</i>	7/5/16 12:30	
Received:			
Received:			
Received:			



J6G0207

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

W. Nores

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	YES NO
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:	PO#:					Dropoff:	C W
Rush TAT Bus. Days: < 2-5 5-7 7-10	Date Req:					Accepted?	YES NO
Release to DOH: Yes						Container Material	
Email Results: Yes	rfilley@boces.com					Container Size (in MI)	
Fax Results: Yes	fhawck@boct5.com					Preservative	
						Comments/Field Data	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			
1 1-1	6/29/02	5:45	RF				
2 1-2		5:42					
3 4-1		5:48					
4 4-2		5:49					
5 16-1		5:40					
6 16-2		5:41					
7 21-1		6:32					
8 21-2		6:33					
Print Name and Company				Signature			
Sampled: Ray Filley				<i>Ray Filley</i>			
Received: David Thomas				<i>David Thomas</i>			
Received:							
Received:							
Received:							
Received:							
Received:							
				Date/Time			
				6/29/02			
				7/3/02 12:30			



J6G0207

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information Name: Jefferson-Levits-Hamilton-Herkimer-Oneida BOCES Address: 20104 NYS Route 3 Watertown, NY 13601 Contact: Ray Filley Phone: 315-779-7054 Project: Lead Testing Quote ID: PO#:		Billing/Invoice: Rush TAT Bus. Days: 2-5 5-7 7-10 Date Req:	
Release to DOH: Yes Email Results: Yes Fax Results: Yes		rfilley@boces.com / fhawk@boce3.com	
Sample Information		Matrix Type	
Description/Location	Date	Time	Initial
1 11-1	6/29/16	6:15	RF
2 11-2		6:16	
3 20-1		6:30	
4 20-2		6:31	
5 10-1		6:17	
6 10-2		6:12	
7 12-1		6:13	
8 12-2		6:14	
Receiving Info (Lab Use Only) Ice: YES NO Cooler: YES NO Sample Temp: YES NO Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted? YES NO Container Material Container Size (in MI) Preservative Comment/Field Data		2008 Lead P 250 HNO3	
Analysis Requested		Number of Containers for Analysis Requested	
Comments Date/Time Signature Print Name and Company		Date/Time Signature Print Name and Company	
Sampled: Ray Filley Received: David Thomas Received: Received: Received: Received:		6/29/16 7/5/16 12:30 [Signature] [Signature] [Signature] [Signature]	



J6G0207

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
MNY Workorder #

W. NORTH

Client Information		Billing/Invoice:	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES		
Address:	20104 NYS Route 3 Watertown, NY 13601		
Contact:	Ray Filley		
Phone:	315-779-7054		
Project:	Lead Testing		
Quote ID:	PO#:		
Rush TAT Bus. Days: < 2-5 5-7 7-10	Date Req.:		
Release to DOH: Yes			
Email Results: Yes	rfilley@boces.com		
Fax Results: Yes	fhanuck@boct5.com		

Sample Information		Matrix	
Description/Location	Date	Time	Initial
9-1	6/29/10	6:09	RF
9-2		6:10	
15-1		6:18	
15-2		6:20	
14-1		6:22	
14-2		6:23	
13-1		6:26	
13-2		6:27	

Receiving Info (Lab Use Only)		Analysis Requested		Number of Containers for Analysis Requested		Comments/Field Data	
Ice:	YES NO						
Cooler:	YES NO						
Sample Temp:							
Cooler Seal:	YES NO						
Pickup:	YES NO						
Dropoff:	C W						
Accepted?	YES NO						
Container Material							
Container size (in MI)							
Preservative							

Print Name and Company		Signature	Date/Time	Comments
Sampled:	Ray Filley	<i>Ray Filley</i>	6/29/10	
Received:	Dawn Munn	<i>Dawn Munn</i>	7/3/10 1230	
Received:				
Received:				
Received:				
Received:				



J6G0207

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

W. Albert

Client Information		Billing/Invoices:		Analysis Requested		Receiving Info (Lab Use Only)	
Name: Jefferson-Lewis-Hamilton-Heckler, Oneida BOCES						Ice: YES NO	
Address: 20104 NYS Route 3						Cooler: YES NO	
Watertown, NY 13601						Sample Temp: YES NO	
Contact: Ray Filley						Cooler Seal: YES NO	
Phone: 315-779-7054						Pickup: YES NO	
Project: Lead Testing						Dropoff: C W	
Quote ID: PO#:						Accepted? YES NO	
Rush TAT Bur. Days: <2 2-5 5-7 7-10		Date Req.:				Container Material	
Release to DOH: Yes						Container Size(In MI)	
Email Results: Yes rfilley@boces.com		/ <i>fhack@boces.com</i>				Preservative	
Fax Results: Yes						Comments/Field Data	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			
1 19-1	6/29/10	6:28	RF	200.8 Lead			
2 19-2		6:29		P			
3				250			
4				HNO3			
5							
6							
7							
8							
Print Name and Company				Signature			
Sampled: Ray Filley				<i>[Signature]</i>			
Received: David P. Lus				<i>[Signature]</i>			
Received:				Date/Time: 6/29/10			
Received:				7/9/16 1230			
Received:							
Received:							
Received:							
Received:							



J6G0207

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.