



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Ohio 22

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 10/05/2016 12:30
Reported: 12/12/2016 13:39

Analytical Testing Parameters

Client Sample ID: 11A
Lab Sample ID: J6J0567-01
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00206, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1203

Analytical Testing Parameters

Client Sample ID: 42L
Lab Sample ID: J6J0567-02
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00293, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1209

Analytical Testing Parameters

Client Sample ID: 12A
Lab Sample ID: J6J0567-03
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00248, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1210



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 43R
Lab Sample ID: J6J0567-04
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00459, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1211

Analytical Testing Parameters

Client Sample ID: 42M
Lab Sample ID: J6J0567-05
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00699, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1212

Analytical Testing Parameters

Client Sample ID: 15A
Lab Sample ID: J6J0567-06
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00342, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1213



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 13A
Lab Sample ID: J6J0567-07
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00245, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1214

Analytical Testing Parameters

Client Sample ID: 9A
Lab Sample ID: J6J0567-08
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00171, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1215

Analytical Testing Parameters

Client Sample ID: 32
Lab Sample ID: J6J0567-09
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0161, 0.0150, 0.00100, mg/L, G, 12/05/16 1949, 12/07/16 1216



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 40
Lab Sample ID: J6J0567-10
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0423, 0.0150, 0.00100, mg/L, G, 12/05/16 1949, 12/07/16 1217

Analytical Testing Parameters

Client Sample ID: 32
Lab Sample ID: J6J0567-11
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.261, 0.0150, 0.00100, mg/L, GE, 12/05/16 1949, 12/07/16 1222

Analytical Testing Parameters

Client Sample ID: 15A
Lab Sample ID: J6J0567-12
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00232, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1223



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 6A
Lab Sample ID: J6J0567-13
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0126, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1224

Analytical Testing Parameters

Client Sample ID: 36
Lab Sample ID: J6J0567-14
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0144, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1225

Analytical Testing Parameters

Client Sample ID: 41
Lab Sample ID: J6J0567-15
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0142, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1226



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 14A
Lab Sample ID: J6J0567-16
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00178, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1227

Analytical Testing Parameters

Client Sample ID: 35
Lab Sample ID: J6J0567-17
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0145, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1228

Analytical Testing Parameters

Client Sample ID: 23
Lab Sample ID: J6J0567-18
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0106, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1229



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 14A
Lab Sample ID: J6J0567-19
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00190, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1232

Analytical Testing Parameters

Client Sample ID: 25L
Lab Sample ID: J6J0567-20
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00422, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1233

Analytical Testing Parameters

Client Sample ID: 10A
Lab Sample ID: J6J0567-21
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00265, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1236



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 42R
Lab Sample ID: J6J0567-22
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00419, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1238

Analytical Testing Parameters

Client Sample ID: 43M
Lab Sample ID: J6J0567-23
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00228, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1239

Analytical Testing Parameters

Client Sample ID: 16A
Lab Sample ID: J6J0567-24
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00169, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1240



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 30
Lab Sample ID: J6J0567-25
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.288, 0.0150, 0.00100, mg/L, GE, 12/05/16 1949, 12/07/16 1241

Analytical Testing Parameters

Client Sample ID: 26
Lab Sample ID: J6J0567-26
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.101, 0.0150, 0.00100, mg/L, GE, 12/05/16 1949, 12/07/16 1242

Analytical Testing Parameters

Client Sample ID: 24M
Lab Sample ID: J6J0567-27
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0873, 0.0150, 0.00100, mg/L, G, 12/05/16 1949, 12/07/16 1245



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 24L
Lab Sample ID: J6J0567-28
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0199, 0.0150, 0.00100, mg/L, G, 12/05/16 1949, 12/07/16 1246

Analytical Testing Parameters

Client Sample ID: 21
Lab Sample ID: J6J0567-29
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00998, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1247

Analytical Testing Parameters

Client Sample ID: 28
Lab Sample ID: J6J0567-30
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0605, 0.0150, 0.00100, mg/L, G, 12/05/16 1949, 12/07/16 1248



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 24R
Lab Sample ID: J6J0567-31
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0134, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1251

Analytical Testing Parameters

Client Sample ID: 25M
Lab Sample ID: J6J0567-32
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00533, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1252

Analytical Testing Parameters

Client Sample ID: 39
Lab Sample ID: J6J0567-33
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0151, 0.0150, 0.00100, mg/L, G, 12/05/16 1949, 12/07/16 1253



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 6B
Lab Sample ID: J6J0567-34
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0115, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1254

Analytical Testing Parameters

Client Sample ID: 29
Lab Sample ID: J6J0567-35
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0347, 0.0150, 0.00100, mg/L, G, 12/05/16 1949, 12/07/16 1258

Analytical Testing Parameters

Client Sample ID: 22
Lab Sample ID: J6J0567-36
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0387, 0.0150, 0.00100, mg/L, G, 12/05/16 1949, 12/07/16 1259



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 31
Lab Sample ID: J6J0567-37
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00884, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1300

Analytical Testing Parameters

Client Sample ID: 25R
Lab Sample ID: J6J0567-38
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00778, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1301

Analytical Testing Parameters

Client Sample ID: 43L
Lab Sample ID: J6J0567-39
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00327, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1302



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J0567

Analytical Testing Parameters

Client Sample ID: 38
Lab Sample ID: J6J0567-40
Sample Type: Grab

Collected By: FH-Client
Collection Date: 10/04/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0134, 0.0150, 0.00100, mg/L, 12/05/16 1949, 12/07/16 1303

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
E: Estimated result
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Yes, Item, Yes. Items include Custody Seals Intact, COC/Labels Agree, Received on Ice.

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795 New York State Department of Health
Microbac Laboratories, Inc. - Chicagoland NY Lab ID No: 12006 Pennsylvania Department of Environmental Protection
PA DEP ID: 68-04863

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale For Michael Fifield
Division Manager
12/12/2016 13:39

Go Green: Contact Michael Fifield to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

0110 22

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3 Watertown, NY 13601					Cooler:	YES NO
Contact:	Ray Filley					Sample Temp:	
Phone:	315-779-7054					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	3 2-5 5-7 7-10	Date Req.:				Accepted?:	YES NO
Release to DOH: Yes						Container Material:	
Email Results: Yes	filley@boces.com					Container Size (in ml):	
Fax Results: Yes	ffhuck@boce3.com					Preservative:	
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Initial	Matrix Type			
32	10/4	7:24	FFH				
40		7:26					
52		7:23					
15A		7:38					
60A		7:22					
36		7:27					
41		7:28					
14A		7:26					
Print Name and Company		Signature		Date/Time		Comments	
Sampled: Fred Huck				10/4 120			
Received: D. Becke				10/5 1230			
Received:							
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY
 MNY Workorder #

OH 10 22

Client Information		Billing/Invoices:		Analysis Requested		Recycling Info (Lab Use Only)	
Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida-BOCES Address: 20104 NYS Route 3 Watertown, NY 13601 Contact: Ray Filley Phone: 315-779-7054 Project: Lead Testing Quote ID: Rush TAT Bur. Days: 2-5 5-7 7-10 Release to DOH: Yes Email Results: Yes Fax Results: Yes		PO#: Date Req.: Email: rfilley@boces.com / rfilley@boce3.com Fax:		Ice: YES NO Cooler: YES NO Sample Temp: Cooler Seal: YES NO Pickup: YES NO Dropoff: C W Accepted? YES NO Container Material Container Size (in MI) Preservative		Comments/Field Data	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix Type			
1 35	10/4	7:25	RFH	P	200.8 Lead		
2 23		7:16		250			
3 14A		7:40		HNO3			
4 25L		7:13					
5 10A		7:32					
6 42R		7:30					
7 43M		7:31					
8 16A		7:38					
Print Name and Company				Signature			
Sampled: Fred Hawck				Date/Time: 10/4 1200			
Received: D. Bechele				Date/Time: 10-5 1230			
Received:				Date/Time:			
Received:				Date/Time:			
Received:				Date/Time:			
Received:				Date/Time:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this arrangement.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

OH 10 22

MNY Workorder #

Client Information		Billing/Invoice:		Analytix Requested		Receiving Info (Lab Use Only)	
Name:	Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Watertown, NY 13601					Sample Temp:	YES NO
Phone:	Ray Filley					Cooler Seal:	YES NO
Project:	315-779-7054					Pickup:	YES NO
Quote ID:	Lead Testing					Dropoff:	C W
Rush TAT Bur. Days:	2-5 5-7 7-10	PO#:				Accepted?	YES NO
Release to DOH: Yes		Date Req.:				Container Material:	
Email Results: Yes						Container Size (in ml):	
Fax Results: Yes						Preservative:	
						Comments/Field Data	

Sample Information		Matrix		Number of Containers for Analysis Requested		Comments
Description/Location	Date	Time	Initial	Type		
1 39	10/4	7:25	FF			
2 6B		7:12				
3 29		7:16				
4 22		7:14				
5 31		7:20				
6 25R		7:13				
7 43L		7:31				
8 38		7:25				

Print Name and Company	Signature	Date/Time
Sampled: Fred Hawk	<i>[Signature]</i>	10/4 1200
Received: D Breche	<i>[Signature]</i>	10-5 1230
Received:		
Received:		
Received:		

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this note...