



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

Jeferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: W. Wiley

Fred Hauck  
20104 NYS Route 3  
Watertown, NY 13601

Project / PO Number: N/A  
Received: 07/12/2016 12:30  
Reported: 07/31/2016 13:51

Analytical Testing Parameters

Client Sample ID: 23-1  
Lab Sample ID: J6G0529-01  
Sample Type: Grab

Collected By: RF-Client  
Collection Date: 07/08/16  
Collection Time: 06:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

| Metals                    | Result | Limit | PQL    | Units | Note | Prepared      | Analyzed      |
|---------------------------|--------|-------|--------|-------|------|---------------|---------------|
| Method: EPA 200.8 Rev 5.4 |        |       |        |       |      |               |               |
| Lead                      | 0.0060 | 0.015 | 0.0050 | mg/L  |      | 07/25/16 1542 | 07/26/16 1545 |

Analytical Testing Parameters

Client Sample ID: 23-2  
Lab Sample ID: J6G0529-02  
Sample Type: Grab

Collected By: RF-Client  
Collection Date: 07/08/16  
Collection Time: 06:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

| Metals                    | Result | Limit | PQL    | Units | Note | Prepared      | Analyzed      |
|---------------------------|--------|-------|--------|-------|------|---------------|---------------|
| Method: EPA 200.8 Rev 5.4 |        |       |        |       |      |               |               |
| Lead                      | 0.024  | 0.015 | 0.0050 | mg/L  | G    | 07/25/16 1542 | 07/26/16 1546 |

Analytical Testing Parameters

Client Sample ID: 13-1  
Lab Sample ID: J6G0529-03  
Sample Type: Grab

Collected By: RF-Client  
Collection Date: 07/08/16  
Collection Time: 07:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

| Metals                    | Result  | Limit | PQL    | Units | Note | Prepared      | Analyzed      |
|---------------------------|---------|-------|--------|-------|------|---------------|---------------|
| Method: EPA 200.8 Rev 5.4 |         |       |        |       |      |               |               |
| Lead                      | <0.0050 | 0.015 | 0.0050 | mg/L  |      | 07/25/16 1542 | 07/26/16 1548 |



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

Analytical Testing Parameters

Client Sample ID: 13-2
Lab Sample ID: J6G0529-04
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1542, 07/26/16 1553

Analytical Testing Parameters

Client Sample ID: 5-1
Lab Sample ID: J6G0529-05
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 06:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1542, 07/26/16 1554

Analytical Testing Parameters

Client Sample ID: 5-2
Lab Sample ID: J6G0529-06
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 06:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1542, 07/26/16 1559



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

Analytical Testing Parameters

Client Sample ID: 6-1
Lab Sample ID: J6G0529-07
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 06:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0052, 0.015, 0.0050, mg/L, 07/25/16 1542, 07/26/16 1600

Analytical Testing Parameters

Client Sample ID: 6-2
Lab Sample ID: J6G0529-08
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 06:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1542, 07/26/16 1602

Analytical Testing Parameters

Client Sample ID: 18-1
Lab Sample ID: J6G0529-09
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1542, 07/26/16 1603



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

Analytical Testing Parameters

Client Sample ID: 18-2
Lab Sample ID: J6G0529-10
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1605

Analytical Testing Parameters

Client Sample ID: 4-1
Lab Sample ID: J6G0529-11
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 06:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1606

Analytical Testing Parameters

Client Sample ID: 4-2
Lab Sample ID: J6G0529-12
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 06:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1611



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

Analytical Testing Parameters

Client Sample ID: 14-1
Lab Sample ID: J6G0529-13
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1612.

Analytical Testing Parameters

Client Sample ID: 14-2
Lab Sample ID: J6G0529-14
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1614.

Analytical Testing Parameters

Client Sample ID: 8-1
Lab Sample ID: J6G0529-15
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 06:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1615.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

Analytical Testing Parameters

Client Sample ID: 8-2
Lab Sample ID: J6G0529-16
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 06:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1620

Analytical Testing Parameters

Client Sample ID: 19-1
Lab Sample ID: J6G0529-17
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1621

Analytical Testing Parameters

Client Sample ID: 19-2
Lab Sample ID: J6G0529-18
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1623



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

Analytical Testing Parameters

Client Sample ID: 16-1
Lab Sample ID: J6G0529-19
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1624

Analytical Testing Parameters

Client Sample ID: 16-2
Lab Sample ID: J6G0529-20
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1635

Analytical Testing Parameters

Client Sample ID: 3-1
Lab Sample ID: J6G0529-21
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 06:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0066, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1637



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

Analytical Testing Parameters

Client Sample ID: 3-2
Lab Sample ID: J6G0529-22
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 06:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1638

Analytical Testing Parameters

Client Sample ID: 7-1
Lab Sample ID: J6G0529-23
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 06:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.012, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1640

Analytical Testing Parameters

Client Sample ID: 7-2
Lab Sample ID: J6G0529-24
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 06:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1641





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

Analytical Testing Parameters

Client Sample ID: 10-2
Lab Sample ID: J6G0529-25
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1643.

Analytical Testing Parameters

Client Sample ID: 12-1
Lab Sample ID: J6G0529-26
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1647.

Analytical Testing Parameters

Client Sample ID: 12-2
Lab Sample ID: J6G0529-27
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1649.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

Analytical Testing Parameters

Client Sample ID: 9-1
Lab Sample ID: J6G0529-28
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1654.

Analytical Testing Parameters

Client Sample ID: 9-2
Lab Sample ID: J6G0529-29
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1655.

Analytical Testing Parameters

Client Sample ID: 17-1
Lab Sample ID: J6G0529-30
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:04

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1657.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

Analytical Testing Parameters

Client Sample ID: 17-2
Lab Sample ID: J6G0529-31
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1658

Analytical Testing Parameters

Client Sample ID: 11-1
Lab Sample ID: J6G0529-32
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0062, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1700

Analytical Testing Parameters

Client Sample ID: 11-2
Lab Sample ID: J6G0529-33
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0062, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1701



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

Analytical Testing Parameters

Client Sample ID: 15-1
Lab Sample ID: J6G0529-34
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1703

Analytical Testing Parameters

Client Sample ID: 15-2
Lab Sample ID: J6G0529-35
Sample Type: Grab

Collected By: RF-Client
Collection Date: 07/08/16
Collection Time: 07:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.0050, 0.015, 0.0050, mg/L, 07/25/16 1545, 07/26/16 1704

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
MDL: Minimum Detection Limit
PQL: Practical Quantitation Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, No, Yes. Rows: Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, Received on Ice (or not required)

Project Requested Certification(s)

Microbac Laboratories, Inc. - Chicagoland
NY Lab ID No: 12006
PA DEP ID: 68-04863

New York State Department of Health
Pennsylvania Department of Environmental Protection



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6G0529

**Report Comments**

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

**Reviewed and Approved By:**

A handwritten signature in blue ink that reads "Michael Fifield".

Michael Fifield  
Division Manager  
07/31/2016 13:51

**Go Green:** Contact Michael Fifield to set up email reporting and invoicing options.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Michael Fifield, Project Manager at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com). You may also contact Michael Fifield, Managing Director at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com) or Robert Crookston, President at [robert.crookston@microbac.com](mailto:robert.crookston@microbac.com).*

| Client Information                                   |        |   |         | Billing/Invoice:    |      |                     |             | Analysis Requested                          |  |           |  | Receiving Info (Lab Use Only)       |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
|--|--------|---|---------|---------------------|------|---------------------|-------------|---|--|-----------|--|-------------------------------------|--|-----------|--|---------------------|--|--------------------|--|------------------|--|------------------|--|---------------------|--|----------------|--|--------------|--|--------------------|--|-----------------------|--|--------------|--|---------------------|--|
| Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES |        | Address: 20104 NYS Route 3<br>Watertown, NY 13601 |         | Contact: Ray Filley |      | Phone: 315-779-7054 |             | Project: Lead Testing                       |  | Quote ID: |  | Ruth TAT Bus. Days: <2 2-5 5-7 7-10 |  | Date Req: |  | Release to DOH: Yes |  | Email Results: Yes |  | Fax Results: Yes |  | Accepted? YES NO |  | Cooler Seal: YES NO |  | Pickup: YES NO |  | Dropoff: C W |  | Container Material |  | Container Size(in MI) |  | Preservative |  | Comments/Field Data |  |
| Sample Information                                   |        |   |         | Matrix Type         |      |                     |             | Number of Containers for Analysis Requested |  |           |  | Comments                            |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| Description/Location                                 | Date   | Time  | Initial | Date                | Time | Initial             | Matrix Type |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| 1 23-1   | 7/2/14 | 6:49  | RF      |                     |      |                     |             |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| 2 23-2   |        | 6:50  |         |                     |      |                     |             |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| 3 13-1   |        | 7:14  |         |                     |      |                     |             |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| 4 13-2   |        | 7:15  |         |                     |      |                     |             |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| 5  |        |   |         |                     |      |                     |             |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| 6  |        |   |         |                     |      |                     |             |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| 7  |        |   |         |                     |      |                     |             |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| 8  |        |   |         |                     |      |                     |             |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| Print Name and Company                               |        |   |         | Signature           |      |                     |             | Date/Time                                   |  |           |  | Comments                            |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| Sampled: Ray Filley                                  |        |   |         |                     |      |                     |             | 7/9/14                                      |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| Received: David Rowas                                |        |   |         |                     |      |                     |             | 7/12/14 12:30                               |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| Received:  |        |   |         |                     |      |                     |             |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| Received:  |        |   |         |                     |      |                     |             |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| Received:  |        |   |         |                     |      |                     |             |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |
| Received:  |        |   |         |                     |      |                     |             |   |  |           |  |                                     |  |           |  |                     |  |                    |  |                  |  |                  |  |                     |  |                |  |              |  |                    |  |                       |  |              |  |                     |  |



J6G0529

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

# Microbac Laboratories, Inc. Samples must be returned on ice

## CHAIN OF CUSTODY

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00995

MNY Workorder #

W 601124

| Client Information                 |  | Billing/Invoice: |  |
|------------------------------------|--|------------------|--|
| Name:                              | Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES |                  |  |
| Address:                           | 20104 NYS Route 3<br>Watertown, NY 13601       |                  |  |
| Contact:                           | Ray Filley                                     |                  |  |
| Phone:                             | 315-779-7054                                   |                  |  |
| Project:                           | Lead Testing                                   |                  |  |
| Quote ID:                          | PO#:   |                  |  |
| Rush TAT Bus. Days: < 2-5 5-7 7-10 | Date Req:                                      |                  |  |
| Release to DOH: Yes                |  |                  |  |
| Email Results: Yes                 | rfilley@booces.com / fhawk@booces.com          |                  |  |
| Fax Results: Yes                   |  |                  |  |


| Sample Information   |        | Matrix | Number of Containers for Analysis Requested |  | Comments/Field Data |
|----------------------|--------|--------|---|--|---------------------|
| Description/Location | Date   | Type   |   |  |                     |
| 1 5-1                | 7/8/10 | RF     |   |  |                     |
| 2 5-2                |        |        |   |  |                     |
| 3 6-1                |        |        |   |  |                     |
| 4 6-2                |        |        |   |  |                     |
| 5 18-1               |        |        |   |  |                     |
| 6 18-2               |        |        |   |  |                     |
| 7 4-1                |        |        |   |  |                     |
| 8 4-2                |        |        |   |  |                     |

| Receiving Info (Lab Use Only) |        |
|-------------------------------|--------|
| Ice:                          | YES NO |
| Cooler:                       | YES NO |
| Sample Temp:                  |        |
| Cooler Seal:                  | YES NO |
| Pickup:                       | YES NO |
| Dropoff:                      | C W    |
| Accepted?                     | YES NO |
| Container Material            |        |
| Container Size(In Mil)        |        |
| Preservative                  |        |

| Print Name and Company |              | Signature          | Date/Time    | Comments |
|------------------------|--------------|--------------------|--------------|----------|
| Sampled:               | Ray Filley   | <i>[Signature]</i> | 7/9/10       |          |
| Received:              | David Thomas | <i>[Signature]</i> | 7/12/10 1230 |          |
| Received:              |              |                    |              |          |
| Received:              |              |                    |              |          |
| Received:              |              |                    |              |          |
| Received:              |              |                    |              |          |



Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

**Microbac Laboratories, Inc. Samples must be returned on ice**  
**CHAIN OF CUSTODY**

3821 Buck Drive  
 Corlind NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00995

MNY Workorder #

| Client Information   |   | Billing/Invoice: |         | Analysis Requested                          |        | Receiving Info (Lab Use Only) |        |
|----------------------|---|------------------|---------|---|--------|-------------------------------|--------|
| Name:                | Jefferson-Lewis-Hamilton-Fentkimer Oneida BOCES |                  |         | Ice:  | YES NO | Ice:                          | YES NO |
| Address:             | 20104 NYS Route 3<br>Watertown, NY 13601        |                  |         | Cooler:                                     | YES NO | Cooler:                       | YES NO |
| Contact:             | Ray Filley                                      |                  |         | Sample Temp:                                |        | Sample Temp:                  |        |
| Phone:               | 315-779-7054                                    |                  |         | Cooler Seal:                                | YES NO | Cooler Seal:                  | YES NO |
| Project:             | Lead Testing                                    |                  |         | Pickup:                                     | YES NO | Pickup:                       | YES NO |
| Quote ID:            |   | PO#:             |         | Dropoff:                                    | C W    | Dropoff:                      | C W    |
| Rush TAT Bus. Days:  | 2-5 5-7 7-10                                    | Date Req:        |         | Accepted?                                   | YES NO | Accepted?                     | YES NO |
| Release to DOH: Yes  |   |                  |         | Container Material                          |        | Container Material            |        |
| Email Results: Yes   | filley@booces.com                               |                  |         | Container Size(in MI)                       |        | Container Size(in MI)         |        |
| Fax Results: Yes     | rfilley@booces.com                              |                  |         | Preservative                                |        | Preservative                  |        |
| Sample Information   |   | Matrix           |         | Number of Containers for Analysis Requested |        | Comments/Field Data           |        |
| Description/Location | Date  | Time             | Initial | Type  |        |                               |        |
| 1 14-1               | 7/13/12   | 7:10             | RF      |   |        |                               |        |
| 2 14-2               |   | 7:17             |         |   |        |                               |        |
| 3 8-1                |   | 6:37             |         |   |        |                               |        |
| 4 8-2                |   | 6:38             |         |   |        |                               |        |
| 5 19-1               |   | 7:09             |         |   |        |                               |        |
| 6 19-2               |   | 7:10             |         |   |        |                               |        |
| 7 16-1               |   | 7:11             |         |   |        |                               |        |
| 8 16-2               |   | 7:12             |         |   |        |                               |        |

| Print Name and Company | Signature          | Date/Time     | Comments |
|------------------------|--------------------|---------------|----------|
| Sampled: Ray Filley    | <i>[Signature]</i> | 7/13/12 07:30 |          |
| Received: David Thomas | <i>[Signature]</i> | 7/12/12 12:30 |          |
| Received:              |                    |               |          |
| Received:              |                    |               |          |
| Received:              |                    |               |          |
| Received:              |                    |               |          |



J6G0529

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this notice.



# Microbac Laboratories, Inc. Samples must be returned on ice

## CHAIN OF CUSTODY

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY008936

MNY Workorder # 6010184

| Client Information                 |  | Billing/Invoice: |  |
|------------------------------------|--|------------------|--|
| Name:                              | Jefferson-Lewis-Hamilton-Herkimer-Oswego BOCES |                  |  |
| Address:                           | 20104 NYS Route 3<br>Watertown, NY 13601       |                  |  |
| Contact:                           | Ray Filley                                     |                  |  |
| Phone:                             | 315-779-7054                                   |                  |  |
| Project:                           | Lead Testing                                   |                  |  |
| Quote ID:                          | PO#:   |                  |  |
| Rush TAT Bus. Days: < 2-5 5-7 7-10 | Date Req.:                                     |                  |  |
| Release to DOH: Yes                |  |                  |  |
| Email Results: Yes                 | rfilley@boces.com / fhawk@boces.com            |                  |  |
| Fax Results: Yes                   |  |                  |  |

| Sample Information   |        |      | Analytix Requested |             | Receiving Info (Lab Use Only)               |                    |
|----------------------|--------|------|--------------------|-------------|---|--------------------|
| Description/Location | Date   | Time | Initial            | Matrix Type | Number of Containers for Analysis Requested | Comments/Field No. |
| 1 3-1                | 7/8/16 | 6:58 | RF                 |             |   |                    |
| 2 3-2                |        | 6:59 |                    |             |   |                    |
| 3 7-1                |        | 6:41 |                    |             |   |                    |
| 4 7-2                |        | 6:42 |                    |             |   |                    |
| 5 10-2               |        | 7:25 |                    |             |   |                    |
| 6 12-1               |        | 7:30 |                    |             |   |                    |
| 7 12-2               |        | 7:31 |                    |             |   |                    |
| 8                    |        |      |                    |             |   |                    |

| Print Name and Company | Signature          | Date/Time     | Comments |
|------------------------|--------------------|---------------|----------|
| Sampled: Ray Filley    | <i>[Signature]</i> | 7/8/16        |          |
| Received: David Thomas | <i>[Signature]</i> | 7/12/16 12:30 |          |
| Received:              |                    |               |          |
| Received:              |                    |               |          |
| Received:              |                    |               |          |
| Received:              |                    |               |          |



J6G0529

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

W. Wiley

| Client Information     |  | Billing/Invoice: |         | Analysis Requested                          |        | Receiving Info (Lab Use Only) |        |
|------------------------|--|------------------|---------|---|--------|-------------------------------|--------|
| Name:                  | Jefferson-Lewis-Hamilton-Herkimer Oneida BOCES |                  |         | Ice:  | YES NO | Accepted?                     | YES NO |
| Address:               | 20104 NYS Route 3<br>Watertown, NY 13601       |                  |         | Cooler:                                     | YES NO | Container Material            |        |
| Contact:               | Ray Filley                                     |                  |         | Sample Temp:                                |        | Container size (in MI)        |        |
| Phone:                 | 315-779-7054                                   |                  |         | Cooler Seal:                                | YES NO | Preservative                  |        |
| Project:               | Lead Testing                                   |                  |         | Pickup:                                     | YES NO | Comments/Field Data           |        |
| Quote ID:              |  | PO#:             |         | Dropoff:                                    | C W    |                               |        |
| Rush TAT Bus. Days:    | <2 2-5 5-7 7-10                                | Date Req:        |         |   |        |                               |        |
| Release to DOH: Yes    |  |                  |         |   |        |                               |        |
| Email Results: Yes     | rfilley@booces.com                             |                  |         |   |        |                               |        |
| Fax Results: Yes       | ffhawck@boce5.com                              |                  |         |   |        |                               |        |
| Sample Information     |  |                  |         | Number of Containers for Analysis Requested |        |                               |        |
| Description/Location   | Date   | Time             | Initial | Matrix Type                                 |        |                               |        |
| 1 9-1                  | 7/6/12   | 7:23             | RF      |   |        |                               |        |
| 2 9-2                  |  | 7:24             |         |   |        |                               |        |
| 3 17-1                 |  | 7:04             |         |   |        |                               |        |
| 4 17-2                 |  | 7:05             |         |   |        |                               |        |
| 5 11-1                 |  | 7:27             |         |   |        |                               |        |
| 6 11-2                 |  | 7:28             |         |   |        |                               |        |
| 7 15-1                 |  | 7:20             |         |   |        |                               |        |
| 8 15-2                 |  | 7:21             |         |   |        |                               |        |
| Print Name and Company |  |                  |         | Signature                                   |        | Date/Time                     |        |
| Sampled: Ray Filley    |  |                  |         | [Signature]                                 |        | 7/5/10 0930                   |        |
| Received: Darci Thomas |  |                  |         | [Signature]                                 |        | 7/2/16 1230                   |        |
| Received:              |  |                  |         |   |        |                               |        |
| Received:              |  |                  |         |   |        |                               |        |
| Received:              |  |                  |         |   |        |                               |        |
| Received:              |  |                  |         |   |        |                               |        |



J6G0529

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.