



Microbac Laboratories, Inc., New York Division  
**CERTIFICATE OF ANALYSIS**

J0C0643

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Watertown Massey

Fred Hauck  
 20104 NYS Route 3  
 Watertown, NY 13601

Project / PO Number: Watertown Massey  
 Received: 03/06/2020  
 Reported: 03/20/2020

**Analytical Testing Parameters**

Client Sample ID:	10	Collected By:	RF-Client
Sample Matrix:	Drinking Water	Collection Date:	03/05/2020 7:15
Lab Sample ID:	J0C0643-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.0028	0.015 AL	0.0010	mg/L		03/16/20 0819	03/16/20 1027	LLW

Client Sample ID:	6	Collected By:	RF-Client
Sample Matrix:	Drinking Water	Collection Date:	03/05/2020 7:11
Lab Sample ID:	J0C0643-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.358	0.015 AL	0.0500	mg/L		03/16/20 1402	03/18/20 1323	DLO

Client Sample ID:	5	Collected By:	RF-Client
Sample Matrix:	Drinking Water	Collection Date:	03/05/2020 7:10
Lab Sample ID:	J0C0643-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.153	0.015 AL	0.0010	mg/L		03/16/20 0819	03/16/20 1038	LLW

Client Sample ID:	1	Collected By:	RF-Client
Sample Matrix:	Drinking Water	Collection Date:	03/05/2020 7:05
Lab Sample ID:	J0C0643-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.0010	0.015 AL	0.0010	mg/L		03/16/20 1100	03/16/20 1127	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0643

<b>Client Sample ID:</b> 11	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF-Client
<b>Lab Sample ID:</b> J0C0643-05		<b>Collection Date:</b> 03/05/2020 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0027	0.015 AL	0.0010	mg/L		03/16/20 1100	03/16/20 1129	DLO

<b>Client Sample ID:</b> 2	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF-Client
<b>Lab Sample ID:</b> J0C0643-06		<b>Collection Date:</b> 03/05/2020 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0059	0.015 AL	0.0020	mg/L	D	03/16/20 1100	03/17/20 1606	DLO

<b>Client Sample ID:</b> 8	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF-Client
<b>Lab Sample ID:</b> J0C0643-07		<b>Collection Date:</b> 03/05/2020 7:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.0019	0.015 AL	0.0010	mg/L		03/16/20 1100	03/16/20 1136	DLO

<b>Client Sample ID:</b> 4	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> RF-Client
<b>Lab Sample ID:</b> J0C0643-08		<b>Collection Date:</b> 03/05/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	0.242	0.015 AL	0.0010	mg/L		03/16/20 1100	03/16/20 1138	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0C0643

Client Sample ID: 9A	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/05/2020 7:09
Lab Sample ID: J0C0643-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	<b>0.0359</b>	0.015 AL	0.0010	mg/L		03/16/20 1100	03/16/20 1140	DLO

Client Sample ID: 9B	Collected By: RF-Client
Sample Matrix: Drinking Water	Collection Date: 03/05/2020 7:08
Lab Sample ID: J0C0643-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4</b>								
Lead	<b>0.0531</b>	0.015 AL	0.0010	mg/L		03/16/20 1100	03/16/20 1142	DLO

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- D: The sample was diluted due to matrix interference.
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Shannon Weeks  
Customer Relationship Coordinator  
Reported: 03/20/2020 11:53

