



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7J0871

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Lead Testing 2016

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: North Elem 4
Received: 10/02/2017
Reported: 10/16/2017

Analytical Testing Parameters

Table with sample information: Client Sample ID: 56, Sample Matrix: Drinking Water, Lab Sample ID: J7J0871-01, Collected By: RF-Client, Collection Date: 09/29/2017 7:36

Table with analytical results: Lead and/or Copper, Total - ICP/MS, Result: 0.0269, Limit(s): 0.015 AL, RL: 0.000500, Units: mg/L, Prepared: 10/14/17 1141, Analyzed: 10/15/17 1337, Lab: NY

Table with sample information: Client Sample ID: 53, Sample Matrix: Drinking Water, Lab Sample ID: J7J0871-02, Collected By: RF-Client, Collection Date: 09/29/2017 7:32

Table with analytical results: Lead and/or Copper, Total - ICP/MS, Result: 0.0151, Limit(s): 0.015 AL, RL: 0.000500, Units: mg/L, Prepared: 10/14/17 1145, Analyzed: 10/15/17 1337, Lab: NY

Table with sample information: Client Sample ID: 45, Sample Matrix: Drinking Water, Lab Sample ID: J7J0871-03, Collected By: RF-Client, Collection Date: 09/29/2017 7:30

Table with analytical results: Lead and/or Copper, Total - ICP/MS, Result: 0.0126, Limit(s): 0.015 AL, RL: 0.000500, Units: mg/L, Prepared: 10/14/17 1145, Analyzed: 10/15/17 1337, Lab: NY

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7J0871

**Report Comments**

*Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.*

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.*

**Reviewed and Approved By:**

A handwritten signature in black ink, appearing to read "Christine Pechacek", written in a cursive style.

Christine Pechacek

Client Services Manager

Reported: 10/16/2017 16:05

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

*NORTH Elm*

Samples must be returned on ice

MNY Workorder #



Jefferson-Lewis-Hamilton-Herkimer-Oneid

**Client Information**

Name: Jefferson-Lewis-Hamilton-Herkimer-Oneid BOCES  
 Address: 20104 NYS Route 3  
 Watertown, NY 13601  
 Contact: Ray Filley  
 Phone: 315-779-7054  
 Project: Lead Testing  
 Quote ID: \_\_\_\_\_  
 Rush TAT Bus. Days: 2-5 5-7 7-10  
 Release to DOH: Yes  
 Email Results: Yes  
 Fax Results: Yes  
 PO#: \_\_\_\_\_  
 Date Req: \_\_\_\_\_  
 Email: [rfilley@boces.com](mailto:rfilley@boces.com)  
 Fax: [ffhuck@boce3.com](mailto:ffhuck@boce3.com)

1	Description/Location	Sample Information			Matrix Type	Number of Containers for Analysis Requested	Comments/Field Data
		Date	Time	Initial			
	200.8 Lead				P		
					250		
					HNO3		

**Receiving Info (Lab Use Only)**

Ice: YES  NO   
 Cooler: YES  NO   
 Sample Temp: \_\_\_\_\_  
 Cooler pack: YES  NO   
 Pickup: YES  NO   
 Dropoff: C  W   
 Accepted? YES  NO   
 Container Material \_\_\_\_\_  
 Container Size (in MI) \_\_\_\_\_  
 Preservative \_\_\_\_\_

Print Name and Company	Signature	Date/Time	Comments
Raymond Filley	<i>[Signature]</i>	9/29/17	
Ernest Spencer	<i>[Signature]</i>	10/2/17 9:45	No Acd
Ernest Spencer	<i>[Signature]</i>	10/2/17	
Nick Hanna	<i>[Signature]</i>	10/2/17	
		10/2/17 12:10	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.