



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7J0872

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Lead Testing 2016

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: Knick 3
Received: 10/02/2017
Reported: 10/16/2017

Analytical Testing Parameters

Table with 2 columns: Client Sample ID: 22, Sample Matrix: Drinking Water, Lab Sample ID: J7J0872-01; Collected By: RF-Client, Collection Date: 09/29/2017 7:17

Table with 10 columns: Lead and/or Copper, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0357, 0.015 AL, 0.000500, mg/L, 10/14/17 1145, 10/15/17 1337, NY

Table with 2 columns: Client Sample ID: 23, Sample Matrix: Drinking Water, Lab Sample ID: J7J0872-02; Collected By: RF-Client, Collection Date: 09/29/2017 7:15

Table with 10 columns: Lead and/or Copper, Total - ICP/MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0336, 0.015 AL, 0.000500, mg/L, 10/14/17 1139, 10/15/17 1337, NY

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Handwritten signature of Christine Pechacek

Christine Pechacek
Client Services Manager
Reported: 10/16/2017 16:22

Kwick ③

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice

MNY Workorder #

Analysis Requested

Billing/Invoice

Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES
Address: 20104 NYS Route 3
 Watertown, NY 13601
Contact: Ray Filley
Phone: 315-779-7054
Project: Lead Testing
Quote ID: _____

Rush TAT Est. Days: 3 2-5 5-7 7-10
Release to DOM: Yes
Email Results: Yes
Fax Results: Yes
PO#: _____
Date Req.: _____
Site: filley@boces.com / fhauck@boce3.com

Sample Information

Description/Location	Date	Time	Initial	Matrix Type
22	9/29	7:17	RF	250 HNO3
23	9/29	7:15	RF	

Sampled:	Print Name/and Company	Signature	Date/Time
Received:	<i>[Signature]</i>	<i>[Signature]</i>	9/29/17
Received:	Ernest Spencer	<i>[Signature]</i>	10/20/17
Received:	Ernest Spencer	<i>[Signature]</i>	10/21/17
Received:	Nicole Hammer	<i>[Signature]</i>	10/21/19
Received:			

Container Material	Container Size (in MI)	Preservative	Accepted?	Notes
			YES NO	
			YES NO	
			YES NO	
			YES NO	
			YES NO	
			YES NO	

Number of Containers for Analysis Requested	Comments/Field Data



Jefferson-Lewis-Hamilton-Herkimer-Oneid

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.