



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J711443

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Starbock 3

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 09/18/2017
Reported: 10/06/2017

Analytical Testing Parameters

Table with 4 columns: Client Sample ID (63), Sample Matrix (Drinking Water), Lab Sample ID (J711443-01), Collected By (RF-Client), Collection Date (09/15/2017 7:25)

Table with 10 columns: Lead and/or Copper, Total - ICP/MS, Result (0.316), Limit(s) (0.015 AL), RL (0.000500), Units (mg/L), Note, Prepared (09/26/17 1212), Analyzed (10/02/17 1630), Lab (NY)

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: US EPA Action Level
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Signature of Renee Lantz

Renee Lantz
Project Manager
Reported: 10/06/2017 09:42

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

STABECK 3
 Billing/Invoice

Client Information
 Name: Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES
 Address: 20104 NYS Route 3
 Watertown, NY 13601
 Contact: Ray Filley
 Phone: 315-779-7054
 Project: Lead Testing
 Quote ID: _____
 Rush TAT Bar. Day: 3 2-5 5-7 7-10 PO#: _____
 Release to DOM: Yes Date Req: _____
 Email Results: Yes rfilley@boces.com
 Fax Results: Yes ffilley@boces.com / ffilley@boce3.com

1	Description/Location	Sample Information			Matrix Type	Number of Containers for Analysis Requested	Comments
		Date	Time	Initial			
	603	9/15/17	7:25	RF	250 HNO3	200.8 Lead P	
2							
3							
4							
5							
6							
7							
8							



J711443

Receiving Info (Lab Use Only)
 Ice: YES NO
 Cooler: YES NO
 Sample Temp: NA
 Cooler Seal: YES NO
 Pickup: YES NO
 Dropoff: C W
 Accepted? YES NO
 Container Material: _____
 Container Size (in MI): _____
 Preservative: _____
 Comm: _____

Print Name and Company
 Sampled: RAY FILLEY
 Received: Ernest Sparr
 Received: Ernest Sparr
 Received: Cayla Atchison
 Received: _____
 Received: _____

Signature
 [Signatures of Ernest Sparr and Cayla Atchison]
 Date/Time: 9/15/17 09:00
 9/16/17 14:00
 9/18/17 15:40
 9/18/17 15:30

Acid
 HNO3 added
 9/19/17
 1102CA

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement to do so.