



Office: (203) 341-1271  
Fax: (203) 341-1277  
Cell Phone: (203) 505-9216  
Email: thunyadi@westportps.org

**Theodore J. Hunyadi**  
*Director of Facilities and Security*

*TH* 2/20/18

**TO:** ALL QUALIFIERS

**SUBJECT:** ADDENDUM #1 – LONG LOTS ELEVATOR CONTROLLER UPGRADE  
BID # 18-007 - BOE

**DATE:** February 20, 2018

Please note addendum change as follows for the above-mentioned BID:

- Scope of Work - PAGE 11

**3. Fire Alarm Scope of Work:**

The existing Notifier addressable fire alarm system shall be modified to include;

- a) Addressable smoke detector for the 1<sup>st</sup> floor elevator lobby, 1 smoke detector for the 2<sup>nd</sup> floor elevator lobby and 1 smoke detector for the elevator machine room.
- b) 3 addressable relay output modules shall be provided at the elevator controller to allow for interconnections to the elevator equipment to recall the elevator upon activation of a fire alarm device.
- c) The detectors shall be provided and installed by the Westport Board of Education's fire alarm service company, Integrated Technical Systems in Wallingford, CT 203-265-8100.
- d) The detectors shall be integrated, configured and programmed to work with the existing fire alarm control panel and existing multi-point digital dialer.
- e) Upon completion and testing of the devices a representative from I.T.S will meet with the elevator equipment provider and the State Elevator Inspector for final testing.

**END OF ADDENDUM #1**