
INTEROFFICE MEMORANDUM

TO: All Bidders
FROM: Theodore Hunyadi
SUBJECT: Addendum to bid 17-015-BOE
DATE: March 27, 2017
CC: Elio Longo, Phil Cross



3/27/17

Addendum to bid 17-015-BOE, Purchase and Installation of Cameras and Video Monitoring Software.

Additional information and responsibilities:

- The exterior end of the cable will be terminated with a jack (e.g., biscuit box) with a service loop of 20 feet. The cable will be left hanging inside of the building at the site of future penetration by the camera installation vendor. The wiring vendor will coordinate with the camera installation vendor to identify the locations of the cameras.
- The camera installation vendor will be responsible for the penetration and re-sealing of the building envelope to code.
- Vendor will provide patch cords to connect cameras to cables ran by the wiring vendor.