



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis


Name: Parkway School
 Greenwich Public Schools - Cordes George
 290 Greenwich Ave
 Greenwich, CT 06830-6521
Sample Date: 6/23/2021 7:40 AM
Receipt Date: 6/23/2021 3:20 PM
Report Date: 6/28/2021
Sample Site: DISTRIBUTION SYSTEM

Sample ID#: 268111
Sample Type: Drinking Water
Sample Source: PS029
Sampler: PD
PWS ID: CT0570212

Parameter	Sample Result	Units	Method	Minimum Detection	Analysis Date	Analyst
Metals						
Copper	0.16	mg/L	EPA 200.5	0.005	6/28/2021 11:00	TJB
Lead	<0.001	mg/L	EPA 200.5	0.001	6/28/2021 11:00	TJB

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
* = Above Specified Limit

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.