

Water Testing Results - Pleasant Hill School District
Action Level is 15 parts per billion (ppb)

Fixture Location / Description	Fixture ID #	Test Date	Test Results (ppb)
PHES K-1 Commons Drinking Fountain *RETEST*	20810100-001DW	6/15/2021	25.8
PHES Classroom #17 Drinking Fountain	20810100-002DW	6/15/2021	4.38
PHES Classroom #14 Drinking Fountain	20810100-003DW	6/15/2021	9
PHES Classroom #12 Drinking Fountain	20810100-004DW	6/15/2021	3.48
PHES Classroom #13 Drinking Fountain	20810100-005DW	6/15/2021	9.62
PHES Classroom #15 Drinking Fountain	20810100-006DW	6/15/2021	9.07
PHES 5th Grade Commons Drinking Fountain	20810100-007DW	6/15/2021	2.48
PHES Classroom #1 Drinking Fountain	20810100-008DW	6/15/2021	3.72
PHES Classroom #3 Drinking Fountain	20810100-010DW	6/15/2021	12.3
PHES Classroom #4 Drinking Fountain	20810100-011DW	6/15/2021	2.3
PHES 2nd Grade Commons / Title I Drinking Fountain	20810100-012DW	6/15/2021	24.9
PHES Classroom #5 Drinking Fountain	20810100-013DW	6/15/2021	ND
PHES Classroom #6 Drinking Fountain	20810100-014DW	6/15/2021	105
PHES Classroom #7 Drinking Fountain	20810100-015DW	6/15/2021	7.59
PHES Classroom #8 Drinking Fountain	20810100-016DW	6/15/2021	8.85
PHES Classroom #11 Drinking Fountain	20810100-018DW	6/15/2021	11
PHES Classroom #16 Drinking Fountain	20810100-019DW	6/15/2021	4.92
PHES Classroom #18 Drinking Fountain	20810100-020DW	6/15/2021	ND
PHES Classroom #19 Drinking Fountain	20810100-021DW	6/15/2021	5.77
PHES 3rd Grade Commons Drinking Fountain	20810100-022DW	6/15/2021	4.33
PHES K-1 Restroom Center Sink	28010100-055BF	6/15/2021	ND
PHES 1st Hallway Girl's Restroom North Sink	20810100-058BF	6/15/2021	ND
PHES 1st Hallway Girl's Restroom Center North Sink	20810100-059BF	6/15/2021	10.1
PHES 1st Hallway Boy's Restroom Center North Sink	20810100-062BF	6/15/2021	3.64
PHES 1st Hallway Boy's Restroom Center South Sink	20810100-063BF	6/15/2021	4.8
PHES 4-5 Restroom South Sink	20810100-076BF	6/15/2021	ND
PHES 4-5 Restroom Center Sink	20810100-077BF	6/15/2021	2.6
PHES 4-5 Restroom North Sink	20810100-078BF	6/15/2021	ND

ND = Not Detected - Lead level is below the set detection limits of 2 ppb

