

**Water Testing Results - Pleasant Hill School District**  
**Action Level is 15 parts per billion (ppb)**

<b>Fixture Location / Description</b>	<b>Fixture ID #</b>	<b>Test Date</b>	<b>Test Results (ppb)</b>
PHHS Band Room Sink	20810202-001CF	6/4/2021	3.49
PHHS Kitchen Dish Sink - Center	20810202-005KF	6/4/2021	ND
PHHS Kitchen Dish Sink - East	20810202-006KF	6/4/2021	ND
PHHS Kitchen Dish Sink - West	20810202-007KF	6/4/2021	2.97
PHHS Kitchen Prep Sink - North	20810202-008KF	6/4/2021	4.68
PHHS Kitchen Prep Sink - South	20810202-009KF	6/4/2021	2
PHHS Kitchen Hand Wash Sink - South	20810202-010KF	6/4/2021	13.2
PHHS Kitchen Restroom Sink	20810202-011BF	6/4/2021	ND
PHHS General Purpose Room Restroom Sink	20810202-013BF	6/4/2021	ND
PHHS General Purpose Room Water Bottle Filler	20810202-014WB	6/4/2021	ND
PHHS Kitchen Hand Wash Sink - West	20810202-015KF	6/4/2021	2.06
PHHS Auxiliary Gym Coach Restroom Sink	20810203-001SF	6/4/2021	ND
PHHS Auxiliary Gym Girl's Restroom Sink	20810203-004BF	6/4/2021	ND
PHHS Auxiliary Gym Boy's Restroom Sink	20810203-007BF	6/4/2021	ND
PHHS Office Kitchen Sink	20810209-001KF	6/4/2021	ND
PHHS Office East Staff Restroom Sink	20810209-002BF	6/4/2021	ND
PHHS Office West Staff Restroom Sink	20810209-003BF	6/4/2021	ND
PHHS Office Nurse's Sink	20810209-004NS	6/4/2021	4.19
PHHS Baseball Snack Shack Sink	20810213-003KF	6/4/2021	22.4

ND = Not Detected - Lead level is below the set detection limits of 2 ppb