Water Testing Results - Pleasant Hill School District Action Level is 15 parts per billion (ppb)			
Fixture Location / Description	**Fixture ID #**	**Test Date**	**Test Results (ppb)**
PHHS Wood Shop Hand Wash Sink	20810204-001CF	5/26/2021	4.38
PHHS Wood Shop Restroom Sink	20810204-002BF	5/26/2021	ND
PHHS Art Room NW Sink	20810204-004CF	5/26/2021	ND
PHHS Art Room Center Sink	20810204-005CF	5/26/2021	ND
PHHS Art Room SW Sink	20810204-006CF	5/26/2021	ND
PHHS Room 21 South Sink	20810204-008CF	5/26/2021	109
PHHS Library N Sink	20810206-001SF	5/26/2021	13.7
PHHS Library S Sink	20810206-002SF	5/26/2021	ND
PHHS Metal Shop Drinking Fountain	20810207-001DW	5/26/2021	3.12
PHHS Metal Shop Restroom Cold Tap	20810207-002BF	5/26/2021	9.7
PHHS Metal Shop Bradley Hand Wash Sink	20810207-003CF	5/26/2021	ND
PHHS Metal Shop Quench Sink	20810207-004CF	5/26/2021	10.6
PHHS Metal Shop Restroom Hot Tap	20810207-007BF	5/26/2021	11.8
ND = Not Dectected - Lead level is below the set detection limits of 2 ppb			