

Maintenance

Fixture Number	Sample Number	Building	Location / Room No.	Fixture Type	Results (ppb)
001	2243MANT-001SF21A	Building 1	Main Corridor	Staff Sink Faucet	2.64
002	2243MANT-002WB21A	Building 1	Main Corridor	Water Bottle Fill	ND
003	2243MANT-003DW21A	Building 1	Main Corridor	Drinking Fountain	ND
004	2243MANT-004SF21A	Building 1	Conference Room 1	Staff Sink Faucet	20.1
004 - Follow Up	2243MANT-004SF21B	Building 1	Conference Room 1	Staff Sink Faucet - Follow Up	4.14
005	2243MANT-005SF21A	Building 2	Warehouse	Staff Sink Faucet	0.997
006	2243MANT-006WB21A	Building 2	Warehouse	Water Bottle Fill	ND
007	2243MANT-007DW21A	Building 2	Warehouse	Drinking Fountain	ND
008	2243MANT-008SF21A	Building 2	Coffee Station	Staff Sink Faucet	0.528
009	2243MANT-009SF21A	Building 5	Kitchenette	Staff Sink Faucet	0.702
010	2243MANT-010SF21A	Plumbing	Kitchenette	Staff Sink Faucet	0.414