

Elmonica

Fixture Number	Sample Number	Building	Location / Room No.	Fixture Type	Results (ppb)
001	22401162-001DW21A	Main	Main Hall	Drinking Fountain	0.829
002	22431162-002DW21A	Main	A100	Drinking Fountain	4.46
003	22431162-003CF21A	Main	A100	Classroom Faucet	2.68
004	22431162-004DW21A	Main	A102	Drinking Fountain	3.69
005	22431162-005CF21A	Main	A102	Classroom Faucet	5.15
005	22431162-005CF21B	Main	A102	Classroom Faucet (Flush)	1.24
007	22431162-007CF21A	Main	A104	Classroom Faucet	1.79
008	22431162-008DW21A	Main	A106	Drinking Fountain	5.91
009	22431162-009CF21A	Main	A106	Classroom Faucet	4.55
009	22431162-009CF21B	Main	A106	Classroom Faucet (Flush)	0.864
010	22431162-010DW21A	Main	A108	Drinking Fountain	1.89
011	22431162-011CF21A	Main	A108	Classroom Faucet	3.3
012	22431162-012DW21A	Main	A112	Drinking Fountain	7.21
013	22431162-013CF21A	Main	A112	Classroom Faucet	0.746
014	22431162-014DW21A	Main	A114	Drinking Fountain	7.93
015	22431162-015CF21A	Main	A114	Classroom Faucet	0.737
016	22431162-016DW21A	Main	A116	Drinking Fountain	11.6
017	22431162-017CF21A	Main	A116	Classroom Faucet	2.55
017	22431162-017CF21B	Main	A116	Classroom Faucet (Flush)	0.727
018	22431162-018DW21A	Main	A118	Drinking Fountain	13.8
019	22431162-019CF21A	Main	A118	Classroom Faucet	3.57
020	22431162-020DW21A	Main	A120	Drinking Fountain	14.5
021	22431162-021CF21A	Main	A120	Classroom Faucet	6.17
022	22431162-022DW21A	Main	A122	Drinking Fountain	11
023	22431162-023CF21A	Main	A122	Classroom Faucet	1.53
023	22431162-023CF21B	Main	A122	Classroom Faucet (Flush)	0.802
024	22431162-024CF21A	Main	A124	Classroom Faucet	7.37
024	22431162-024CF21B	Main	A124	Classroom Faucet (Flush)	1.66
025	22431162-025DW21A	Main	Hall at Staff Lounge	Drinking Fountain	0.584
026	22431162-026DW21A	Main	Main Gym	Drinking Fountain	0.223
026	22431162-026DW21B	Main	Main Gym	Drinking Fountain (Flush)	ND
027	22431162-027DW21A	Main	B100	Drinking Fountain	4.67
028	22431162-028CF21A	Main	B100	Classroom Faucet	4.48
028	22431162-028CF21B	Main	B100	Classroom Faucet (Flush)	2.06
029	22431162-029DW21A	Main	B102	Drinking Fountain	1.99
030	22431162-030CF21A	Main	B102	Classroom Faucet	7.6
031	22431162-031DW21A	Main	B104	Drinking Fountain	2.04
032	22431162-032CF21A	Main	B104	Classroom Faucet	6.95
033	22431162-033DW21A	Main	B106	Drinking Fountain	1.11
034	22431162-034CF21A	Main	B106	Classroom Faucet	7.61
035	22431162-035DW21A	Main	B108	Drinking Fountain	6.45
036	22431162-036CF21A	Main	B108	Classroom Faucet	10.7
036	22431162-036CF21B	Main	B108	Classroom Faucet (Flush)	1.36
037	22431162-037DW21A	Main	B110	Drinking Fountain	3.39

038	22431162-038CF21A	Main	B110	Classroom Faucet	4.8
039	22431162-039CF21A	Main	B112	Classroom Faucet	2.72
040	22431162-040DW21A	Main	B114	Drinking Fountain	2.47
041	22431162-041CF21A	Main	B114	Classroom Faucet	1.76
042	22431162-042DW21A	Main	B116	Drinking Fountain	4.39
043	22431162-043CF21A	Main	B116	Classroom Faucet	0.442
043	22431162-043CF21B	Main	B116	Classroom Faucet (Flush)	0.287
044	22431162-044DW21A	Main	B118	Drinking Fountain	8.47
045	22431162-045CF21A	Main	B118	Classroom Faucet	0.668
046	22431162-046DW21A	Main	B120	Drinking Fountain	0.712
047	22431162-047CF21A	Main	B120	Classroom Faucet	4.46
048	22431162-048DW21A	Main	B122	Drinking Fountain	5.2
049	22431162-049CF21A	Main	B122	Classroom Faucet	8.76
050	22431162-050DW21A	Main	B124	Drinking Fountain	11.5
051	22431162-051CF21A	Main	B124	Classroom Faucet	0.756
052	22431162-052NS21A	Main	Health Room	Nurse's Sink	8.61
053	22431162-053SF21A	Main	Staff Room	Staff Room Sink	5.38
053	22431162-053SF21B	Main	Staff Room	Staff Room Sink (Flush)	0.468
054	22431162-054KF21A	Main	Kitchen	Main Prep Sink	1.49
054	22431162-054KF21B	Main	Kitchen	Main Prep Sink (Flush)	ND