

ANALYTICAL REPORT

Job Number: 420-195346-1

SDG Number: Washingtonville CSD Middle School

Job Description: Orange-Ulster BOCES

For:
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Attention: Jack DeGraw



Designee for
Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
06/15/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at Envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

Envirotest Laboratories

315 Fullerton Avenue, Newburgh, NY 12550
Tel (845) 562-0890 Fax (845) 562-0841 www.envirotestlaboratories.com

METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-195346-1

SDG Number: Washingtonville CSD Middle School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-195346-1

SDG Number: Washingtonville CSD Middle School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-195346-1
SDG Number: Washingtonville CSD Middle School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195346-1	WB 1 by 193	Drinking Water	04/15/2021 0317	04/15/2021 1205
420-195346-2	MB by 193	Drinking Water	04/15/2021 0318	04/15/2021 1205
420-195346-3	MB 1 locker room	Drinking Water	04/15/2021 0320	04/15/2021 1205
420-195346-4	MB 2 locker room	Drinking Water	04/15/2021 0320	04/15/2021 1205
420-195346-5	BS boy's coaches office	Drinking Water	04/15/2021 0322	04/15/2021 1205
420-195346-6	Kitchen BS	Drinking Water	04/15/2021 0324	04/15/2021 1205
420-195346-7	Kitchen sink- across from BS	Drinking Water	04/15/2021 0325	04/15/2021 1205
420-195346-8	Kitchen sink- serving line "B"	Drinking Water	04/15/2021 0326	04/15/2021 1205
420-195346-9	Kitchen sink #1 Prep area	Drinking Water	04/15/2021 0327	04/15/2021 1205
420-195346-10	Kitchen sink #2 Prep area	Drinking Water	04/15/2021 0327	04/15/2021 1205
420-195346-11	Kitchen sink #3 Prep area	Drinking Water	04/15/2021 0328	04/15/2021 1205
420-195346-12	Kitchen-Kettle Filler	Drinking Water	04/15/2021 0329	04/15/2021 1205
420-195346-13	Kitchen-Kettle Filler (sprayer)	Drinking Water	04/15/2021 0329	04/15/2021 1205
420-195346-14	Kitchen sink #1- Dishwasher area	Drinking Water	04/15/2021 0331	04/15/2021 1205
420-195346-15	Kitchen (sprayer) Dishwasher area	Drinking Water	04/15/2021 0332	04/15/2021 1205
420-195346-16	Kitchen sink #2- Dishwasher area	Drinking Water	04/15/2021 0333	04/15/2021 1205
420-195346-17	Kitchen sink- island sink by dishwashing area	Drinking Water	04/15/2021 0333	04/15/2021 1205
420-195346-18	Kitchen sink- serving line "B"	Drinking Water	04/15/2021 0334	04/15/2021 1205
420-195346-19	CU BF by Kitchen	Drinking Water	04/15/2021 0339	04/15/2021 1205
420-195346-20	Girl's coaches office BS	Drinking Water	04/15/2021 0340	04/15/2021 1205
420-195346-21	Girl's locker room- sink #1	Drinking Water	04/15/2021 0342	04/15/2021 1205
420-195346-22	Girl's locker room- sink #2	Drinking Water	04/15/2021 0342	04/15/2021 1205
420-195346-23	CU BF by 170 wing	Drinking Water	04/15/2021 0344	04/15/2021 1205
420-195346-24	170 wing WB sink #1	Drinking Water	04/15/2021 0345	04/15/2021 1205
420-195346-25	170 wing WB sink #2	Drinking Water	04/15/2021 0345	04/15/2021 1205
420-195346-26	170 wing WB sink #3	Drinking Water	04/15/2021 0346	04/15/2021 1205
420-195346-27	170 wing Faculty BS	Drinking Water	04/15/2021 0347	04/15/2021 1205
420-195346-28	170 wing Boy's (B) BS sink!	Drinking Water	04/15/2021 0348	04/15/2021 1205
420-195346-29	170 wing Boy's (B) BS sink!	Drinking Water	04/15/2021 0348	04/15/2021 1205
420-195346-30	Girl's BS #1 by Kitchen	Drinking Water	04/15/2021 0350	04/15/2021 1205
420-195346-31	Girl's BS #2 by Kitchen	Drinking Water	04/15/2021 0350	04/15/2021 1205
420-195346-32	Girl's BS #3 by Kitchen	Drinking Water	04/15/2021 0351	04/15/2021 1205
420-195346-33	Girl's BS #4 by Kitchen	Drinking Water	04/15/2021 0351	04/15/2021 1205
420-195346-34	Boy's BS #1 by Kitchen	Drinking Water	04/15/2021 0352	04/15/2021 1205
420-195346-35	Boy's BS #2 by Kitchen	Drinking Water	04/15/2021 0353	04/15/2021 1205
420-195346-36	Boy's BS #3 by Kitchen	Drinking Water	04/15/2021 0354	04/15/2021 1205
420-195346-37	Boy's BS #4 by Kitchen	Drinking Water	04/15/2021 0354	04/15/2021 1205
420-195346-38	CS 150- Kitchen sink #1	Drinking Water	04/15/2021 0356	04/15/2021 1205
420-195346-39	CS 150- Kitchen sink #2	Drinking Water	04/15/2021 0356	04/15/2021 1205
420-195346-40	CS 154- Kitchen sink	Drinking Water	04/15/2021 0357	04/15/2021 1205

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-195346-1

SDG Number: Washingtonville CSD Middle School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195346-41	CS 154 BS	Drinking Water	04/15/2021 0358	04/15/2021 1205
420-195346-42	CS 114- sink #1	Drinking Water	04/15/2021 0401	04/15/2021 1205
420-195346-43	CS 114- sink #2	Drinking Water	04/15/2021 0401	04/15/2021 1205
420-195346-44	CS 114- sink #3	Drinking Water	04/15/2021 0402	04/15/2021 1205
420-195346-45	CS 114- sink #4	Drinking Water	04/15/2021 0402	04/15/2021 1205
420-195346-46	CU BF by cafeteria	Drinking Water	04/15/2021 0403	04/15/2021 1205
420-195346-47	CU 113 BS	Drinking Water	04/15/2021 0405	04/15/2021 1205
420-195346-48	CS 112	Drinking Water	04/15/2021 0406	04/15/2021 1205
420-195346-49	CS 105	Drinking Water	04/15/2021 0407	04/15/2021 1205
420-195346-50	104 BS	Drinking Water	04/15/2021 0408	04/15/2021 1205
420-195346-51	Mail room sink	Drinking Water	04/15/2021 0409	04/15/2021 1205
420-195346-52	Mail office BS	Drinking Water	04/15/2021 0410	04/15/2021 1205
420-195346-53	Principal's office BS	Drinking Water	04/15/2021 0412	04/15/2021 1205
420-195346-54	Hall Bathroom (handicap) by main office	Drinking Water	04/15/2021 0414	04/15/2021 1205
420-195346-55	Nurse's office sink	Drinking Water	04/15/2021 0415	04/15/2021 1205
420-195346-56	Nurse's BS	Drinking Water	04/15/2021 0415	04/15/2021 1205
420-195346-57	Ice Machine	Drinking Water	04/15/2021 0416	04/15/2021 1205
420-195346-58	Faculty Room 206 sink	Drinking Water	04/15/2021 0420	04/15/2021 1205
420-195346-59	2nd Floor Faculty BS (left)	Drinking Water	04/15/2021 0421	04/15/2021 1205
420-195346-60	2nd Floor Faculty BS (right)	Drinking Water	04/15/2021 0422	04/15/2021 1205
420-195346-61	CU BF next to 208	Drinking Water	04/15/2021 0423	04/15/2021 1205
420-195346-62	2nd Floor WB sink #1	Drinking Water	04/15/2021 0424	04/15/2021 1205
420-195346-63	2nd Floor WB sink #2	Drinking Water	04/15/2021 0425	04/15/2021 1205
420-195346-64	2nd Floor WB sink #3	Drinking Water	04/15/2021 0425	04/15/2021 1205
420-195346-65	Handicap bathroom 2nd Floor	Drinking Water	04/15/2021 0426	04/15/2021 1205
420-195346-66	2nd Floor Boy's BS #1	Drinking Water	04/15/2021 0427	04/15/2021 1205
420-195346-67	2nd Floor Boy's BS #2	Drinking Water	04/15/2021 0428	04/15/2021 1205
420-195346-68	2nd Floor Boy's BS #3	Drinking Water	04/15/2021 0428	04/15/2021 1205
420-195346-69	CS 216 sink #1	Drinking Water	04/15/2021 0430	04/15/2021 1205
420-195346-70	CS 216 sink #2	Drinking Water	04/15/2021 0430	04/15/2021 1205
420-195346-71	CS 216 sink #3	Drinking Water	04/15/2021 0431	04/15/2021 1205

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: WB 1 by 193
Lab Sample ID: 420-195346-1

Date Sampled: 04/15/2021 0317
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2141	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	6.09	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: MB by 193
Lab Sample ID: 420-195346-2

Date Sampled: 04/15/2021 0318
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2143	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	6.92	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: MB 1 locker room
Lab Sample ID: 420-195346-3

Date Sampled: 04/15/2021 0320
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2145	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	11.4	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: MB 2 locker room
Lab Sample ID: 420-195346-4

Date Sampled: 04/15/2021 0320
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2147	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	7.77	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: BS boy's coaches office
Lab Sample ID: 420-195346-5

Date Sampled: 04/15/2021 0322
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2150	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	1.61	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen BS
Lab Sample ID: 420-195346-6

Date Sampled: 04/15/2021 0324
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2152	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	8.54	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen sink- across from BS
Lab Sample ID: 420-195346-7

Date Sampled: 04/15/2021 0325
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2154	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	6.02	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen sink- serving line "B"
Lab Sample ID: 420-195346-8

Date Sampled: 04/15/2021 0326
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2207	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	52.3 g	ug/L	5.00	5.00	5.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen sink #1 Prep area
Lab Sample ID: 420-195346-9

Date Sampled: 04/15/2021 0327
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2209	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	4.89	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen sink #2 Prep area
Lab Sample ID: 420-195346-10

Date Sampled: 04/15/2021 0327
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2212	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	10.2	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen sink #3 Prep area
Lab Sample ID: 420-195346-11

Date Sampled: 04/15/2021 0328
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2214	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	4.09	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen-Kettle Filler
Lab Sample ID: 420-195346-12

Date Sampled: 04/15/2021 0329
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2216	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	1.53	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen-Kettle Filler (sprayer)
Lab Sample ID: 420-195346-13

Date Sampled: 04/15/2021 0329
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2218	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	1.23	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen sink #1- Dishwasher area
Lab Sample ID: 420-195346-14

Date Sampled: 04/15/2021 0331
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2220	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	7.36	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen (sprayer) Dishwasher area
Lab Sample ID: 420-195346-15

Date Sampled: 04/15/2021 0332
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2222	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	9.85	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen sink #2- Dishwasher area
Lab Sample ID: 420-195346-16

Date Sampled: 04/15/2021 0333
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2225	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	2.36	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen sink- island sink by dishwashing area
Lab Sample ID: 420-195346-17

Date Sampled: 04/15/2021 0333
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2231	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	3.37	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Kitchen sink- serving line "B"
Lab Sample ID: 420-195346-18

Date Sampled: 04/15/2021 0334
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2233	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	9.69	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CU BF by Kitchen
Lab Sample ID: 420-195346-19

Date Sampled: 04/15/2021 0339
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2238	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	1.15	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Girl's coaches office BS
Lab Sample ID: 420-195346-20

Date Sampled: 04/15/2021 0340
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2240	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	4.95	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Girl's locker room- sink #1
Lab Sample ID: 420-195346-21

Date Sampled: 04/15/2021 0342
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2242	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	11.3	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Girl's locker room- sink #2
Lab Sample ID: 420-195346-22

Date Sampled: 04/15/2021 0342
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2244	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	17.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CU BF by 170 wing
Lab Sample ID: 420-195346-23

Date Sampled: 04/15/2021 0344
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/09/2021 2246	
Prep Method: 200.7/200.8				Date Prepared:	06/03/2021 1200	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 170 wing WB sink #1
Lab Sample ID: 420-195346-24

Date Sampled: 04/15/2021 0345
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2249	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	6.91	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 170 wing WB sink #2
Lab Sample ID: 420-195346-25

Date Sampled: 04/15/2021 0345
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/09/2021 2251	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	5.85	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 170 wing WB sink #3
Lab Sample ID: 420-195346-26

Date Sampled: 04/15/2021 0346
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1608	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	3.92	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 170 wing Faculty BS
Lab Sample ID: 420-195346-27

Date Sampled: 04/15/2021 0347
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/10/2021 1610	
Prep Method: 200.7/200.8				Date Prepared:	06/03/2021 1200	
Pb	17.8	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 170 wing Boy's (B) BS sink!
Lab Sample ID: 420-195346-28

Date Sampled: 04/15/2021 0348
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1246	
Prep Method: 200.7/200.8			Date Prepared:	06/04/2021 1226	
Pb	36.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 170 wing Boy's (B) BS sink!
Lab Sample ID: 420-195346-29

Date Sampled: 04/15/2021 0348
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/10/2021 1612	
Prep Method: 200.7/200.8				Date Prepared:	06/03/2021 1200	
Pb	20.7	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Girl's BS #1 by Kitchen
Lab Sample ID: 420-195346-30

Date Sampled: 04/15/2021 0350
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1621	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	3.15	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Girl's BS #2 by Kitchen
Lab Sample ID: 420-195346-31

Date Sampled: 04/15/2021 0350
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1623	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	2.13	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Girl's BS #3 by Kitchen
Lab Sample ID: 420-195346-32

Date Sampled: 04/15/2021 0351
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/10/2021 1626	
Prep Method: 200.7/200.8				Date Prepared:	06/03/2021 1200	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Girl's BS #4 by Kitchen
Lab Sample ID: 420-195346-33

Date Sampled: 04/15/2021 0351
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1632	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	1.65	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Boy's BS #1 by Kitchen
Lab Sample ID: 420-195346-34

Date Sampled: 04/15/2021 0352
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1634	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	1.17	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Boy's BS #2 by Kitchen
Lab Sample ID: 420-195346-35

Date Sampled: 04/15/2021 0353
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1637	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	1.61	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Boy's BS #3 by Kitchen
Lab Sample ID: 420-195346-36

Date Sampled: 04/15/2021 0354
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1639	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	2.36	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Boy's BS #4 by Kitchen
Lab Sample ID: 420-195346-37

Date Sampled: 04/15/2021 0354
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1641	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	2.39	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 150- Kitchen sink #1
Lab Sample ID: 420-195346-38

Date Sampled: 04/15/2021 0356
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1643	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	1.61	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 150- Kitchen sink #2
Lab Sample ID: 420-195346-39

Date Sampled: 04/15/2021 0356
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1645	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	4.80	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 154- Kitchen sink
Lab Sample ID: 420-195346-40

Date Sampled: 04/15/2021 0357
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1650	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	1.46	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 154 BS
Lab Sample ID: 420-195346-41

Date Sampled: 04/15/2021 0358
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/10/2021 1652	
Prep Method: 200.7/200.8				Date Prepared:	06/03/2021 1200	
Pb	27.5	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 114- sink #1
Lab Sample ID: 420-195346-42

Date Sampled: 04/15/2021 0401
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021	1658	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021	1200	
Pb	20.2	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 114- sink #2
Lab Sample ID: 420-195346-43

Date Sampled: 04/15/2021 0401
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1701	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	12.7	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 114- sink #3
Lab Sample ID: 420-195346-44

Date Sampled: 04/15/2021 0402
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/10/2021 1703	
Prep Method: 200.7/200.8				Date Prepared:	06/03/2021 1200	
Pb	15.3	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 114- sink #4
Lab Sample ID: 420-195346-45

Date Sampled: 04/15/2021 0402
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/10/2021 1705	
Prep Method: 200.7/200.8				Date Prepared:	06/03/2021 1200	
Pb	24.6	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CU BF by cafeteria
Lab Sample ID: 420-195346-46

Date Sampled: 04/15/2021 0403
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/10/2021 1707	
Prep Method: 200.7/200.8				Date Prepared:	06/03/2021 1200	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CU 113 BS
Lab Sample ID: 420-195346-47

Date Sampled: 04/15/2021 0405
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1709	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	10.7	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 112
Lab Sample ID: 420-195346-48

Date Sampled: 04/15/2021 0406
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021	1712	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021	1200	
Pb	35.5	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 105
Lab Sample ID: 420-195346-49

Date Sampled: 04/15/2021 0407
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1714	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	4.65	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 104 BS
Lab Sample ID: 420-195346-50

Date Sampled: 04/15/2021 0408
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1727	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	5.49	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Mail room sink
Lab Sample ID: 420-195346-51

Date Sampled: 04/15/2021 0409
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1729	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	16.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Mail office BS
Lab Sample ID: 420-195346-52

Date Sampled: 04/15/2021 0410
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1731	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	16.8 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Principal's office BS
Lab Sample ID: 420-195346-53

Date Sampled: 04/15/2021 0412
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1733	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	27.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Hall Bathroom (handicap) by main office
Lab Sample ID: 420-195346-54

Date Sampled: 04/15/2021 0414
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1736	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	12.0	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Nurse's office sink
Lab Sample ID: 420-195346-55

Date Sampled: 04/15/2021 0415
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1738	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	22.9 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Nurse's BS
Lab Sample ID: 420-195346-56

Date Sampled: 04/15/2021 0415
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1740	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	23.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Ice Machine
Lab Sample ID: 420-195346-57

Date Sampled: 04/15/2021 0416
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/10/2021 1742	
Prep Method: 200.7/200.8				Date Prepared:	06/03/2021 1200	
Pb	1.00	U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Faculty Room 206 sink
Lab Sample ID: 420-195346-58

Date Sampled: 04/15/2021 0420
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1744	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	8.87	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 2nd Floor Faculty BS (left)
Lab Sample ID: 420-195346-59

Date Sampled: 04/15/2021 0421
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1751	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	7.59	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 2nd Floor Faculty BS (right)
Lab Sample ID: 420-195346-60

Date Sampled: 04/15/2021 0422
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1755	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	20.5 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CU BF next to 208
Lab Sample ID: 420-195346-61

Date Sampled: 04/15/2021 0423
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1757	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 2nd Floor WB sink #1
Lab Sample ID: 420-195346-62

Date Sampled: 04/15/2021 0424
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1800	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	8.30	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 2nd Floor WB sink #2
Lab Sample ID: 420-195346-63

Date Sampled: 04/15/2021 0425
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1802	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	3.87	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 2nd Floor WB sink #3
Lab Sample ID: 420-195346-64

Date Sampled: 04/15/2021 0425
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1804	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	5.35	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: Handicap bathroom 2nd Floor
Lab Sample ID: 420-195346-65

Date Sampled: 04/15/2021 0426
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1806	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	14.5	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 2nd Floor Boy's BS #1
Lab Sample ID: 420-195346-66

Date Sampled: 04/15/2021 0427
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1808	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	1.44	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 2nd Floor Boy's BS #2
Lab Sample ID: 420-195346-67

Date Sampled: 04/15/2021 0428
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1811	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	1.79	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: 2nd Floor Boy's BS #3
Lab Sample ID: 420-195346-68

Date Sampled: 04/15/2021 0428
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1817	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	4.70	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 216 sink #1
Lab Sample ID: 420-195346-69

Date Sampled: 04/15/2021 0430
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/10/2021 1819	
Prep Method: 200.7/200.8			Date Prepared:	06/03/2021 1200	
Pb	35.4 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 216 sink #2
Lab Sample ID: 420-195346-70

Date Sampled: 04/15/2021 0430
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/10/2021 1828	
Prep Method: 200.7/200.8				Date Prepared:	06/03/2021 1200	
Pb	31.4	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-195346-1
Sdg Number: Washingtonville CSD Middle School

Client Sample ID: CS 216 sink #3
Lab Sample ID: 420-195346-71

Date Sampled: 04/15/2021 0431
Date Received: 04/15/2021 1205
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/10/2021 1830	
Prep Method: 200.7/200.8				Date Prepared:	06/03/2021 1200	
Pb	31.8	g	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Washingtonville CSD Middle School

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Washingtonville CSD Middle School

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Washingtonville CSD Middle School

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

EnviroTest Laboratories

Client Information		Sampler: M. Doherty	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 195346 1085
Client Contact: Joseph Russo		Phone: 845-781-4887	Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		
Company: Orange-Ulster BOCES					Page: Page 1 of 1
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	Analysis Requested		
City: Goshen		TAT Requested (days):			
State, Zip: NY , 10924					
Phone: 845-781-4887		PO #:			
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		PWS #:			
Project Name: Washingtonville CSD		Project #:			
Site: Middle School		Additional Contacts:			
Sample Identification Client ID (Lab ID)		Sample Type (C=comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil,	Field Filtered Sample (Yes or No)	Total Number of containers
		Preservation Code:		Perform MS/MSD (Yes or No)	
				Chlorine Present (Yes or No)	
				Lead	
WB 1 by 193		G	DW	1	1
MB by 193		G	DW	1	1
MB 1 locker room		G	DW	1	1
MB 2 locker room		G	DW	1	1
BS boy's coaches office		G	DW	1	1
Kitchen BS		G	DW	1	1
Kitchen sink - across from BS		G	DW	1	1
Kitchen sink - serving line "B"		G	DW	1	1
Kitchen sink #1 Prep area		G	DW	1	1
Kitchen sink #2 Prep area		G	DW	1	1
Kitchen sink #3 Prep area		G	DW	1	1
Kitchen - Kettle Filler		G	DW	1	1
Kitchen - Kettle Filler (sprayer)		G	DW	1	1
Kitchen sink #1 - Dishwasher area		G	DW	1	1
Kitchen (sprayer) Dishwasher area		G	DW	1	1
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle				P	
Preservation Added Upon Receipt:		Manufacturer/Lot #:	Date:	Time:	Sample # (s):
Relinquished by: Maureen Doherty		Date/Time: 4/15/2021; 1205	Company: OUBOCES	Received by: Natasha	Date/Time: 4/15/21 1205
Relinquished by:		Date/Time:	Company:	Received by:	Date/Time:
Relinquished by:		Date/Time:	Company:	Received by:	Date/Time:
ICE Present		Custody Seal No.: 420-195346-B-1	Seals Intact: Δ	Cooler Temperature(s) °C/IR GUN #:	

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record

**EnviroTest
Laboratories**

Client Information Client Contact: Joseph Russo				Sampler: <i>Maureen B Doherty</i> Phone: 845-781-4887				Lab PM: E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org				Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):				JOB #: 195346 2 of 5			
Company: Orange-Ulster BOCES								Analysis Requested								Page: Page 1 of 1			
Address: 53 Gibson Road								Due Date Requested: Standard Turn-Around								Preservation Codes: A - HCL L - EDA B - NaOH M - Sodium Sulfite C - Zn Acetate N - None D - Nitric Acid O - MCAA E - H2SO4 P - Other (specify) F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate Other: D-Nitric Acid Upon Receipt Preservation verified: Y / N			
City: Goshen								TAT Requested (days):											
State, Zip: NY , 10924								PO #:											
Phone: 845-781-4887								PWS #:											
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org								Project #:											
Project Name: Washingtonville CSD								Additional Contacts:											
Site: Middle School																			

Sample Date	Sample Time	Sample Identification Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
			Preservation Code:					D		
4/14/21	3:33	Kitchen sink #2 - Dishwasher area	G	DW				1		
4/14/21	3:33	Kitchen sink - island sink by dishwashing area	G	DW				1		
4/14/21	3:34	Kitchen sink - serving line "B"	G	DW				1		
4/14/21	3:39	CU BF by Kitchen	G	DW				1		
4/14/21	3:40	Girl's coaches office BS	G	DW				1		
4/14/21	3:42	Girl's locker room - sink #1	G	DW				1		
4/14/21	3:42	Girl's locker room - sink #2	G	DW				1		
4/14/21	3:44	CU BF by 170 wing	G	DW				1		
4/14/21	3:45	170 wing WB sink #1	G	DW				1		
4/14/21	3:45	170 wing WB sink #2	G	DW				1		
4/14/21	3:46	170 wing WB sink #3	G	DW				1		
4/14/21	3:47	170 wing Faculty BS	G	DW				1		
4/14/21	3:48	170 wing Boy's (B) BS sink #1	G	DW				1		
4/14/21	3:48	170 wing Boy's (B) BS sink #1	G	DW				1		
4/14/21	3:50	Girl's BS #1 by Kitchen	G	DW				1		

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle										Container Type									
Preservation Added Upon Receipt:										Manufacturer/Lot #:									
Relinquished by: <i>Maureen B Doherty</i>										Date/Time: 4/15/2021, 12:05									
Relinquished by:										Date/Time:									
Relinquished by:										Date/Time:									
Relinquished by:										Date/Time:									
ICE Present: <i>AP</i>										Custody Seal No.:									
Custody Seals Intact: Δ										Cooler Temperature(s) °C/IR GUN #: 20.0 °C									

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record

EnviroTest
Laboratories

Client Information Client Contact: Joseph Russo				Sampler: M. Doherty <i>Maureen Doherty</i>		Lab PM: Joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 195346 345	
				Company: Orange-Ulster BOCES		Due Date Requested: Standard Turn-Around		Analysis Requested		Page: Page 1 of 1	
Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org				PO #: PWS #: Project #: Additional Contacts:		Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) Chlorine Present (Yes or No) Lead		Total Number of Containers		Preservation Codes: A - HCL L - EDA B - NaOH M - Sodium Sulfite C - Zn Acetate N - None D - Nitric Acid O - MCAA E - H2SO4 P - Other (specify) F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate	
Project Name: Washingtonville CSD Site: Middle School				Project #: Additional Contacts:							

Sample Date	Sample Time	Sample Identification Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead											Total Number of Containers	Special Instructions/Note:
4/14/21	3:50	Girl's BS #2 by Kitchen	G	DW				1								1				
4/14/21	3:51	Girl's BS #3 by Kitchen	G	DW				1								1				
4/14/21	3:51	Girl's BS #4 by Kitchen	G	DW				1								1				
4/14/21	3:52	Boy's BS #1 by Kitchen	G	DW				1								1				
4/14/21	3:53	Boy's BS #2 by Kitchen	G	DW				1								1				
4/14/21	3:54	Boy's BS #3 by Kitchen	G	DW				1								1				
4/14/21	3:54	Boy's BS #4 by Kitchen	G	DW				1								1				
4/14/21	3:56	CS 150 - Kitchen sink #1	G	DW				1								1				
4/14/21	3:56	CS 150 - Kitchen sink #2	G	DW				1								1				
4/14/21	3:57	CS 154 - Kitchen sink	G	DW				1								1				
4/14/21	3:58	CS 154 BS	G	DW				1								1				
4/14/21	4:01	CS 114 - sink #1	G	DW				1								1				
4/14/21	4:01	CS 114 - sink #2	G	DW				1								1				
4/14/21	4:02	CS 114 - sink #3	G	DW				1								1				
4/14/21	4:02	CS 114 - sink #4	G	DW				1								1				

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle Preservation Added Upon Receipt:										Manufacturer/lot # Date:										Sample # (s):																																							
Relinquished by: <i>Maureen Doherty</i>										Date/Time: 4/15/2021, 12:05										Company: OUBOCES										Received by: <i>Maureen Doherty</i>										Date/Time: 4/15/21 1205										Company: ETL									
Relinquished by:										Date/Time:										Company:										Received by:										Date/Time:										Company:									
Relinquished by:										Date/Time:										Company:										Received by:										Date/Time:										Company:									

ICE Present: <i>NA</i>	Custody Seal No.:	Custody Seals Intact: Δ	Cooler Temperature(s) °C/IR GUN #: 20.0°C
------------------------	-------------------	--------------------------------	---

Client Information		Sampler: M. Doherty <i>Maureen Doherty</i>		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #:					
Client Contact: Joseph Russo		Phone: 845-781-4887		E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org				195346 yob5					
Company: Orange-Ulster BOCES				Analysis Requested						Page: Page 1 of 1			
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around		Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) Chlorine Present (Yes or No) Lead								Preservation Codes:	
City: Goshen		TAT Requested (days):										A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate	
State, Zip: NY, 10924		PO #:										L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)	
Phone: 845-781-4887		PWS #:											
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org													
Project Name: Washingtonville CSD		Project #:										Other: D-Nitric Acid	
Site: Middle School		Additional Contacts:										Upon Receipt Preservation verified Y / N	
Sample Identification Client ID (Lab ID)				Sample Type (C=comp, G=grab)		Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)							
				Preservation Code:								Special Instructions/Note:	
CU BF by cafeteria				G DW									
CS 113 BS				G DW									
CS 112				G DW									
CS 105				G DW									
104 BS				G DW									
Mail room sink				G DW									
Main office BS				G DW									
Principal's office BS				G DW									
Hall Bathroom (handicap) by main office				G DW									
Nurse's office sink				G DW									
Nurse's BS				G DW									
Ice Machine				G DW									
Faculty Room 206 sink				G DW									
2nd Floor Faculty BS (left)				G DW									
2nd Floor Faculty BS (right)				G DW									
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle						P						Container Type	
Preservation Added Upon Receipt:		Manufacturer/lot #:		Date:		Time:		Sample # (s):					
Relinquished by: <i>Maureen Doherty</i>		Date/Time: 4/15/2021; 12:05		Company: OUBOCES		Received by: <i>Maureen Doherty</i>		Date/Time: 4/15/21 1205		Company: ETL			
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:			
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:			
ICE Present: 11		Custody Seal No.:		Custody Seals Intact: Δ		Cooler Temperature(s) °C/IR GUN #: 70.0°C							

EnviroTest
Laboratories[illegible]

Chain of Custody Record

Client Information			Sampler: M. Doherty		Lab PM: 		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 			
Client Contact: Joseph Russo			Phone: 845-781-4887		E-Mail: joseph_russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org							
Company: Orange-Ulster BOCES					Analysis Requested					Page: Page 1 of 1		
Address: 53 Gibson Road			Due Date Requested: Standard Turn-Around									
City: Goshen			TAT Requested (days):								Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)	
State, Zip: NY , 10924												
Phone: 845-781-4887			PO #:									
Email: joseph.russo@ouboces.org Maureen.doherty@ouboces.org			PWS #:									
Project Name: Washingtonville CSD			Project #:									
Site: Middle School			Additional Contacts:								Other: D-Nitric Acid	

Sample Date	Sample Time	Sample Identification Client ID (Lab ID)	Sample Type (C=comp, S=solid, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil,	Field Filtered \$	Potomac MS/MS	Chlorine Preser	Lead										Total Number of Samples	Upon Receipt Preservation verified: Y / N
			Preservation Code		X	X	X	D										X	Special Instructions/Note:
4/15/21	3:17	WB 1 by 193	G	DW				1											
4/15/21	3:18	MB by 193	G	DW				1											
4/15/21	3:20	MB 1 locker room	G	DW				1											
4/15/21	3:20	MB 2 locker room	G	DW				1											
4/15/21	3:22	BS boy's coaches office	G	DW				1											
4/15/21	3:24	Kitchen BS	G	DW				1											
4/15/21	3:25	Kitchen sink - across from BS	G	DW				1											
4/15/21	3:26	Kitchen sink - serving line "B"	G	DW				1											
4/15/21	3:27	Kitchen sink #1 Prep area	G	DW				1											
4/15/21	3:27	Kitchen sink #2 Prep area	G	DW				1											
4/15/21	3:28	Kitchen sink #3 Prep area	G	DW				1											
4/15/21	3:29	Kitchen - Kettle Filler	G	DW				1											
4/15/21	3:29	Kitchen - Kettle Filler (sprayer)	G	DW				1											
4/15/21	3:31	Kitchen sink #1 - Dishwasher area	G	DW				1											
4/15/21	3:32	Kitchen (sprayer) Dishwasher area	G	DW				1											
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle							P											Container Type	
Preservation Added Upon Receipt:					Manufacturer/Lot #: _____ Date: _____ Time: _____					Sample # (s): _____									
Relinquished by: _____			Date/Time: _____		Company OUBOCES		Received by: _____			Date/Time: _____			Company						
Relinquished by: _____			Date/Time: _____		Company		Received by: _____			Date/Time: _____			Company						
Relinquished by: _____			Date/Time: _____		Company		Received by: _____			Date/Time: _____			Company						
ICE Present:		Custody Seal No. :		Custody Seals Intact:		Δ		Cooler Temperature(s) °C/IR GUN #											

EnviroTest
Laboratories

06/15/2021

Chain of Custody Record

Client Information		Sampler: M. Doherty		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #:																
Client Contact: Joseph Russo		Phone: 845-781-4887		E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org																				
Company: Orange-Ulster BOCES				Analysis Requested						Page: Page 1 of 1														
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around		Field Filtered Sample (Yes or No)	Perform HSM/SD (Yes or No)	Chlorine Present (Yes or No)	Lead													Total Number of Containers	Preservation Codes:			
City: Goshen		TAT Requested (days):																			A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate		L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)	
State, Zip: NY , 10924																								
Phone: 845-781-4887		PO #:																						
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		PWS #:																						
Project Name: Washingtonville CSD		Project #:																		Other: D-Nitric Acid <i>Upon Receipt Preservation verified</i> Y / N				
Site: Middle School		Additional Contacts:																						
Sample Identification Client ID (Lab ID)				Sample Type (C=comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil.																			
				Preservation Code:																				
Girl's BS #2 by Kitchen				G	DW																			
Girl's BS #3 by Kitchen				G	DW																			
Girl's BS #4 by Kitchen				G	DW																			
Boy's BS #1 by Kitchen				G	DW																			
Boy's BS #2 by Kitchen				G	DW																			
Boy's BS #3 by Kitchen				G	DW																			
Boy's BS #4 by Kitchen				G	DW																			
CS 150 - Kitchen sink #1				G	DW																			
CS 150 - Kitchen sink #2				G	DW																			
CS 154 - Kitchen sink				G	DW																			
CS 154 BS				G	DW																			
CS 114 - sink #1				G	DW																			
CS 114 - sink #2				G	DW																			
CS 114 - sink #3				G	DW																			
CS 114 - sink #4				G	DW																			
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle																								
Preservation Added Upon Receipt:																								
Relinquished by:																								
Relinquished by:																								
Relinquished by:																								
ICE Present:						Custody Seal No.:						Custody Seals Intact:						Cooler Temperature(s) °C/ IR GUN #:						

EnviroTest
Laboratories

Sample Date	Sample Time	Sample Identification Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)	Field Filtered	Perform MS/MS	Chlorine Preser	Lead												Total Number	Upon Receipt Preservation verified: Y / N
4/15/21	4:03	CU BF by cafeteria	G	DW				D													Special Instructions/Note:
4/15/21	4:05	CS 113 BS	G	DW				1													
4/15/21	4:06	CS 112	G	DW				1													
4/15/21	4:07	CS 105	G	DW				1													
4/15/21	4:08	104 BS	G	DW				1													
4/15/21	4:09	Mail room sink	G	DW				1													
4/15/21	4:10	Main office BS	G	DW				1													
4/15/21	4:12	Principal's office BS	G	DW				1													
4/15/21	4:14	Hall Bathroom (handicap) by main office	G	DW				1													
4/15/21	4:15	Nurse's office sink	G	DW				1													
4/15/21	4:15	Nurse's BS	G	DW				1													
4/15/21	4:16	Ice Machine	G	DW				1													
4/15/21	4:20	Faculty Room 206 sink	G	DW				1													
4/15/21	4:21	2nd Floor Faculty BS (left)	G	DW				1													
4/15/21	4:22	2nd Floor Faculty BS (right)	G	DW				1													
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle							P														Container Type
Preservation Added Upon Receipt:					Manufacturer/L of #: _____ Date: _____ Time: _____					Sample # (s): _____											
Relinquished by: _____					Date/Time: _____ Company OUBOCES					Received by: _____					Date/Time: _____ Company						
Relinquished by: _____					Date/Time: _____ Company					Received by: _____					Date/Time: _____ Company						
Relinquished by: _____					Date/Time: _____ Company					Received by: _____					Date/Time: _____ Company						
ICE Present:		Custody Seal No.:			Custody Seals Intact: Δ			Cooler Temperature(s) °C/ IR GUN #:													

[illegible]

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-195346-1

SDG Number: Washingtonville CSD Middle School

Login Number: 195346

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	20.0C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require chilled samples
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	