

ANALYTICAL REPORT

Job Number: 420-196950-1

SDG Number: CTE

Job Description: Orange-Ulster BOCES

For:

Orange-Ulster BOCES

53 Gibson Road

Goshen, NY 10924

Attention: Jack DeGraw



Designee for

Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

07/13/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at Envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

Envirotest Laboratories

315 Fullerton Avenue, Newburgh, NY 12550

Tel (845) 562-0890 Fax (845) 562-0841 www.envirotestlaboratories.com

METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-196950-1

SDG Number: CTE

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-196950-1

SDG Number: CTE

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Cusack, Renee	RC
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-196950-1

SDG Number: CTE

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-196950-1	Boiler Room	Drinking Water	04/23/2021 0449	05/07/2021 1253
420-196950-2	152 Kitchen prep sink #1 south wall	Drinking Water	04/23/2021 0455	05/07/2021 1253
420-196950-3	152 Kitchen prep sink #2 south wall	Drinking Water	04/23/2021 0455	05/07/2021 1253
420-196950-4	152 Kitxhen prep sink island west	Drinking Water	04/23/2021 0456	05/07/2021 1253
420-196950-5	152 Kitchen Culligan Filter water fill	Drinking Water	04/23/2021 0457	05/07/2021 1253
420-196950-6	152 Kitchen prep island center sink	Drinking Water	04/23/2021 0457	05/07/2021 1253
420-196950-7	152 Kitchen North wall dish wash sink #1	Drinking Water	04/23/2021 0458	05/07/2021 1253
420-196950-8	152 Kitchen North wall dish wash sink #2	Drinking Water	04/23/2021 0458	05/07/2021 1253
420-196950-9	152 Kitchen North wall dish wash sink #3	Drinking Water	04/23/2021 0458	05/07/2021 1253
420-196950-10	Rm 152 Commercial Kitchen Ice Machine	Drinking Water	04/23/2021 0458	05/07/2021 1253
420-196950-11	162 BR Sink	Drinking Water	04/23/2021 0500	05/07/2021 1253
420-196950-12	152 Kitchen prep sink island east	Drinking Water	04/23/2021 0500	05/07/2021 1253
420-196950-13	152 Kitchen East Wall dish wash sink #1	Drinking Water	04/23/2021 0501	05/07/2021 1253
420-196950-14	152 Kitchen East Wall dish wash sink #2	Drinking Water	04/23/2021 0501	05/07/2021 1253
420-196950-15	152 Kitchen East Wall dish wash sink #3	Drinking Water	04/23/2021 0501	05/07/2021 1253
420-196950-16	166 sink left	Drinking Water	04/23/2021 0502	05/07/2021 1253
420-196950-17	166 sink right	Drinking Water	04/23/2021 0502	05/07/2021 1253
420-196950-18	152 Kitchen HS east wall	Drinking Water	04/23/2021 0503	05/07/2021 1253
420-196950-19	152 small kitchen dish wash sink #1	Drinking Water	04/23/2021 0504	05/07/2021 1253
420-196950-20	152 small kitchen dish wash sink #2	Drinking Water	04/23/2021 0504	05/07/2021 1253
420-196950-21	152 small kitchen HS	Drinking Water	04/23/2021 0504	05/07/2021 1253
420-196950-22	163 locker room sink	Drinking Water	04/23/2021 0504	05/07/2021 1253
420-196950-23	165 BR #1	Drinking Water	04/23/2021 0507	05/07/2021 1253
420-196950-24	165 BR #2	Drinking Water	04/23/2021 0507	05/07/2021 1253
420-196950-25	169 CS	Drinking Water	04/23/2021 0507	05/07/2021 1253
420-196950-26	132 work station sink	Drinking Water	04/23/2021 0509	05/07/2021 1253
420-196950-27	132 BR sink	Drinking Water	04/23/2021 0509	05/07/2021 1253
420-196950-28	Woman's BR o/s 169	Drinking Water	04/23/2021 0509	05/07/2021 1253
420-196950-29	132 sink Kitchen	Drinking Water	04/23/2021 0510	05/07/2021 1253
420-196950-30	CU/BF o/s 169	Drinking Water	04/23/2021 0510	05/07/2021 1253
420-196950-31	101 Main Office KS	Drinking Water	04/23/2021 0511	05/07/2021 1253
420-196950-32	129 Nurse's sink	Drinking Water	04/23/2021 0512	05/07/2021 1253
420-196950-33	105 BR 106 side	Drinking Water	04/23/2021 0512	05/07/2021 1253
420-196950-34	125 CS	Drinking Water	04/23/2021 0513	05/07/2021 1253
420-196950-35	105 Bath 104 side	Drinking Water	04/23/2021 0517	05/07/2021 1253

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-196950-1

SDG Number: CTE

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-196950-36	124 KS	Drinking Water	04/23/2021 0518	05/07/2021 1253
420-196950-37	124 BR sink	Drinking Water	04/23/2021 0518	05/07/2021 1253
420-196950-38	113 BR sink	Drinking Water	04/23/2021 0519	05/07/2021 1253
420-196950-39	111 Bath sink	Drinking Water	04/23/2021 0520	05/07/2021 1253
420-196950-40	114 BR sink	Drinking Water	04/23/2021 0520	05/07/2021 1253
420-196950-41	115 Bath sink	Drinking Water	04/23/2021 0523	05/07/2021 1253
420-196950-42	200 sink #1 KS	Drinking Water	04/23/2021 0523	05/07/2021 1253
420-196950-43	200 sink #2 KS	Drinking Water	04/23/2021 0524	05/07/2021 1253
420-196950-44	200 BR sink	Drinking Water	04/23/2021 0524	05/07/2021 1253
420-196950-45	118 Bath sink	Drinking Water	04/23/2021 0524	05/07/2021 1253
420-196950-46	218A Bath	Drinking Water	04/23/2021 0526	05/07/2021 1253
420-196950-47	218A KS #1	Drinking Water	04/23/2021 0526	05/07/2021 1253
420-196950-48	218A KS #2	Drinking Water	04/23/2021 0526	05/07/2021 1253
420-196950-49	204 BR Sink	Drinking Water	04/23/2021 0527	05/07/2021 1253
420-196950-50	204 CS	Drinking Water	04/23/2021 0528	05/07/2021 1253
420-196950-51	205 CS	Drinking Water	04/23/2021 0529	05/07/2021 1253
420-196950-52	218 C bath sink	Drinking Water	04/23/2021 0529	05/07/2021 1253
420-196950-53	212 CS	Drinking Water	04/23/2021 0531	05/07/2021 1253
420-196950-54	207 CS	Drinking Water	04/23/2021 0532	05/07/2021 1253
420-196950-55	210 CS	Drinking Water	04/23/2021 0533	05/07/2021 1253
420-196950-56	211 CS	Drinking Water	04/23/2021 0533	05/07/2021 1253
420-196950-57	209 CS	Drinking Water	04/23/2021 0535	05/07/2021 1253
420-196950-58	134 sink	Drinking Water	04/23/2021 0536	05/07/2021 1253
420-196950-59	137 CS	Drinking Water	04/23/2021 0536	05/07/2021 1253
420-196950-60	B 3 KS	Drinking Water	04/23/2021 0538	05/07/2021 1253
420-196950-61	138 CS	Drinking Water	04/23/2021 0539	05/07/2021 1253
420-196950-62	Mens Bath o/s 139	Drinking Water	04/23/2021 0541	05/07/2021 1253
420-196950-63	148 sink #1	Drinking Water	04/23/2021 0542	05/07/2021 1253
420-196950-64	148 CS #2	Drinking Water	04/23/2021 0543	05/07/2021 1253
420-196950-65	145 BR sink	Drinking Water	04/23/2021 0545	05/07/2021 1253
420-196950-66	139 CS	Drinking Water	04/23/2021 0547	05/07/2021 1253
420-196950-67	140 BR sink	Drinking Water	04/23/2021 0548	05/07/2021 1253
420-196950-68	144 Bath	Drinking Water	04/23/2021 0548	05/07/2021 1253
420-196950-69	141 BR sink	Drinking Water	04/23/2021 0549	05/07/2021 1253
420-196950-70	142 BR sink	Drinking Water	04/23/2021 0550	05/07/2021 1253
420-196950-71	407 KS	Drinking Water	04/23/2021 0550	05/07/2021 1253
420-196950-72	Woman o/s 407 Bath #1	Drinking Water	04/23/2021 0551	05/07/2021 1253
420-196950-73	Woman o/s 407 Bath #2	Drinking Water	04/23/2021 0551	05/07/2021 1253
420-196950-74	GN Bath o/s 407	Drinking Water	04/23/2021 0553	05/07/2021 1253
420-196950-75	407 HS	Drinking Water	04/23/2021 0554	05/07/2021 1253
420-196950-76	420 sink #1	Drinking Water	04/23/2021 0555	05/07/2021 1253
420-196950-77	420 sink #2	Drinking Water	04/23/2021 0555	05/07/2021 1253
420-196950-78	408 HS	Drinking Water	04/23/2021 0556	05/07/2021 1253
420-196950-79	408 dishwash sink	Drinking Water	04/23/2021 0556	05/07/2021 1253
420-196950-80	408 prep sink by cooler	Drinking Water	04/23/2021 0557	05/07/2021 1253

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: Boiler Room
Lab Sample ID: 420-196950-1

Date Sampled: 04/23/2021 0449
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 0810	
Prep Method: 200.7/200.8			Date Prepared:	07/10/2021 1424	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitchen prep sink #1 south wall
Lab Sample ID: 420-196950-2

Date Sampled: 04/23/2021 0455
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0812		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitchen prep sink #2 south wall
Lab Sample ID: 420-196950-3

Date Sampled: 04/23/2021 0455
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0815		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitxhen prep sink island west
Lab Sample ID: 420-196950-4

Date Sampled: 04/23/2021 0456
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0817		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitchen Culligan Filter water fill
Lab Sample ID: 420-196950-5

Date Sampled: 04/23/2021 0457
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0819		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitchen prep island center sink
Lab Sample ID: 420-196950-6

Date Sampled: 04/23/2021 0457
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0821		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitchen North wall dish wash sink #1
Lab Sample ID: 420-196950-7

Date Sampled: 04/23/2021 0458
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 0828	
Prep Method: 200.7/200.8			Date Prepared:	07/10/2021 1424	
Pb	4.45	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitchen North wall dish wash sink #2
Lab Sample ID: 420-196950-8

Date Sampled: 04/23/2021 0458
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0832		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.11	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitchen North wall dish wash sink #3
Lab Sample ID: 420-196950-9

Date Sampled: 04/23/2021 0458
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0834		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: Rm 152 Commercial Kitchen Ice Machine
Lab Sample ID: 420-196950-10

Date Sampled: 04/23/2021 0458
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0836		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 162 BR Sink
Lab Sample ID: 420-196950-11

Date Sampled: 04/23/2021 0500
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0839		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.28	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitchen prep sink island east
Lab Sample ID: 420-196950-12

Date Sampled: 04/23/2021 0500
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0841		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitchen East Wall dish wash sink #1
Lab Sample ID: 420-196950-13

Date Sampled: 04/23/2021 0501
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0843		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitchen East Wall dish wash sink #2
Lab Sample ID: 420-196950-14

Date Sampled: 04/23/2021 0501
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0845		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitchen East Wall dish wash sink #3
Lab Sample ID: 420-196950-15

Date Sampled: 04/23/2021 0501
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0847		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 166 sink left
Lab Sample ID: 420-196950-16

Date Sampled: 04/23/2021 0502
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0854		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 166 sink right
Lab Sample ID: 420-196950-17

Date Sampled: 04/23/2021 0502
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0856		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 Kitchen HS east wall
Lab Sample ID: 420-196950-18

Date Sampled: 04/23/2021 0503
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0905		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 small kitchen dish wash sink #1
Lab Sample ID: 420-196950-19

Date Sampled: 04/23/2021 0504
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0907		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	3.75	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 small kitchen dish wash sink #2
Lab Sample ID: 420-196950-20

Date Sampled: 04/23/2021 0504
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0909		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 152 small kitchen HS
Lab Sample ID: 420-196950-21

Date Sampled: 04/23/2021 0504
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 0911	
Prep Method: 200.7/200.8			Date Prepared:	07/10/2021 1424	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 163 locker room sink
Lab Sample ID: 420-196950-22

Date Sampled: 04/23/2021 0504
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0913		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 165 BR #1
Lab Sample ID: 420-196950-23

Date Sampled: 04/23/2021 0507
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0920		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.54	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 165 BR #2
Lab Sample ID: 420-196950-24

Date Sampled: 04/23/2021 0507
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0922		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.86	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 169 CS
Lab Sample ID: 420-196950-25

Date Sampled: 04/23/2021 0507
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0924		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 132 work station sink
Lab Sample ID: 420-196950-26

Date Sampled: 04/23/2021 0509
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0927		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 132 BR sink
Lab Sample ID: 420-196950-27

Date Sampled: 04/23/2021 0509
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0929		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: Woman's BR o/s 169
Lab Sample ID: 420-196950-28

Date Sampled: 04/23/2021 0509
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 0933	
Prep Method: 200.7/200.8			Date Prepared:	07/10/2021 1424	
Pb	1.08	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 132 sink Kitchen
Lab Sample ID: 420-196950-29

Date Sampled: 04/23/2021 0510
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0935		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: CU/BF o/s 169
Lab Sample ID: 420-196950-30

Date Sampled: 04/23/2021 0510
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0937		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 101 Main Office KS
Lab Sample ID: 420-196950-31

Date Sampled: 04/23/2021 0511
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0940		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 129 Nurse's sink
Lab Sample ID: 420-196950-32

Date Sampled: 04/23/2021 0512
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0946		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 105 BR 106 side
Lab Sample ID: 420-196950-33

Date Sampled: 04/23/2021 0512
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0948		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	8.42	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 125 CS
Lab Sample ID: 420-196950-34

Date Sampled: 04/23/2021 0513
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0950		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	4.47	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 105 Bath 104 side
Lab Sample ID: 420-196950-35

Date Sampled: 04/23/2021 0517
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0953		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	562 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 124 KS
Lab Sample ID: 420-196950-36

Date Sampled: 04/23/2021 0518
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0955		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 124 BR sink
Lab Sample ID: 420-196950-37

Date Sampled: 04/23/2021 0518
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1613	
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021	1424	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 113 BR sink
Lab Sample ID: 420-196950-38

Date Sampled: 04/23/2021 0519
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0957		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 111 Bath sink
Lab Sample ID: 420-196950-39

Date Sampled: 04/23/2021 0520
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 0959		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 114 BR sink
Lab Sample ID: 420-196950-40

Date Sampled: 04/23/2021 0520
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1621	
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021	1424	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 115 Bath sink
Lab Sample ID: 420-196950-41

Date Sampled: 04/23/2021 0523
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1623	
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021	1424	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 200 sink #1 KS
Lab Sample ID: 420-196950-42

Date Sampled: 04/23/2021 0523
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1626	
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021	1424	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 200 sink #2 KS
Lab Sample ID: 420-196950-43

Date Sampled: 04/23/2021 0524
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1628	
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021	1424	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 200 BR sink
Lab Sample ID: 420-196950-44

Date Sampled: 04/23/2021 0524
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 1630		
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021 1424		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 118 Bath sink
Lab Sample ID: 420-196950-45

Date Sampled: 04/23/2021 0524
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1632	
Prep Method: 200.7/200.8			Date Prepared: 07/10/2021	1424	
Pb	1.08	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 218A Bath
Lab Sample ID: 420-196950-46

Date Sampled: 04/23/2021 0526
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1652	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 218A KS #1
Lab Sample ID: 420-196950-47

Date Sampled: 04/23/2021 0526
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1654	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	53.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 218A KS #2
Lab Sample ID: 420-196950-48

Date Sampled: 04/23/2021 0526
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 1656	
Prep Method: 200.7/200.8			Date Prepared:	07/11/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 204 BR Sink
Lab Sample ID: 420-196950-49

Date Sampled: 04/23/2021 0527
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 1658	
Prep Method: 200.7/200.8			Date Prepared:	07/11/2021 1000	
Pb	1.30	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 204 CS
Lab Sample ID: 420-196950-50

Date Sampled: 04/23/2021 0528
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 1705	
Prep Method: 200.7/200.8			Date Prepared:	07/11/2021 1000	
Pb	7.21	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 205 CS
Lab Sample ID: 420-196950-51

Date Sampled: 04/23/2021 0529
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1707	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 218 C bath sink
Lab Sample ID: 420-196950-52

Date Sampled: 04/23/2021 0529
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1709	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 212 CS
Lab Sample ID: 420-196950-53

Date Sampled: 04/23/2021 0531
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 1712	
Prep Method: 200.7/200.8			Date Prepared:	07/11/2021 1000	
Pb	1.21	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 207 CS
Lab Sample ID: 420-196950-54

Date Sampled: 04/23/2021 0532
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1716	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	5.76	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 210 CS
Lab Sample ID: 420-196950-55

Date Sampled: 04/23/2021 0533
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 1718	
Prep Method: 200.7/200.8			Date Prepared:	07/11/2021 1000	
Pb	4.80	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 211 CS
Lab Sample ID: 420-196950-56

Date Sampled: 04/23/2021 0533
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 1720	
Prep Method: 200.7/200.8			Date Prepared:	07/11/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 209 CS
Lab Sample ID: 420-196950-57

Date Sampled: 04/23/2021 0535
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution	
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1722		
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000		
Pb	32.2	g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 134 sink
Lab Sample ID: 420-196950-58

Date Sampled: 04/23/2021 0536
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 1725	
Prep Method: 200.7/200.8			Date Prepared:	07/11/2021 1000	
Pb	1.06	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 137 CS
Lab Sample ID: 420-196950-59

Date Sampled: 04/23/2021 0536
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 1731	
Prep Method: 200.7/200.8			Date Prepared:	07/11/2021 1000	
Pb	1.22	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: B 3 KS
Lab Sample ID: 420-196950-60

Date Sampled: 04/23/2021 0538
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1733	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	23.3 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 138 CS
Lab Sample ID: 420-196950-61

Date Sampled: 04/23/2021 0539
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 1736	
Prep Method: 200.7/200.8			Date Prepared:	07/11/2021 1000	
Pb	4.60	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: Mens Bath o/s 139
Lab Sample ID: 420-196950-62

Date Sampled: 04/23/2021 0541
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1738	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 148 sink #1
Lab Sample ID: 420-196950-63

Date Sampled: 04/23/2021 0542
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1740	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 148 CS #2
Lab Sample ID: 420-196950-64

Date Sampled: 04/23/2021 0543
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1749	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	51.0	U g ug/L	51.0	51.0	51

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 145 BR sink
Lab Sample ID: 420-196950-65

Date Sampled: 04/23/2021 0545
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1751	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 139 CS
Lab Sample ID: 420-196950-66

Date Sampled: 04/23/2021 0547
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1757	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 140 BR sink
Lab Sample ID: 420-196950-67

Date Sampled: 04/23/2021 0548
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/11/2021 1800	
Prep Method: 200.7/200.8			Date Prepared:	07/11/2021 1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 144 Bath
Lab Sample ID: 420-196950-68

Date Sampled: 04/23/2021 0548
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1802	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.27	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 141 BR sink
Lab Sample ID: 420-196950-69

Date Sampled: 04/23/2021 0549
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1804	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 142 BR sink
Lab Sample ID: 420-196950-70

Date Sampled: 04/23/2021 0550
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1806	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 407 KS
Lab Sample ID: 420-196950-71

Date Sampled: 04/23/2021 0550
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1808	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: Woman o/s 407 Bath #1
Lab Sample ID: 420-196950-72

Date Sampled: 04/23/2021 0551
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1811	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	9.60	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: Woman o/s 407 Bath #2
Lab Sample ID: 420-196950-73

Date Sampled: 04/23/2021 0551
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1813	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.47	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: GN Bath o/s 407
Lab Sample ID: 420-196950-74

Date Sampled: 04/23/2021 0553
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1817	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 407 HS
Lab Sample ID: 420-196950-75

Date Sampled: 04/23/2021 0554
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1824	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 420 sink #1
Lab Sample ID: 420-196950-76

Date Sampled: 04/23/2021 0555
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	1.00 U	ug/L	1.00	07/11/2021 1826 1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 420 sink #2
Lab Sample ID: 420-196950-77

Date Sampled: 04/23/2021 0555
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1828	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 408 HS
Lab Sample ID: 420-196950-78

Date Sampled: 04/23/2021 0556
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1830	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 408 dishwash sink
Lab Sample ID: 420-196950-79

Date Sampled: 04/23/2021 0556
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021	1832	
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021	1000	
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196950-1
Sdg Number: CTE

Client Sample ID: 408 prep sink by cooler
Lab Sample ID: 420-196950-80

Date Sampled: 04/23/2021 0557
Date Received: 05/07/2021 1253
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/11/2021 1835		
Prep Method: 200.7/200.8			Date Prepared: 07/11/2021 1000		
Pb	1.00 U	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:
Sdg Number: CTE

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: CTE

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: CTE

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.


EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record

EnviroTest Laboratories

Client Information		Sampler: Joseph Russo	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 196950
Client Contact: Joseph Russo		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES		Analysis Requested			Page: Page 1 of 6
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	 420-196950-B-1 Boiler Room Date Sampled: 4/23/2021 420-1686314		
City: Goshen		TAT Requested (days):			
State, Zip: NY, 10924		PO #:			
Phone: 845-781-4887		PWS #:			
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Project #:	Other: D-Nitric Acid Upon Receipt Preservation verified: Y / N		
Project Name: Orange-Ulster BOCES - CTE		Additional Contacts:			
Site: Career and Technical Education					

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Y/N)	Performs MS/MS (Yes/No)	Chlorine Present (Yes/No)	Lead	Total Number of Containers	Special Instructions/Note:
4/23/21	4:49	Boiler Room		G	DW				1	1	
4/23/21	4:55	152 Kitchen prep sink #1 south wall		G	DW				1	1	
4/23/21	4:55	152 Kitchen prep sink #2 south wall		G	DW				1	1	
4/23/21	4:56	152 Kitchen prep sink island west		G	DW				1	1	
4/23/21	4:57	152 Kitchen Culligan Filter water fill		G	DW				1	1	
4/23/21	4:57	152 Kitchen prep island center sink		G	DW				1	1	
4/23/21	4:58	152 Kitchen North wall dish wash sink #1		G	DW				1	1	
4/23/21	4:58	152 Kitchen North wall dish wash sink #2		G	DW				1	1	
4/23/21	4:58	152 Kitchen North wall dish wash sink #3		G	DW				1	1	
4/23/21	4:58	Rm 152 Commercial Kitchen Ice Machine		G	DW				1	1	
4/23/21	5:00	162 BR sink		G	DW				1	1	
4/23/21	5:00	152 Kitchen prep sink island east		G	DW				1	1	
4/23/21	5:01	152 Kitchen East wall dish wash sink #1		G	DW				1	1	
4/23/21	5:01	152 Kitchen East wall dish wash sink #2		G	DW				1	1	
4/23/21	5:01	152 Kitchen East wall dish wash sink #3		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		Manufacturer/1 of #:		Date:	Time:	Sample # (s):	Container Type
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:		



ICE Present: Custody Seal No.: _____ Custody Seals Intact: Cooler Temperature(s) °C/IR GUN #: **21.7 C**

Chain of Custody Record

Client Information Client Contact: Joseph Russo	Sampler: Joseph Russo Phone: 845-781-4887	Lab PM: E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 196950
--	--	--	--	-----------------------------

Company: Orange-Ulster BOCES		Analysis Requested					Page: Page 2 of 6
Address: 53 Gibson Road	Due Date Requested: Standard Turn-Around						Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate Other: D-Nitric Acid Upon Receipt Preservation verified: Y / N
City: Goshen	TAT Requested (days):						
State, Zip: NY, 10924	PO #:						
Phone: 845-781-4887	PWS #:						
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org	Project #:						
Project Name: Orange-Ulster BOCES - CTE	Additional Contacts:						
Site: Career and Technical Education							

Sample Date	Sample Time	Sample Identification Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/SP (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
			Preservation Code:					D		
4/23/21	5:02	166 sink left	G	DW				1	1	
4/23/21	5:02	166 sink Right	G	DW				1	1	
4/23/21	5:03	152 Kitchen HS east wall	G	DW				1	1	
4/23/21	5:04	152 small Kitchen Dish wash sink #1	G	DW				1	1	
4/23/21	5:04	152 small Kitchen Dish wash sink #2	G	DW				1	1	
4/23/21	5:04	152 small Kitchen HS	G	DW				1	1	
4/23/21	5:04	163 Locker room sink	G	DW				1	1	
4/23/21	5:07	165 BR #1	G	DW				1	1	
4/23/21	5:07	165 BR #2	G	DW				1	1	
4/23/21	5:07	169 C. S.	G	DW				1	1	
4/23/21	5:09	132 work station sink	G	DW				1	1	
4/23/21	5:09	132 BR sink	G	DW				1	1	
4/23/21	5:09	Woman's BR o/s 169	G	DW				1	1	
4/23/21	5:10	132 sink Kitchen	G	DW				1	1	
4/23/21	5:10	CU/BF o/s 169	G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle	P	Container Type			
Preservation Added Upon Receipt:	Manufacturer/lot #	Date:	Time:	Sample # (s):	
Relinquished by: 	Date/Time: 5/7/21 12:53	Company: OUBOCES	Received by: 	Date/Time: 5/17/21 1253	Company: ETR
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present: Custody Seal No.: _____ Custody Seals Intact: Cooler Temperature(s) °C/IR GUN #: **21.7**

Client Information		Sampler: Joseph Russo	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 196950
Client Contact: Joseph Russo		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		

Company: Orange-Ulster BOCES			Analysis Requested												Page: Page 3 of 6							
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around		Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers													Preservation Codes:	
City: Goshen		TAT Requested (days):																			A - HCL	L - EDA
State, Zip: NY, 10924		PO #:																			B - NaOH	M - Sodium Sulfitte
Phone: 845-781-4887		PWS #:																			C - Zn Acetate	N - None
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Project #:																			D - Nitric Acid	O - MCAA
Project Name: Orange-Ulster BOCES - CTE		Additional Contacts:																			E - H2SO4	P - Other (specify)
Site: Career and Technical Education				F - MeOH	G - NH4CL																	
				H - Ascorbic Acid	I - Ice																	
				J - DI Water	K - Sodium																	
				Thiosulfate																		
				Other: D-Nitric Acid																		
				Upon Receipt Preservation verified: Y / N																		

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/foil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead													Total Number of Containers	Special Instructions/Note:
4/23/21	5:11	101 Main Office	KS	G	DW				1													1	
4/23/21	5:12	129 Nurse's sink		G	DW				1													1	
4/23/21	5:12	105 BR 106 side		G	DW				1													1	
4/23/21	5:13	125 C.S.		G	DW				1													1	
4/23/21	5:17	105 Bath 104 Side		G	DW				1													1	
4/23/21	5:18	124 KS		G	DW				1													1	
4/23/21	5:18	124 BR sink		G	DW				1													1	
4/23/21	5:19	113 BR sink		G	DW				1													1	
4/23/21	5:20	111 Bath sink		G	DW				1													1	
4/23/21	5:20	114 BR sink		G	DW				1													1	
4/23/21	5:23	115 Bath sink		G	DW				1													1	
4/23/21	5:23	200 sink #1	KS	G	DW				1													1	
4/23/21	5:24	200 sink #2	KS	G	DW				1													1	
4/23/21	5:24	200 BR sink		G	DW				1													1	
4/23/21	5:24	118 Bath sink		G	DW				1													1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle
 Container Type: **P**

Preservation Added Upon Receipt:	Manufacturer/lot #:	Date:	Time:	Sample # (s):
Relinquished by:	Company: OUBOCES	Date/Time: 5/7/21 12:53	Received by:	Date/Time: 5/7/21 12:53
Relinquished by:	Company:	Date/Time:	Received by:	Date/Time:
Relinquished by:	Company:	Date/Time:	Received by:	Date/Time:

ICE Present: Custody Seal No.: _____ Custody Seals Intact: Cooler Temperature(s) °C/IR GUN #: 21.7°C

Client Information		Sampler: Joseph Russo	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 196950
Client Contact: Joseph Russo		Phone: 845-781-4887	E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		
Company: Orange-Ulster BOCES					Page: Page 4 of 6

Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around	Analysis Requested										Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfitte N - None O - MCAA P - Other (specify)				
City: Goshen		TAT Requested (days):	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead											
State, Zip: NY, 10924		PO #:															
Phone: 845-781-4887		PWS #:															
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org		Project #:															
Project Name: Orange-Ulster BOCES - CTE		Additional Contacts:															
Site: Career and Technical Education																	

Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
4/23/21	5:26	218A Bath		G	DW				1	1	
4/23/21	5:26	218A KS #1		G	DW				1	1	
4/23/21	5:26	218A KS #2		G	DW				1	1	
4/23/21	5:27	204 BR sink		G	DW				1	1	
4/23/21	5:28	204 C.S.		G	DW				1	1	
4/23/21	5:29	205 C.S.		G	DW				1	1	
4/23/21	5:29	218C Bath sink		G	DW				1	1	
4/23/21	5:31	212 CS		G	DW				1	1	
4/23/21	5:32	207 C.S.		G	DW				1	1	
4/23/21	5:33	210 C.S.		G	DW				1	1	
4/23/21	5:33	211 C.S.		G	DW				1	1	
4/23/21	5:35	209 C.S.		G	DW				1	1	
4/23/21	5:36	134 sink		G	DW				1	1	
4/23/21	5:36	137 C.S.		G	DW				1	1	
4/23/21	5:38	B 3 KS		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle

Preservation Added Upon Receipt: AW Manufacturer/Lot #: _____ Date: _____ Time: _____ Sample # (s): _____ Container Type

Relinquished by: <u>AW</u>	Date/Time: <u>5/7/21 12:33</u>	Company: OUBOCES	Received by: <u>AW</u>	Date/Time: <u>5/7/21 12:53</u>	Company: <u>ETC</u>
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present: Y Custody Seal No.: _____ Custody Seals Intact: Δ Cooler Temperature(s) °C/IR GUN #: 21.7 C

Client Information	Sampler: Joseph Russo	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 196950
	Client Contact: Joseph Russo	Phone: 845-781-4887		

Company: Orange-Ulster BOCES Address: 53 Gibson Road City: Goshen State, Zip: NY, 10924 Phone: 845-781-4887 Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org Project Name: Orange-Ulster BOCES - CTE Site: Career and Technical Education	Due Date Requested: Standard Turn-Around	Analysis Requested	Page: Page 5 of 6	
	TAT Requested (days):			Preservation Codes:
	PO #:			A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate
	PWS #:			L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)
Project #:	Additional Contacts:	Other: D-Nitric Acid Upon Receipt Preservation verified: Y / N		

Sample Date	Sample Time	Sample Identification Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Performs MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers	Special Instructions/Note:
4/23/21	5:39	138 C.S.	G	DW				1	1	
4/23/21	5:41	Mens Bath o/s 139	G	DW				1	1	
4/23/21	5:42	148 sink #1	G	DW				1	1	
4/23/21	5:43	148 CS #2	G	DW				1	1	
4/23/21	5:45	145 BR sink	G	DW				1	1	
4/23/21	5:47	139 C.S.	G	DW				1	1	
4/23/21	5:48	140 BR sink	G	DW				1	1	
4/23/21	5:48	144 Bath	G	DW				1	1	
4/23/21	5:49	141 BR sink	G	DW				1	1	
4/23/21	5:50	142 BR sink	G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle				P	Container Type
Preservation Added Upon Receipt:	Manufacturer/Lot #:	Date:	Time:	Sample # (s):	
Relinquished by: <i>[Signature]</i>	Date/Time: 5/7/21 12:53	Company: OUBOCES	Received by: <i>[Signature]</i>	Date/Time: 5/7/21 12:53	Company: <i>[Signature]</i>
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present: Custody Seal No.: Custody Seals Intact: Cooler Temperature(s) °C/IR GUN #: 21.7°C

Client Information

Client Contact:
Joseph Russo

Sampler:
Joseph Russo
Phone:
845-781-4887

Lab PM:
E-Mail:
joseph.russo@ouboces.org
Halina.redner@ouboces.org
Maureen.doherty@ouboces.org

Deliverable Type:
Level I, Level II,
NYS ASP Cat B
EDD (Specify):

JOB #:

196950

Company:
Orange-Ulster BOCES

Address:
53 Gibson Road
City:
Goshen
State, Zip:
NY, 10924

Phone:
845-781-4887

Email:

joseph.russo@ouboces.org
Maureen.doherty@ouboces.org

Halina.redner@ouboces.org

Project Name:

Orange-Ulster BOCES - CTE (400 bldg.)

Site:

Career and Technical Education (400 Bldg.)

Due Date Requested:
Standard Turn-Around
TAT Requested (days):

PO #:

PWS #:

Project #:

Additional Contacts:

Analysis RequestedPage:
Page 6 of 6

Preservation Codes:

A - HCL	L - EDA
B - NaOH	M - Sodium Sulfite
C - Zn Acetate	N - None
D - Nitric Acid	O - MCAA
E - H2SO4	P - Other (specify)
F - MeOH	
G - NH4CL	
H - Ascorbic Acid	
I - Ice	
J - DI Water	
K - Sodium Thioculfate	

Other:

D-Nitric Acid

Upon Receipt Preservation verified:
Y / N

Sample Date	Sample Time	Sample Identification Client ID (Lab ID)	Sample Type (G=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Containers
4/23/21	5:50	407 KS	G	DW	X	X	X	1	1
4/23/21	5:51	Woman's o/s 407 Bath #1	G	DW	X	X	X	1	1
4/23/21	5:51	Woman's o/s 407 Bath #2	G	DW	X	X	X	1	1
4/23/21	5:53	GN Bath o/s 407	G	DW	X	X	X	1	1
4/23/21	5:54	407 HS	G	DW	X	X	X	1	1
4/23/21	5:55	420 sink #1	G	DW	X	X	X	1	1
4/23/21	5:55	420 sink #2	G	DW	X	X	X	1	1
4/23/21	5:56	408 HS	G	DW	X	X	X	1	1
4/23/21	5:56	408 Dish wash sink	G	DW	X	X	X	1	1
4/23/21	5:57	408 prep sink by cooler	G	DW	X	X	X	1	1

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle

P

Container Type

Preservation Added Upon Receipt:

Manufacturer/Lot #

Date:

Time:

Sample # (s):

Relinquished by:

Date/Time:

Company:

Received by:

Date/Time:

Company:

Relinquished by:

Date/Time:

Company:

Received by:

Date/Time:

Company:

Relinquished by:

Date/Time:

Company:

Received by:

Date/Time:

Company:

ICE Present:

Custody Seal No.:

Custody Seals Intact:

Cooler Temperature(s) °C/IR GUN #:

7/17°C

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-196950-1

SDG Number: CTE

Login Number: 196950

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	21.7 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	

SAMPLE DELIVERY GROUP	CLIENT SAMPLE ID	RESULT	DATE SAMPLED	TIME COLLECTED
CTE	Boiler Room	ND<1.00	04/23/2021	04:49
CTE	Rm 152 Commercial Kitchen Ice Machine	ND<1.00	04/23/2021	04:58
CTE	162 BR Sink	1.28	04/23/2021	05:00
CTE	152 Kitchen prep sink island east	ND<1.00	04/23/2021	05:00
CTE	152 Kitchen East Wall dish wash sink #1	ND<1.00	04/23/2021	05:01
CTE	152 Kitchen East Wall dish wash sink #2	ND<1.00	04/23/2021	05:01
CTE	152 Kitchen East Wall dish wash sink #3	ND<1.00	04/23/2021	05:01
CTE	166 sink left	ND<1.00	04/23/2021	05:02
CTE	166 sink right	ND<1.00	04/23/2021	05:02
CTE	152 Kitchen HS east wall	ND<1.00	04/23/2021	05:03
CTE	152 small kitchen dish wash sink #1	3.75	04/23/2021	05:04
CTE	152 Kitchen prep sink #1 south wall	ND<1.00	04/23/2021	04:55
CTE	152 small kitchen dish wash sink #2	ND<1.00	04/23/2021	05:04
CTE	152 small kitchen HS	ND<1.00	04/23/2021	05:04
CTE	163 locker room sink	ND<1.00	04/23/2021	05:04
CTE	165 BR #1	1.54	04/23/2021	05:07
CTE	165 BR #2	1.86	04/23/2021	05:07
CTE	169 CS	ND<1.00	04/23/2021	05:07
CTE	132 work station sink	ND<1.00	04/23/2021	05:09
CTE	132 BR sink	ND<1.00	04/23/2021	05:09
CTE	Woman's BR o/s 169	1.08	04/23/2021	05:09
CTE	132 sink Kitchen	ND<1.00	04/23/2021	05:10
CTE	152 Kitchen prep sink #2 south wall	ND<1.00	04/23/2021	04:55
CTE	CU/BF o/s 169	ND<1.00	04/23/2021	05:10
CTE	101 Main Office KS	ND<1.00	04/23/2021	05:11
CTE	129 Nurse's sink	ND<1.00	04/23/2021	05:12
CTE	105 BR 106 side	8.42	04/23/2021	05:12
CTE	125 CS	4.47	04/23/2021	05:13
CTE	105 Bath 104 side	562	04/23/2021	05:17
CTE	124 KS	ND<1.00	04/23/2021	05:18
CTE	124 BR sink	ND<1.00	04/23/2021	05:18
CTE	113 BR sink	ND<1.00	04/23/2021	05:19
CTE	111 Bath sink	ND<1.00	04/23/2021	05:20
CTE	152 Kitxhen prep sink island west	ND<1.00	04/23/2021	04:56
CTE	114 BR sink	ND<1.00	04/23/2021	05:20
CTE	115 Bath sink	ND<1.00	04/23/2021	05:23
CTE	200 sink #1 KS	ND<1.00	04/23/2021	05:23
CTE	200 sink #2 KS	ND<1.00	04/23/2021	05:24
CTE	200 BR sink	ND<1.00	04/23/2021	05:24
CTE	118 Bath sink	1.08	04/23/2021	05:24
CTE	218A Bath	ND<1.00	04/23/2021	05:26
CTE	218A KS #1	53.0	04/23/2021	05:26
CTE	218A KS #2	ND<1.00	04/23/2021	05:26
CTE	204 BR Sink	1.30	04/23/2021	05:27
CTE	152 Kitchen Culligan Filter water fill	ND<1.00	04/23/2021	04:57
CTE	204 CS	7.21	04/23/2021	05:28
CTE	205 CS	ND<1.00	04/23/2021	05:29
CTE	218 C bath sink	ND<1.00	04/23/2021	05:29
CTE	212 CS	1.21	04/23/2021	05:31
CTE	207 CS	5.76	04/23/2021	05:32
CTE	210 CS	4.80	04/23/2021	05:33
CTE	211 CS	ND<1.00	04/23/2021	05:33
CTE	209 CS	32.2	04/23/2021	05:35
CTE	134 sink	1.06	04/23/2021	05:36
CTE	137 CS	1.22	04/23/2021	05:36
CTE	152 Kitchen prep island center sink	ND<1.00	04/23/2021	04:57
CTE	B 3 KS	23.3	04/23/2021	05:38
CTE	138 CS	4.60	04/23/2021	05:39

CTE	Mens Bath o/s 139	ND<1.00	04/23/2021	05:41
CTE	148 sink #1	ND<1.00	04/23/2021	05:42
CTE	148 CS #2	51.0	04/23/2021	05:43
CTE	145 BR sink	ND<1.00	04/23/2021	05:45
CTE	139 CS	ND<1.00	04/23/2021	05:47
CTE	140 BR sink	ND<1.00	04/23/2021	05:48
CTE	144 Bath	1.27	04/23/2021	05:48
CTE	141 BR sink	ND<1.00	04/23/2021	05:49
CTE	152 Kitchen North wall dish wash sink #1	4.45	04/23/2021	04:58
CTE	142 BR sink	ND<1.00	04/23/2021	05:50
CTE	407 KS	ND<1.00	04/23/2021	05:50
CTE	Woman o/s 407 Bath #1	9.60	04/23/2021	05:51
CTE	Woman o/s 407 Bath #2	1.47	04/23/2021	05:51
CTE	GN Bath o/s 407	ND<1.00	04/23/2021	05:53
CTE	407 HS	ND<1.00	04/23/2021	05:54
CTE	420 sink #1	ND<1.00	04/23/2021	05:55
CTE	420 sink #2	ND<1.00	04/23/2021	05:55
CTE	408 HS	ND<1.00	04/23/2021	05:56
CTE	408 dishwash sink	ND<1.00	04/23/2021	05:56
CTE	152 Kitchen North wall dish wash sink #2	1.11	04/23/2021	04:58
CTE	408 prep sink by cooler	ND<1.00	04/23/2021	05:57
CTE	152 Kitchen North wall dish wash sink #3	ND<1.00	04/23/2021	04:58