

ANALYTICAL REPORT

Job Number: 420-196241-1

SDG Number: Marlboro CSD Middlehope Elementry School

Job Description: Orange-Ulster BOCES

For:

Orange-Ulster BOCES

53 Gibson Road

Goshen, NY 10924

Attention: Jack DeGraw

Meredith Ruthven

Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

07/07/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

Envirotest Laboratories

315 Fullerton Avenue, Newburgh, NY 12550

Tel (845) 562-0890 Fax (845) 562-0841 www.envirotestlaboratories.com

METHOD SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-196241-1

SDG Number: Marlboro CSD Middlehope Elementary School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-196241-1

SDG Number: Marlboro CSD Middlehope Elementry School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Orange-Ulster BOCES

Job Number: 420-196241-1

SDG Number: Marlboro CSD Middlehope Elementary School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-196241-1	Main office kitchen sink	Drinking Water	04/28/2021 0532	04/29/2021 1147
420-196241-2	Kitchen island sink	Drinking Water	04/28/2021 0534	04/29/2021 1147
420-196241-3	Kitchen handwashing sink	Drinking Water	04/28/2021 0535	04/29/2021 1147
420-196241-4	Kitchen 3-bay left faucet	Drinking Water	04/28/2021 0536	04/29/2021 1147
420-196241-5	Kitchen 3-bay right faucet	Drinking Water	04/28/2021 0537	04/29/2021 1147
420-196241-6	Kitchen 3-bay sink sprayer	Drinking Water	04/28/2021 0538	04/29/2021 1147
420-196241-7	Kitchen dishwasher sprayer	Drinking Water	04/28/2021 0540	04/29/2021 1147
420-196241-8	CS 109	Drinking Water	04/28/2021 0542	04/29/2021 1147
420-196241-9	CS 111	Drinking Water	04/28/2021 0543	04/29/2021 1147
420-196241-10	CS 103	Drinking Water	04/28/2021 0546	04/29/2021 1147
420-196241-11	Teachers lounge	Drinking Water	04/28/2021 0547	04/29/2021 1147
420-196241-12	CS 101A	Drinking Water	04/28/2021 0548	04/29/2021 1147
420-196241-13	CS 114	Drinking Water	04/28/2021 0550	04/29/2021 1147
420-196241-14	CS 112	Drinking Water	04/28/2021 0551	04/29/2021 1147
420-196241-15	CS 110	Drinking Water	04/28/2021 0552	04/29/2021 1147
420-196241-16	CS 113	Drinking Water	04/28/2021 0544	04/29/2021 1147
420-196241-17	Nurse's office med room sink	Drinking Water	04/28/2021 0353	04/29/2021 1147

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: Main office kitchen sink
Lab Sample ID: 420-196241-1

Date Sampled: 04/28/2021 0532
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/03/2021 0632		
Prep Method: 200.7/200.8			Date Prepared: 07/01/2021 1330		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementry School

Client Sample ID: Kitchen island sink
Lab Sample ID: 420-196241-2

Date Sampled: 04/28/2021 0534
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/03/2021 0634	
Prep Method: 200.7/200.8			Date Prepared:	07/01/2021 1330	
Pb	19.0 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: Kitchen handwashing sink
Lab Sample ID: 420-196241-3

Date Sampled: 04/28/2021 0535
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/03/2021 0637	
Prep Method: 200.7/200.8			Date Prepared:	07/01/2021 1330	
Pb	22.7 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: Kitchen 3-bay left faucet
Lab Sample ID: 420-196241-4

Date Sampled: 04/28/2021 0536
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/03/2021 0639	
Prep Method: 200.7/200.8			Date Prepared:	07/01/2021 1330	
Pb	4.75	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: Kitchen 3-bay right faucet
Lab Sample ID: 420-196241-5

Date Sampled: 04/28/2021 0537
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/03/2021 0641	
Prep Method: 200.7/200.8			Date Prepared:	07/01/2021 1330	
Pb	2.15	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: Kitchen 3-bay sink sprayer
Lab Sample ID: 420-196241-6

Date Sampled: 04/28/2021 0538
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/03/2021 0648		
Prep Method: 200.7/200.8			Date Prepared: 07/01/2021 1330		
Pb	3.35	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: Kitchen dishwasher sprayer
Lab Sample ID: 420-196241-7

Date Sampled: 04/28/2021 0540
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/03/2021 0650	
Prep Method: 200.7/200.8			Date Prepared:	07/01/2021 1330	
Pb	44.2 g	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: CS 109
Lab Sample ID: 420-196241-8

Date Sampled: 04/28/2021 0542
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/03/2021 0652	
Prep Method: 200.7/200.8			Date Prepared:	07/01/2021 1330	
Pb	3.36	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: CS 111
Lab Sample ID: 420-196241-9

Date Sampled: 04/28/2021 0543
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/03/2021 0654	
Prep Method: 200.7/200.8			Date Prepared:	07/01/2021 1330	
Pb	7.18	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementry School

Client Sample ID: CS 103
Lab Sample ID: 420-196241-10

Date Sampled: 04/28/2021 0546
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/03/2021 0703		
Prep Method: 200.7/200.8			Date Prepared: 07/01/2021 1330		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: Teachers lounge
Lab Sample ID: 420-196241-11

Date Sampled: 04/28/2021 0547
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/03/2021 0705		
Prep Method: 200.7/200.8			Date Prepared: 07/01/2021 1330		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementry School

Client Sample ID: CS 101A
Lab Sample ID: 420-196241-12

Date Sampled: 04/28/2021 0548
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/03/2021 0707	
Prep Method: 200.7/200.8			Date Prepared:	07/01/2021 1330	
Pb	1.40	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: CS 114
Lab Sample ID: 420-196241-13

Date Sampled: 04/28/2021 0550
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/03/2021 0714	
Prep Method: 200.7/200.8			Date Prepared:	07/01/2021 1330	
Pb	2.04	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: CS 112
Lab Sample ID: 420-196241-14

Date Sampled: 04/28/2021 0551
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/03/2021 0716	
Prep Method: 200.7/200.8			Date Prepared:	07/01/2021 1330	
Pb	5.09	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: CS 110
Lab Sample ID: 420-196241-15

Date Sampled: 04/28/2021 0552
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/03/2021 0718	
Prep Method: 200.7/200.8			Date Prepared:	07/01/2021 1330	
Pb	2.68	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: CS 113
Lab Sample ID: 420-196241-16

Date Sampled: 04/28/2021 0544
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed: 07/03/2021 0720		
Prep Method: 200.7/200.8			Date Prepared: 07/01/2021 1330		
Pb	1.00 U	ug/L	1.00	1.00	1.0

Jack DeGraw
Orange-Ulster BOCES
53 Gibson Road
Goshen, NY 10924

Job Number: 420-196241-1
Sdg Number: Marlboro CSD Middlehope Elementary School

Client Sample ID: Nurse's office med room sink
Lab Sample ID: 420-196241-17

Date Sampled: 04/28/2021 0353
Date Received: 04/29/2021 1147
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/03/2021 0723	
Prep Method: 200.7/200.8			Date Prepared:	07/01/2021 1330	
Pb	1.00 U	ug/L	1.00	1.00	1.0

DATA REPORTING QUALIFIERS

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Marlboro CSD Middlehope Elementry School

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Orange-Ulster BOCES

Job Number:

Sdg Number: Marlboro CSD Middlehope Elementry School

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Orange-Ulster BOCES


Job Number:

Sdg Number: Marlboro CSD Middlehope Elementary School

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

Client Information		Sampler: M. Doherty <i>Maureen Doherty</i>	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 196241
Client Contact: Joseph Russo		Phone: 845-781-4887	E-Mail: joseph.russo@oubores.org Halina.redner@oubores.org Maureen.doherty@oubores.org		

Company: Orange-Ulster BOCES		Analysis Requested			Page: Page 1 of 1
Address: 53 Gibson Road		Due Date Requested: Standard Turn-Around			Preservation Codes:
City: Goshen		TAT Requested (days):			A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate
State, Zip: NY, 10924		PO #:			L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)
Phone: 845-781-4887		PWS #:			
Email: joseph.russo@oubores.org Halina.redner@oubores.org Maureen.doherty@oubores.org					
Project Name: Marlboro CSD		Project #:	Date Sampled: 4/28/2021 420-1679289		
Site: Middlehope Elementary School		Additional Contacts:			Other: D-Nitric Acid



Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered (S)	Perform MS/MSD	Chlorine Present	Lead	Total Number of Containers	Special Instructions/Note:
4/28/21	5:32	Main office kitchen sink		G	DW				1	1	
4/28/21	5:34	Kitchen island sink		G	DW				1	1	
4/28/21	5:35	Kitchen hand washing sink		G	DW				1	1	
4/28/21	5:36	Kitchen 3-bay left faucet		G	DW				1	1	
4/28/21	5:37	Kitchen 3-bay right faucet		G	DW				1	1	
4/28/21	5:38	Kitchen 3-bay sink sprayer		G	DW				1	1	
4/28/21	5:40	Kitchen dishwasher sprayer		G	DW				1	1	
4/28/21	5:42	CS 109		G	DW				1	1	
4/28/21	5:43	CS 111		G	DW				1	1	
4/28/21	5:46	CS 103		G	DW				1	1	
4/28/21	5:47	teacher's lounge		G	DW				1	1	
4/28/21	5:48	CS 101A		G	DW				1	1	
4/28/21	5:50	CS 114		G	DW				1	1	
4/28/21	5:51	CS 112		G	DW				1	1	
4/28/21	5:52	CS 110		G	DW				1	1	

Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle		P		Container Type	
Preservation Added Upon Receipt:		Manufacturer/Lot #		Date:	
Relinquished by: <i>Maureen Doherty</i>	Date/Time: 4/29/21, 11:47	Company: OUBOCES	Received by: <i>LL</i>	Date/Time: 4/29/21 11:47	Company: ETC
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:

ICE Present: *no* Custody Seal No.: Custody Seals Intact: Δ Cooler Temperature(s) °C/IR GUN #: 21.8°C

Client Information		Sampler: <i>Maureen Doherty</i>			Lab PM:			Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):			JOB #: 196241				
Client Contact: Joseph Russo		Phone: 845-781-4887			E-Mail: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org						Page: Page 1 of 1				
Company: Orange-Ulster BOCES					Analysis Requested					Preservation Codes:					
Address: 53 Gibson Road					Due Date Requested: Standard Turn-Around					A - HCL			L- EDA		
City: Goshen					TAT Requested (days):					B - NaOH			M - Sodium Sulfit		
State, Zip: NY, 10924										C - Zn Acetate			N - None		
Phone: 845-781-4887					PO #:					D - Nitric Acid			O - MCAA		
Email: joseph.russo@ouboces.org Halina.redner@ouboces.org Maureen.doherty@ouboces.org					PWS #:					E - H2SO4			P - Other (specify)		
Project Name: Marlboro CSD					Project #:					F - MeOH			G - NH4CL		
Site: Middlehope Elementary School					Additional Contacts:					H - Ascorbic Acid			I - Ice		
										J - DI Water			K - Sodium Thiosulfate		
										Other: D-Nitric Acid			Upon Receipt Preservation verified: Y / N		
Sample Date	Sample Time	Sample Identification	Client ID (Lab ID)	Sample Type (C=comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/WSB (Yes or No)	Chlorine Present (Yes or No)	Lead	Total Number of Contaminants	Special Instructions/Note:				
4/28/21	5:44	CS 113		G	DW				1	1					
4/29/21	0353	Nurse's Office Med Room sink		G	DW				1	1					
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle										Container Type					
Preservation Added Upon Receipt:															
Relinquished by: <i>Maureen Doherty</i>				Manufacturer/lot #: <i>4/29/21; 1147</i>		Date/Time:		Time:		Sample # (s):					
Relinquished by:				Date/Time:		Company: OUBOCES		Received by: <i>LL</i>		Date/Time: <i>4/29/21 1147</i>		Company: <i>ETL</i>			
Relinquished by:				Date/Time:		Company:		Received by:		Date/Time:		Company:			
ICE Present: <i>Y</i>				Custody Seal No.:		Custody Seal Intact: Δ		Cooler Temperature(s) °C/IR GUN #: <i>21.8 °C</i>							

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Orange-Ulster BOCES

Job Number: 420-196241-1

SDG Number: Marlboro CSD Middlehope Elementary School

Login Number: 196241

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	21.8 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	

SAMPLE DELIVERY GROUP	CLIENT SAMPLE ID	RESULT	DATE SAMPLED	TIME COLLECTED
Marlboro CSD Middlehope Elementary School	Main office kitchen sink	ND<1.00	04/28/2021	05:32
Marlboro CSD Middlehope Elementary School	CS 103	ND<1.00	04/28/2021	05:46
Marlboro CSD Middlehope Elementary School	Teachers lounge	ND<1.00	04/28/2021	05:47
Marlboro CSD Middlehope Elementary School	CS 101A	1.40	04/28/2021	05:48
Marlboro CSD Middlehope Elementary School	CS 114	2.04	04/28/2021	05:50
Marlboro CSD Middlehope Elementary School	CS 112	5.09	04/28/2021	05:51
Marlboro CSD Middlehope Elementary School	CS 110	2.68	04/28/2021	05:52
Marlboro CSD Middlehope Elementary School	CS 113	ND<1.00	04/28/2021	05:44
Marlboro CSD Middlehope Elementary School	Nurse's office med room sink	ND<1.00	04/28/2021	03:53
Marlboro CSD Middlehope Elementary School	Kitchen island sink	19.0	04/28/2021	05:34
Marlboro CSD Middlehope Elementary School	Kitchen handwashing sink	22.7	04/28/2021	05:35
Marlboro CSD Middlehope Elementary School	Kitchen 3-bay left faucet	4.75	04/28/2021	05:36
Marlboro CSD Middlehope Elementary School	Kitchen 3-bay right faucet	2.15	04/28/2021	05:37
Marlboro CSD Middlehope Elementary School	Kitchen 3-bay sink sprayer	3.35	04/28/2021	05:38
Marlboro CSD Middlehope Elementary School	Kitchen dishwasher sprayer	44.2	04/28/2021	05:40
Marlboro CSD Middlehope Elementary School	CS 109	3.36	04/28/2021	05:42
Marlboro CSD Middlehope Elementary School	CS 111	7.18	04/28/2021	05:43