



Microbac Laboratories, Inc., New York Division  
**CERTIFICATE OF ANALYSIS**

J1G0925

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Sherman

Fred Hauck  
 20104 NYS Route 3  
 Watertown, NY 13601

Project / PO Number: N/A  
 Received: 07/02/2021  
 Reported: 07/31/2021

**Analytical Testing Parameters**

Client Sample ID:	27	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	06/30/2021 7:46
Lab Sample ID:	J1G0925-01		

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.000879	0.015 AL	0.000400	mg/L		07/21/21 2029	07/21/21 2029	EMB

Client Sample ID:	24	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	06/30/2021 7:45
Lab Sample ID:	J1G0925-02		

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0233	0.015 AL	0.000400	mg/L		07/21/21 2031	07/21/21 2031	EMB

Client Sample ID:	52	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	06/30/2021 7:47
Lab Sample ID:	J1G0925-03		

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0216	0.015 AL	0.000400	mg/L		07/21/21 2033	07/21/21 2033	EMB

Client Sample ID:	42	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	06/30/2021 7:50
Lab Sample ID:	J1G0925-04		

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0191	0.015 AL	0.000400	mg/L		07/21/21 2035	07/21/21 2035	EMB



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0925

Client Sample ID: 25	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 06/30/2021 7:45
Lab Sample ID: J1G0925-05	

Analyses Performed by: Microbac Laboratories Inc., Pittsburgh Division

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<b>0.0463</b>	0.015 AL	0.000400	mg/L		07/21/21 2037	07/21/21 2037	EMB

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division  
10121  
02-00257

New York State Department of Health  
PA Department of Environmental Protection  
PADEP Accreditation by Rule

Microbac Laboratories, Inc., New York Division  
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Shannon Weeks  
Customer Relationship Coordinator  
Reported: 07/31/2021 09:30

3821 Buck Drive  
Cortland NY 13045  
Phone: (607) 753-3403 Fax: (607) 753-3415  
NY #10795, EPA #NY00935

**Microbac Laboratories, Inc.**  
**CHAIN OF CUSTODY**

Samples must be returned on ice  
MNY Workorder #

*Steele*

**Client Information**  
Name: Jeff Lew Boces  
Address: 20104 NYS Route 3  
Contact: Health/Safety Dept.  
Phone: 315-779-7000  
Project: Lead Testing  
Quote ID: PO#  
Rush TAT Bus. Days: 2-5 3-7 7-10  
Carbon Copy: Yes  
Email Results: Yes  
Fax Results: Yes

**Billing/Invoice**

**Receiving Info (Lab Use Only)**  
Ice: YES NO  
Cooler: YES NO  
Sample Temp: YES NO  
Cooler Seal: YES NO  
Pickup: YES NO  
Dropoff: C W  
Accepted? YES NO

Number	Description/Location	Sample Information		Matrix		Number of Containers for Analysis Requested	Comments/Field Data
		Date	Time	Type			
1	27	6/31/21	746	DW	1		
2	24		745				
3	52		747				
4	42		750				
5	25		745				
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							

J 1 G 0 9 2 5  
Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE  
PM: Shannon Weeks

**Sampled:** [Signature] Date/Time: 6/31/21 7:22 AM  
**Received:** [Signature] Date/Time: 7/2/21 12:15 PM  
**Received:** [Signature] Date/Time: 7/2/21 14:40

ES. Turner  
D. Walker

Microbac Laboratories (MNY) will be held responsible for the analysis of any samples submitted for analysis to Microbac Laboratories (MNY) unless the analysis is requested for use in a legal proceeding.