



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0924

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Knickerbocker

Fred Hauck  
20104 NYS Route 3  
Watertown, NY 13601

Project / PO Number: N/A  
Received: 07/02/2021  
Reported: 07/31/2021

Analytical Testing Parameters

Client Sample ID:	68	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	06/25/2021 6:57
Lab Sample ID:	J1G0924-01		

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.111	0.015 AL	0.00100	mg/L			07/29/21 1514	RPL

Client Sample ID:	56	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	06/25/2021 7:05
Lab Sample ID:	J1G0924-02		

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0624	0.015 AL	0.00100	mg/L			07/29/21 1515	RPL

Client Sample ID:	64	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	06/25/2021 6:55
Lab Sample ID:	J1G0924-03		

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00231	0.015 AL	0.00100	mg/L			07/29/21 1516	RPL

Client Sample ID:	78	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	06/25/2021 7:00
Lab Sample ID:	J1G0924-04		

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0666	0.015 AL	0.00100	mg/L			07/29/21 1517	RPL



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0924

Client Sample ID: 53	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 06/25/2021 6:59
Lab Sample ID: J1G0924-05	

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0511	0.015 AL	0.00100	mg/L			07/29/21 1518	RPL

Client Sample ID: 62	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 06/25/2021 6:58
Lab Sample ID: J1G0924-06	

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0195	0.015 AL	0.00100	mg/L			07/29/21 1519	RPL

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Chicagoland 12006	New York State Department of Health (m)
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Shannon Weeks  
Customer Relationship Coordinator  
Reported: 07/31/2021 09:30

3821 Buck Drive  
 Cortland NY 13045  
 Phone: (607) 753-3403 Fax: (607) 753-3415  
 NY #10795, EPA #NY00835

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned on ice  
 MNY Workorder #

*Kaicker Boeker*

Client Information		Billing/Invoicing		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Boces					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Health/Safety Dept.					Sample Temp:	YES NO
Phone:	315-779-7000					Cooler Seal:	YES NO
Project:						Pickup:	YES NO
Quote ID:	Lead Testing	PO#:				Dropoff:	C W
Rush TAT Bus. Days:	2-5 3-7 7-10	Date Req.:				Accepted?	YES NO
Carbon Copy:	Yes					Container Material	
Email Results:	Yes					Container Size (in MI)	
Fax Results:	Yes					Preservative	

Sample #	Sample Information		Date	Time	Matrix Type	Number of Containers for Analysis Requested	Comments/Field Data
	Description/Location						
1			6/5/21	6:57	DW	1	
2	<del>78</del> 56			7:05			
3	<del>78</del> 56			6:55			
4	78			7:00			
5	<del>78</del> 53			6:59			
6	<del>78</del> 53			6:58			
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							

J 1 G 0 9 2 4  
 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE  
 PM: Shannon Weeks

Sample:	<i>[Signature]</i>	Date/Time:	6/25/21 12:36	Comments:	
Received:	<i>[Signature]</i>	Date/Time:	7-2-2021 19:10	Comments:	
Received:	<i>[Signature]</i>	Date/Time:	7/2/21 14:40	Comments:	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing by which case we will still complete the analysis in our reference laboratory.