



2501 Mayes Road, Ste 100
 Carrollton, TX 75006
 (800) 324-5928
 www.DrHomeAir.com

Laboratory Certification Info
 NRPP ID#: 101132 AL
 STATE ID#: N/A
 NJ MEB#: MEB 90095

Client: TerraFirma Foundation
 Systems
 Roseburg Public Schools
 Facilities Dept.
 1419 Nw Valley View Dr.

RADON RESULTS SUMMARY

Detailed individual reports available online at DrHomeAir.com/Results
 Short Term (Activated Charcoal)
 EPA-402-R-92-004

Project: Roseburg Public Schools
 - Hucrest

Date Received: 2/11/2020

Kit Serial	Lab ID	Test Address	Test Location/Floor	Structure/Reason	Closed?	Test Start	Test Stop	Result
1)	AE854542	2104469 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Principal Office Not Provided	Other Personal Knowledge	Yes	6:45 AM 2/5/2020	7:18 AM 2/7/2020	<0.6 pCi/L *
2)	AE854550	2104446 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Front Office Not Provided	Other Personal Knowledge	Yes	6:49 AM 2/5/2020	7:19 AM 2/7/2020	<0.7 pCi/L *
3)	AE854534	2104458 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 1 Not Provided	Other Personal Knowledge	Yes	6:53 AM 2/5/2020	7:21 AM 2/7/2020	<0.5 pCi/L *
4)	AE854518	2104471 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 2 Not Provided	Other Personal Knowledge	Yes	6:54 AM 2/5/2020	7:23 AM 2/7/2020	<0.8 pCi/L *
5)	AE854558	2104455 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 3 Not Provided	Other Personal Knowledge	Yes	6:56 AM 2/5/2020	7:25 AM 2/7/2020	<0.5 pCi/L *
6)	AE854551	2104480 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 4 Not Provided	Other Personal Knowledge	Yes	6:58 AM 2/5/2020	7:25 AM 2/7/2020	<0.7 pCi/L *
7)	AE854526	2104454 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 5 Not Provided	Other Personal Knowledge	Yes	7:00 AM 2/5/2020	7:26 AM 2/7/2020	<0.4 pCi/L *
8)	AE854536	2104474 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 6 Not Provided	Other Personal Knowledge	Yes	7:02 AM 2/5/2020	7:27 AM 2/7/2020	<0.6 pCi/L *

QA/QC - Short Term Radon Tests have an estimated accuracy of ±5% when used according to directions.

*The measured radon level was lower than the detector's Lower Limit of Detection. Visit DrHomeAir.com/LLD for info

DISCLAIMER: Test results are only indicative of the sample as received by the lab. Incorrect information or improper procedures will affect results. Alpha Energy Laboratories did not provide sampling services unless otherwise indicated. This measurement is not necessarily predictive or supportive of measurements conducted at different times or different locations. Alpha Energy Laboratories is not responsible for the consequences of any action you do or do not take based on the test results. One sampler can test up to 2,000 square feet.

CONFIDENTIALITY: This report is confidential. If you receive the report in error, please inform the lab and destroy all copies.



2501 Mayes Road, Ste 100
 Carrollton, TX 75006
 (800) 324-5928
 www.DrHomeAir.com

Laboratory Certification Info
 NRPP ID#: 101132 AL
 STATE ID#: N/A
 NJ MEB#: MEB 90095

Client: TerraFirma Foundation
 Systems
 Roseburg Public Schools
 Facilities Dept.
 1419 Nw Valley View Dr.

RADON RESULTS SUMMARY

Detailed individual reports available online at DrHomeAir.com/Results
 Short Term (Activated Charcoal)
 EPA-402-R-92-004

Project: Roseburg Public Schools
 - Hucrest

Date Received: 2/11/2020

Kit Serial	Lab ID	Test Address	Test Location/Floor	Structure/Reason	Closed?	Test Start	Test Stop	Result
9)	AE854537	2104442 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Music Room Not Provided	Other Personal Knowledge	Yes	7:04 AM 2/5/2020	7:29 AM 2/7/2020	<0.6 pCi/L *
10)	AE854545	2104472 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 12 Not Provided	Other Personal Knowledge	Yes	7:07 AM 2/5/2020	7:30 AM 2/7/2020	<0.6 pCi/L *
11)	AE854559	2104470 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 12 - Not Provided	Other Personal Knowledge	Yes	7:09 AM 2/5/2020	7:30 AM 2/7/2020	<0.7 pCi/L *
12)	AE854552	2104463 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 11 Not Provided	Other Personal Knowledge	Yes	7:10 AM 2/5/2020	7:31 AM 2/7/2020	<0.5 pCi/L *
13)	AE854543	2104476 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 10 Not Provided	Other Personal Knowledge	Yes	7:12 AM 2/5/2020	7:32 AM 2/7/2020	<0.7 pCi/L *
14)	AE854519	2104475 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 9 Not Provided	Other Personal Knowledge	Yes	7:14 AM 2/5/2020	7:33 AM 2/7/2020	<1.0 pCi/L *
15)	AE854535	2104467 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 8 Not Provided	Other Personal Knowledge	Yes	7:16 AM 2/5/2020	7:34 AM 2/7/2020	<0.6 pCi/L *
16)	AE854560	2104468 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 7 Not Provided	Other Personal Knowledge	Yes	7:18 AM 2/5/2020	7:35 AM 2/7/2020	<0.7 pCi/L *

QA/QC - Short Term Radon Tests have an estimated accuracy of ±5% when used according to directions.

*The measured radon level was lower than the detector's Lower Limit of Detection. Visit DrHomeAir.com/LLD for info

DISCLAIMER: Test results are only indicative of the sample as received by the lab. Incorrect information or improper procedures will affect results. Alpha Energy Laboratories did not provide sampling services unless otherwise indicated. This measurement is not necessarily predictive or supportive of measurements conducted at different times or different locations. Alpha Energy Laboratories is not responsible for the consequences of any action you do or do not take based on the test results. One sampler can test up to 2,000 square feet.

CONFIDENTIALITY: This report is confidential. If you receive the report in error, please inform the lab and destroy all copies.



2501 Mayes Road, Ste 100
 Carrollton, TX 75006
 (800) 324-5928
 www.DrHomeAir.com

Laboratory Certification Info
 NRPP ID#: 101132 AL
 STATE ID#: N/A
 NJ MEB#: MEB 90095

Client: TerraFirma Foundation
 Systems
 Roseburg Public Schools
 Facilities Dept.
 1419 Nw Valley View Dr.

RADON RESULTS SUMMARY

Detailed individual reports available online at DrHomeAir.com/Results
 Short Term (Activated Charcoal)
 EPA-402-R-92-004

Project: Roseburg Public Schools
 - Hucrest

Date Received: 2/11/2020

Kit Serial	Lab ID	Test Address	Test Location/Floor	Structure/Reason	Closed?	Test Start	Test Stop	Result
17)	AE854527	2104445 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Blank Test Not Provided	Other Personal Knowledge	Not Provided		7:35 AM	Error pCi/L
18)	AE854513	2104473 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Cafeteria/multitpurp Not Provided	Other Personal Knowledge	Yes	7:22 AM 2/5/2020	7:38 AM 2/7/2020	<0.5 pCi/L *
19)	AE854502	2104460 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Cafeteria/multitpurp Not Provided	Other Personal Knowledge	Yes	7:22 AM 2/5/2020	7:37 AM 2/7/2020	<0.6 pCi/L *
20)	AE854510	2104456 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Teachers Lounge Not Provided	Other Personal Knowledge	Yes	7:25 AM 2/5/2020	7:40 AM 2/7/2020	<0.8 pCi/L *
21)	AE854512	2104478 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Mrs. Hull Not Provided	Other Personal Knowledge	Yes	7:27 AM 2/5/2020	7:42 AM 2/7/2020	<0.5 pCi/L *
22)	AE854511	2104452 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Mrs. Kirk Not Provided	Other Personal Knowledge	Yes	7:30 AM 2/5/2020	7:44 AM 2/7/2020	<0.6 pCi/L *
23)	AE854503	2104457 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Mrs. Kirk Not Provided	Other Personal Knowledge	Yes	7:31 AM 2/5/2020	7:44 AM 2/7/2020	<0.6 pCi/L *
24)	AE854485	2104461 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Work Room Not Provided	Other Personal Knowledge	Yes	7:32 AM 2/5/2020	7:44 AM 2/7/2020	<0.8 pCi/L *

QA/QC - Short Term Radon Tests have an estimated accuracy of ±5% when used according to directions.

*The measured radon level was lower than the detector's Lower Limit of Detection. Visit DrHomeAir.com/LLD for info

DISCLAIMER: Test results are only indicative of the sample as received by the lab. Incorrect information or improper procedures will affect results. Alpha Energy Laboratories did not provide sampling services unless otherwise indicated. This measurement is not necessarily predictive or supportive of measurements conducted at different times or different locations. Alpha Energy Laboratories is not responsible for the consequences of any action you do or do not take based on the test results. One sampler can test up to 2,000 square feet.

CONFIDENTIALITY: This report is confidential. If you receive the report in error, please inform the lab and destroy all copies.



2501 Mayes Road, Ste 100
 Carrollton, TX 75006
 (800) 324-5928
 www.DrHomeAir.com

Laboratory Certification Info
 NRPP ID#: 101132 AL
 STATE ID#: N/A
 NJ MEB#: MEB 90095

Client: TerraFirma Foundation
 Systems
 Roseburg Public Schools
 Facilities Dept.
 1419 Nw Valley View Dr.

RADON RESULTS SUMMARY

Detailed individual reports available online at DrHomeAir.com/Results
 Short Term (Activated Charcoal)
 EPA-402-R-92-004

Project: Roseburg Public Schools
 - Hucrest

Date Received: 2/11/2020

Kit Serial	Lab ID	Test Address	Test Location/Floor	Structure/Reason	Closed?	Test Start	Test Stop	Result
25)	AE854498	2104444 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Library Not Provided	Other Personal Knowledge	Yes	7:37 AM 2/5/2020	7:48 AM 2/7/2020	<0.6 pCi/L *
26)	AE854486	2104465 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Library Not Provided	Other Personal Knowledge	Yes	7:38 AM 2/5/2020	7:46 AM 2/7/2020	<0.9 pCi/L *
27)	AE854494	2104450 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Van Burger Office Not Provided	Other Personal Knowledge	Yes	7:40 AM 2/5/2020	7:50 AM 2/7/2020	<0.7 pCi/L *
28)	AE854556	2104479 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Gymnasium Not Provided	Other Personal Knowledge	Yes	7:45 AM 2/5/2020	7:52 AM 2/7/2020	<0.8 pCi/L *
29)	AE854531	2104453 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Gymnasium Not Provided	Other Personal Knowledge	Yes	7:46 AM 2/5/2020	7:53 AM 2/7/2020	<0.6 pCi/L *
30)	AE854524	2104462 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Smith Office Not Provided	Other Personal Knowledge	Yes	7:48 AM 2/5/2020	7:54 AM 2/7/2020	<0.5 pCi/L *
31)	AE854515	2104441 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 14 Not Provided	Other Personal Knowledge	Yes	7:50 AM 2/5/2020	7:58 AM 2/7/2020	<0.8 pCi/L *
32)	AE854507	2104448 Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 16 Not Provided	Other Personal Knowledge	Yes	7:50 AM 2/5/2020	8:01 AM 2/7/2020	<0.5 pCi/L *

QA/QC - Short Term Radon Tests have an estimated accuracy of ±5% when used according to directions.

*The measured radon level was lower than the detector's Lower Limit of Detection. Visit DrHomeAir.com/LLD for info

DISCLAIMER: Test results are only indicative of the sample as received by the lab. Incorrect information or improper procedures will affect results. Alpha Energy Laboratories did not provide sampling services unless otherwise indicated. This measurement is not necessarily predictive or supportive of measurements conducted at different times or different locations. Alpha Energy Laboratories is not responsible for the consequences of any action you do or do not take based on the test results. One sampler can test up to 2,000 square feet.
 CONFIDENTIALITY: This report is confidential. If you receive the report in error, please inform the lab and destroy all copies.



2501 Mayes Road, Ste 100
 Carrollton, TX 75006
 (800) 324-5928
 www.DrHomeAir.com

Laboratory Certification Info

NRPP ID#: 101132 AL
 STATE ID#: N/A
 NJ MEB#: MEB 90095

Client: TerraFirma Foundation
 Systems
 Roseburg Public Schools
 Facilities Dept.
 1419 Nw Valley View Dr.

RADON RESULTS SUMMARY

Detailed individual reports available online at DrHomeAir.com/Results
 Short Term (Activated Charcoal)
 EPA-402-R-92-004

Project: Roseburg Public Schools
 - Hucrest

Date Received: 2/11/2020

Kit Serial	Lab ID	Test Address	Test Location/Floor	Structure/Reason	Closed?	Test Start	Test Stop	Result
33)	AE854529	2104439	Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 17 Not Provided	Other Personal Knowledge	Yes 2/5/2020	8:06 AM 2/7/2020	<0.6 pCi/L *
34)	AE854530	2104438	Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 17 Duplicate Not Provided	Other Personal Knowledge	Yes 2/5/2020	8:06 AM 2/7/2020	<0.7 pCi/L *
35)	AE854549	2104449	Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 18 Not Provided	Other Personal Knowledge	Yes 2/5/2020	8:06 AM 2/7/2020	<0.7 pCi/L *
36)	AE854565	2104464	Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 20 Not Provided	Other Personal Knowledge	Yes 2/5/2020	8:10 AM 2/7/2020	<0.9 pCi/L *
37)	AE854573	2104459	Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 19 Not Provided	Other Personal Knowledge	Yes 2/5/2020	8:10 AM 2/7/2020	<0.5 pCi/L *
38)	AE854547	2104451	Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 40 Not Provided	Other Personal Knowledge	Yes 2/5/2020	8:14 AM 2/7/2020	<0.5 pCi/L *
39)	AE854561	2104440	Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Computer Not Provided	Other Personal Knowledge	Yes 2/5/2020	8:18 AM 2/7/2020	<0.7 pCi/L *
40)	AE854584	2104447	Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Blank Test Not Provided	Other Personal Knowledge	Not Provided		Error pCi/L

QA/QC - Short Term Radon Tests have an estimated accuracy of ±5% when used according to directions.

*The measured radon level was lower than the detector's Lower Limit of Detection. Visit DrHomeAir.com/LLD for info

DISCLAIMER: Test results are only indicative of the sample as received by the lab. Incorrect information or improper procedures will affect results. Alpha Energy Laboratories did not provide sampling services unless otherwise indicated. This measurement is not necessarily predictive or supportive of measurements conducted at different times or different locations. Alpha Energy Laboratories is not responsible for the consequences of any action you do or do not take based on the test results. One sampler can test up to 2,000 square feet.

CONFIDENTIALITY: This report is confidential. If you receive the report in error, please inform the lab and destroy all copies.



2501 Mayes Road, Ste 100
 Carrollton, TX 75006
 (800) 324-5928
 www.DrHomeAir.com

Laboratory Certification Info
 NRPP ID#: 101132 AL
 STATE ID#: N/A
 NJ MEB#: MEB 90095

Client: TerraFirma Foundation
 Systems
 Roseburg Public Schools
 Facilities Dept.
 1419 Nw Valley View Dr.

RADON RESULTS SUMMARY

Detailed individual reports available online at DrHomeAir.com/Results
 Short Term (Activated Charcoal)
 EPA-402-R-92-004

Project: Roseburg Public Schools
 - Hucrest

Date Received: 2/11/2020

Kit Serial	Lab ID	Test Address	Test Location/Floor	Structure/Reason	Closed?	Test Start	Test Stop	Result
41) AE854539	2104443	Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 15 Not Provided	Other Personal Knowledge	Yes	8:07 AM 2/5/2020	8:20 AM 2/7/2020	<0.5 pCi/L *
42) AE854568	2104466	Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Room 13 Not Provided	Other Personal Knowledge	Yes	8:09 AM 2/5/2020	8:22 AM 2/7/2020	<0.5 pCi/L *
43) AE854557	2104477	Hucrest Elementary School 1810 Nw Kline St. Roseburg, OR 97471 USA	Copy Room Not Provided	Other Personal Knowledge	Yes	8:11 AM 2/5/2020	8:23 AM 2/7/2020	<0.5 pCi/L *

QA/QC - Short Term Radon Tests have an estimated accuracy of ±5% when used according to directions.

*The measured radon level was lower than the detector's Lower Limit of Detection. Visit DrHomeAir.com/LLD for info

DISCLAIMER: Test results are only indicative of the sample as received by the lab. Incorrect information or improper procedures will affect results. Alpha Energy Laboratories did not provide sampling services unless otherwise indicated. This measurement is not necessarily predictive or supportive of measurements conducted at different times or different locations. Alpha Energy Laboratories is not responsible for the consequences of any action you do or do not take based on the test results. One sampler can test up to 2,000 square feet.

CONFIDENTIALITY: This report is confidential. If you receive the report in error, please inform the lab and destroy all copies.

Measurement Specialist / Laboratory Director *[Signature]* NJ MES: 11306 Date 2/13/2020