



2501 Mayes Road, Ste 100
 Carrollton, TX 75006
 (800) 324-5928
 www.DrHomeAir.com

Laboratory Certification Info

NRPP ID#: 101132 AL
 STATE ID#: N/A
 NJ MEB#: MEB 90095

Client: TerraFirma Foundation
 Systems
 Roseburg Public Schools
 Facilities Dept.
 1419 Nw Valley View Dr.

RADON RESULTS SUMMARY

Detailed individual reports available online at DrHomeAir.com/Results
 Short Term (Activated Charcoal)
 EPA-402-R-92-004

Project: Roseburg Public Schools
 - Fullerton Iv

Date Received: 2/11/2020

Kit Serial	Lab ID	Test Address	Test Location/Floor	Structure/Reason	Closed?	Test Start	Test Stop	Result
1)	AE854021	2104375	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Workroom Not Provided Personal Knowledge	Other No	9:41 AM 2/5/2020	9:52 AM 2/7/2020	<0.5 pCi/L *
2)	AE854015	2104376	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Custodial Office Not Provided Personal Knowledge	Other Yes	9:43 AM 2/5/2020	9:54 AM 2/7/2020	<0.7 pCi/L *
3)	AE854007	2104377	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Gymnasium Not Provided Personal Knowledge	Other Yes	9:45 AM 2/5/2020	9:55 AM 2/7/2020	<0.6 pCi/L *
4)	AE854013	2104371	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Gymnasium Not Provided Personal Knowledge	Other Yes	9:46 AM 2/5/2020	9:56 AM 2/7/2020	<0.5 pCi/L *
5)	AE853997	2104372	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Office Not Provided Personal Knowledge	Other Yes	9:49 AM 2/5/2020	9:58 AM 2/7/2020	<1.0 pCi/L *
6)	AE854006	2104373	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Principals Office Not Provided Personal Knowledge	Other Yes	9:52 AM 2/5/2020	9:59 AM 2/7/2020	<1.0 pCi/L *
7)	AE854034	2104403	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Logerstedt Not Provided Personal Knowledge	Other Yes	9:54 AM 2/5/2020	10:00 AM 2/7/2020	<0.9 pCi/L *
8)	AE853990	2104391	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Staff Room Not Provided Personal Knowledge	Other Yes	9:55 AM 2/5/2020	10:01 AM 2/7/2020	<0.6 pCi/L *

QA/QC - Short Term Radon Tests have an estimated accuracy of ±5% when used according to directions.

*The measured radon level was lower than the detector's Lower Limit of Detection. Visit DrHomeAir.com/LLD for info

DISCLAIMER: Test results are only indicative of the sample as received by the lab. Incorrect information or improper procedures will affect results. Alpha Energy Laboratories did not provide sampling services unless otherwise indicated. This measurement is not necessarily predictive or supportive of measurements conducted at different times or different locations. Alpha Energy Laboratories is not responsible for the consequences of any action you do or do not take based on the test results. One sampler can test up to 2,000 square feet.

CONFIDENTIALITY: This report is confidential. If you receive the report in error, please inform the lab and destroy all copies.



2501 Mayes Road, Ste 100
 Carrollton, TX 75006
 (800) 324-5928
 www.DrHomeAir.com

Laboratory Certification Info
 NRPP ID#: 101132 AL
 STATE ID#: N/A
 NJ MEB#: MEB 90095

Client: TerraFirma Foundation
 Systems
 Roseburg Public Schools
 Facilities Dept.
 1419 Nw Valley View Dr.

RADON RESULTS SUMMARY

Detailed individual reports available online at DrHomeAir.com/Results
 Short Term (Activated Charcoal)
 EPA-402-R-92-004

Project: Roseburg Public Schools
 - Fullerton Iv

Date Received: 2/11/2020

Kit Serial	Lab ID	Test Address	Test Location/Floor	Structure/Reason	Closed?	Test Start	Test Stop	Result
9)	AE854014	2104382 Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 1 Not Provided	Other Personal Knowledge	Yes	9:57 AM 2/5/2020	10:04 AM 2/7/2020	<0.6 pCi/L *
10)	AE853988	2104390 Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 2 Not Provided	Other Personal Knowledge	Yes	9:58 AM 2/5/2020	10:06 AM 2/7/2020	<0.6 pCi/L *
11)	AE853980	2104397 Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 2 Not Provided	Other Personal Knowledge	Yes	9:59 AM 2/5/2020	10:06 AM 2/7/2020	<0.4 pCi/L *
12)	AE854022	2104384 Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 3 Not Provided	Other Personal Knowledge	Yes	10:02 AM 2/5/2020	10:08 AM 2/7/2020	<0.7 pCi/L *
13)	AE854038	2104364 Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 4 Not Provided	Other Personal Knowledge	Yes	10:04 AM 2/5/2020	10:09 AM 2/7/2020	<0.8 pCi/L *
14)	AE853992	2104392 Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 5 Not Provided	Other Personal Knowledge	Yes	10:04 AM 2/5/2020	10:11 AM 2/7/2020	<0.4 pCi/L *
15)	AE854018	2104383 Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 6 Not Provided	Other Personal Knowledge	Yes	10:06 AM 2/5/2020	10:12 AM 2/7/2020	<1.0 pCi/L *
16)	AE854030	2104401 Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 7 Not Provided	Other Personal Knowledge	Yes	10:10 AM 2/5/2020	10:14 AM 2/7/2020	<0.5 pCi/L *

QA/QC - Short Term Radon Tests have an estimated accuracy of ±5% when used according to directions.

*The measured radon level was lower than the detector's Lower Limit of Detection. Visit DrHomeAir.com/LLD for info

DISCLAIMER: Test results are only indicative of the sample as received by the lab. Incorrect information or improper procedures will affect results. Alpha Energy Laboratories did not provide sampling services unless otherwise indicated. This measurement is not necessarily predictive or supportive of measurements conducted at different times or different locations. Alpha Energy Laboratories is not responsible for the consequences of any action you do or do not take based on the test results. One sampler can test up to 2,000 square feet.

CONFIDENTIALITY: This report is confidential. If you receive the report in error, please inform the lab and destroy all copies.



2501 Mayes Road, Ste 100
 Carrollton, TX 75006
 (800) 324-5928
 www.DrHomeAir.com

Laboratory Certification Info
 NRPP ID#: 101132 AL
 STATE ID#: N/A
 NJ MEB#: MEB 90095

Client: TerraFirma Foundation
 Systems
 Roseburg Public Schools
 Facilities Dept.
 1419 Nw Valley View Dr.

RADON RESULTS SUMMARY

Detailed individual reports available online at DrHomeAir.com/Results
 Short Term (Activated Charcoal)
 EPA-402-R-92-004

Project: Roseburg Public Schools
 - Fullerton Iv

Date Received: 2/11/2020

Kit Serial	Lab ID	Test Address	Test Location/Floor	Structure/Reason	Closed?	Test Start	Test Stop	Result
17) AE854010	2104381	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Blank Test Not Provided	Other Personal Knowledge	Not Provided			Error pCi/L
18) AE853998	2104394	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Office Room 7 Not Provided	Other Personal Knowledge	Yes	10:12 AM 2/5/2020	10:16 AM 2/7/2020	<0.8 pCi/L *
19) AE853996	2104393	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Office Room 7.1 Not Provided	Other Personal Knowledge	Yes	10:14 AM 2/5/2020	10:17 AM 2/7/2020	<0.5 pCi/L *
20) AE854000	2104378	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Office Room 7.2 Not Provided	Other Personal Knowledge	Yes	10:16 AM 2/5/2020	10:18 AM 2/7/2020	<0.7 pCi/L *
21) AE854033	2104402	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Library Not Provided	Other Personal Knowledge	Yes	10:18 AM 2/5/2020	10:20 AM 2/7/2020	<0.9 pCi/L *
22) AE854025	2104399	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Library Not Provided	Other Personal Knowledge	Yes	10:18 AM 2/5/2020	10:20 AM 2/7/2020	<0.8 pCi/L *
23) AE854026	2104400	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Library Not Provided	Other Personal Knowledge	Yes	10:19 AM 2/5/2020	10:21 AM 2/7/2020	<0.5 pCi/L *
24) AE854009	2104380	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 8 Not Provided	Other Personal Knowledge	Yes	10:22 AM 2/5/2020	10:23 AM 2/7/2020	<0.6 pCi/L *

QA/QC - Short Term Radon Tests have an estimated accuracy of ±5% when used according to directions.

*The measured radon level was lower than the detector's Lower Limit of Detection. Visit DrHomeAir.com/LLD for info

DISCLAIMER: Test results are only indicative of the sample as received by the lab. Incorrect information or improper procedures will affect results. Alpha Energy Laboratories did not provide sampling services unless otherwise indicated. This measurement is not necessarily predictive or supportive of measurements conducted at different times or different locations. Alpha Energy Laboratories is not responsible for the consequences of any action you do or do not take based on the test results. One sampler can test up to 2,000 square feet.

CONFIDENTIALITY: This report is confidential. If you receive the report in error, please inform the lab and destroy all copies.



2501 Mayes Road, Ste 100
 Carrollton, TX 75006
 (800) 324-5928
 www.DrHomeAir.com

Laboratory Certification Info

NRPP ID#: 101132 AL
 STATE ID#: N/A
 NJ MEB#: MEB 90095

Client: TerraFirma Foundation
 Systems
 Roseburg Public Schools
 Facilities Dept.
 1419 Nw Valley View Dr.

RADON RESULTS SUMMARY

Detailed individual reports available online at DrHomeAir.com/Results
 Short Term (Activated Charcoal)
 EPA-402-R-92-004

Project: Roseburg Public Schools
 - Fullerton Iv

Date Received: 2/11/2020

Kit Serial	Lab ID	Test Address	Test Location/Floor	Structure/Reason	Closed?	Test Start	Test Stop	Result
25) AE854569	2104365	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 9 Not Provided	Other Personal Knowledge	Yes	10:24 AM 2/5/2020	10:25 AM 2/7/2020	<0.6 pCi/L *
26) AE854580	2104369	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 10 Not Provided	Other Personal Knowledge	Yes	10:26 AM 2/5/2020	10:26 AM 2/7/2020	<0.8 pCi/L *
27) AE854002	2104379	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 11 Not Provided	Other Personal Knowledge	Yes	10:28 AM 2/5/2020	10:28 AM 2/7/2020	<0.8 pCi/L *
28) AE854570	2104366	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 12 Not Provided	Other Personal Knowledge	Yes	10:31 AM 2/5/2020	10:37 AM 2/7/2020	<0.5 pCi/L *
29) AE854506	2104395	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 13 Not Provided	Other Personal Knowledge	Yes	10:32 AM 2/5/2020	10:38 AM 2/7/2020	<0.6 pCi/L *
30) AE853989	2104398	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 14 Not Provided	Other Personal Knowledge	Yes	10:34 AM 2/5/2020	10:40 AM 2/7/2020	<0.6 pCi/L *
31) AE854548	2104385	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 15 Not Provided	Other Personal Knowledge	Yes	10:36 AM 2/5/2020	10:41 AM 2/7/2020	<0.4 pCi/L *
32) AE854578	2104368	Fullerton Iv Elementary School 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 16 Not Provided	Other Personal Knowledge	Yes	10:38 AM 2/5/2020	10:43 AM 2/7/2020	<0.6 pCi/L *

QA/QC - Short Term Radon Tests have an estimated accuracy of ±5% when used according to directions.

*The measured radon level was lower than the detector's Lower Limit of Detection. Visit DrHomeAir.com/LLD for info

DISCLAIMER: Test results are only indicative of the sample as received by the lab. Incorrect information or improper procedures will affect results. Alpha Energy Laboratories did not provide sampling services unless otherwise indicated. This measurement is not necessarily predictive or supportive of measurements conducted at different times or different locations. Alpha Energy Laboratories is not responsible for the consequences of any action you do or do not take based on the test results. One sampler can test up to 2,000 square feet.

CONFIDENTIALITY: This report is confidential. If you receive the report in error, please inform the lab and destroy all copies.



2501 Mayes Road, Ste 100
 Carrollton, TX 75006
 (800) 324-5928
 www.DrHomeAir.com

Laboratory Certification Info
 NRPP ID#: 101132 AL
 STATE ID#: N/A
 NJ MEB#: MEB 90095

Client: TerraFirma Foundation
 Systems
 Roseburg Public Schools
 Facilities Dept.
 1419 Nw Valley View Dr.

RADON RESULTS SUMMARY

Detailed individual reports available online at DrHomeAir.com/Results
 Short Term (Activated Charcoal)
 EPA-402-R-92-004

Project: Roseburg Public Schools
 - Fullerton Iv

Date Received: 2/11/2020

Kit Serial	Lab ID	Test Address	Test Location/Floor	Structure/Reason	Closed?	Test Start	Test Stop	Result	
33)	AE854564	2104388	Fullerton Iv Elementary School Room 17 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 17 Not Provided	Other Personal Knowledge	Yes 2/5/2020	10:41 AM 2/7/2020	10:44 AM 2/7/2020	0.8 pCi/L
34)	AE854571	2104367	Fullerton Iv Elementary School Room 17 Duplicate 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 17 Duplicate Not Provided	Other Personal Knowledge	Yes 2/5/2020	10:41 AM 2/7/2020	10:45 AM 2/7/2020	0.6 pCi/L
35)	AE854563	2104387	Fullerton Iv Elementary School Room 18 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 18 Not Provided	Other Personal Knowledge	Yes 2/5/2020	10:42 AM 2/7/2020	10:46 AM 2/7/2020	<0.8 pCi/L *
36)	AE854487	2104396	Fullerton Iv Elementary School Room 19 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 19 Not Provided	Other Personal Knowledge	Yes 2/5/2020	10:45 AM 2/7/2020	10:48 AM 2/7/2020	<0.5 pCi/L *
37)	AE854581	2104370	Fullerton Iv Elementary School Room 20 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 20 Not Provided	Other Personal Knowledge	Yes 2/5/2020	10:48 AM 2/7/2020	10:50 AM 2/7/2020	<0.4 pCi/L *
38)	AE854583	2104374	Fullerton Iv Elementary School Room 21 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 21 Not Provided	Other Personal Knowledge	Yes 2/5/2020	10:50 AM 2/7/2020	10:52 AM 2/7/2020	<0.5 pCi/L *
39)	AE854567	2104389	Fullerton Iv Elementary School Room 22 2560 W Bradford Ct Roseburg, OR 97471 USA	Room 22 Not Provided	Other Personal Knowledge	Yes 2/5/2020	10:51 AM 2/7/2020	10:54 AM 2/7/2020	<0.6 pCi/L *
40)	AE854562	2104386	Fullerton Iv Elementary School Blank Test 2560 W Bradford Ct Roseburg, OR 97471 USA	Blank Test Not Provided	Other Personal Knowledge	Not Provided			Error pCi/L

QA/QC - Short Term Radon Tests have an estimated accuracy of ±5% when used according to directions.

*The measured radon level was lower than the detector's Lower Limit of Detection. Visit DrHomeAir.com/LLD for info

DISCLAIMER: Test results are only indicative of the sample as received by the lab. Incorrect information or improper procedures will affect results. Alpha Energy Laboratories did not provide sampling services unless otherwise indicated. This measurement is not necessarily predictive or supportive of measurements conducted at different times or different locations. Alpha Energy Laboratories is not responsible for the consequences of any action you do or do not take based on the test results. One sampler can test up to 2,000 square feet.
 CONFIDENTIALITY: This report is confidential. If you receive the report in error, please inform the lab and destroy all copies.