



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Parkway School
 Greenwich Public Schools - Cordes George
 290 Greenwich Ave
 Greenwich, CT 06830-6521

Sample ID#: 270698
Sample Type: Drinking Water
Sample Source: PS017
Sampler: PD
PWS ID: CT0570212

Sample Date: 8/10/2021 10:05 AM
Receipt Date: 8/10/2021 3:30 PM
Report Date: 8/12/2021
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	Minimum Detection	Analysis Date	Analyst
Biological						
Coliform Bacteria	absent	none	SM9223B-04	0	8/10/2021 17:10	KH
e Coli Bacteria	absent	none	SM9223B-04	0	8/10/2021 17:10	KH
Inorganic Compounds						
Chlorine, residual	ND	mg/L	SM4500CLG-2	0.05	8/10/2021 15:30	KH

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected * = Above Specified Limit
--

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.