



Charles County Public Schools
P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646
Attention:

Thursday, July 15, 2021
Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 60102.
Samples flushed by Martel on May 18, 2021, sampled by Martel on 5/19/21.
Project Identification: MD HB 270
School: 25 Billingsley Elementary School.

References and Important Notes:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

* Indicates result(s) greater than 5.5 ug/l - regulatory limit for these samples.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.

Project Manager



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time		
60102	000001	BIES-1-NO				05/19/2021 05:40
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 15:46 CSG	
60102	000002	BIES-2-IM				05/19/2021 05:40
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.24	ug/l	EPA .200.8	2	06/17/2021 15:59 CSG	
60102	000003	BIES-3-IM				05/19/2021 05:41
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.08	ug/l	EPA .200.8	2	06/17/2021 16:01 CSG	
60102	000004	BIES-4-TL				05/19/2021 05:41
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:04 CSG	
60102	000005	BIES-5-IM				05/19/2021 05:42
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:07 CSG	
60102	000006	BIES-6-DF				05/19/2021 05:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:09 CSG	
60102	000007	BIES-7-OT				05/19/2021 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	not	working	EPA .200.8	2	/ /	
60102	000008	BIES-8-DF				05/19/2021 05:45
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:12 CSG	



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000009	BIES-9-DF		05/19/2021 05:46	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:15 CSG
60102	000010	BIES-10-OT		05/19/2021 05:46	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:17 CSG
60102	000011	BIES-11-DF		05/19/2021 05:46	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:20 CSG
60102	000012	BIES-12-DF		05/19/2021 05:47	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:30 CSG
60102	000013	BIES-13-OT		05/19/2021 05:47	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:36 CSG
60102	000014	BIES-14-DF		05/19/2021 05:47	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:38 CSG
60102	000015	BIES-15-OT		05/19/2021 05:50	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.67	ug/l	EPA .200.8	2	06/17/2021 16:41 CSG
60102	000016	BIES-16-KS		05/19/2021 05:51	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:44 CSG



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000017	BIES-17-IM		05/19/2021 05:51	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:46 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000018	BIES-18-KS		05/19/2021 05:52	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:49 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000019	BIES-19-KS		05/19/2021 05:52	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:51 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000020	BIES-20-CF		05/19/2021 05:56	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.93	ug/l	EPA .200.8	2	06/17/2021 16:54 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000021	BIES-21-DF		05/19/2021 05:56	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/17/2021 16:57 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000022	BIES-22-CF		05/19/2021 05:57	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.39	ug/l	EPA .200.8	2	07/09/2021 16:01 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000023	BIES-23-DF		05/19/2021 05:57	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.06	ug/l	EPA .200.8	2	07/09/2021 16:19 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000024	BIES-24-SE		05/19/2021 05:58	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 16:21 CSG



MARTEL NO. 60102 000025 BIES-25-IM CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/19/2021 05:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.24	ug/l	EPA .200.8	2	07/09/2021 16:24 CSG

MARTEL NO. 60102 000026 BIES-26-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/19/2021 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 16:27 CSG

MARTEL NO. 60102 000027 BIES-27-OT CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/19/2021 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 16:29 CSG

MARTEL NO. 60102 000028 BIES-28-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/19/2021 06:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 16:32 CSG

MARTEL NO. 60102 000029 BIES-29-OT CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/19/2021 06:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 16:35 CSG

MARTEL NO. 60102 000030 BIES-30-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/19/2021 06:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 16:37 CSG

MARTEL NO. 60102 000031 BIES-31-DF CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/19/2021 06:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 16:40 CSG

MARTEL NO. 60102 000032 BIES-32-OT CLIENT SAMPLE IDENTIFICATION Sample Date/Time 05/19/2021 06:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 16:50 CSG



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000033	BIES-33-DF		05/19/2021 06:06	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 16:56 CSG
60102	000034	BIES-34-OT		05/19/2021 06:06	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 16:58 CSG
60102	000035	BIES-35-DF		05/19/2021 06:06	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 17:01 CSG
60102	000036	BIES-36-SE		05/19/2021 06:08	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 17:04 CSG
60102	000037	BIES-37-SE		05/19/2021 06:08	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 17:06 CSG
60102	000038	BIES-38-CF		05/19/2021 06:09	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 17:09 CSG
60102	000039	BIES-39-DF		05/19/2021 06:09	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 17:11 CSG
60102	000040	BIES-40-CF		05/19/2021 06:10	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.13	ug/l	EPA .200.8	2	07/09/2021 17:14 CSG



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000041	BIES-41-DF		05/19/2021 06:10	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/09/2021 17:17 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000042	BIES-42-CF		05/19/2021 06:11	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/08/2021 13:00 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000043	BIES-43-DF		05/19/2021 06:11	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/08/2021 13:02 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000044	BIES-44-CF		05/19/2021 06:12	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.33	ug/l	EPA .200.8	2	07/15/2021 12:32 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000045	BIES-45-DF		05/19/2021 06:12	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 12:46 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000046	BIES-46-IM		05/19/2021 06:13	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 12:48 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000047	BIES-47-CR		05/19/2021 06:13	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 12:51 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000048	BIES-48-CF		05/19/2021 06:14	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 12:54 CSG



Certificate of Analysis

MARTEL NO. 60102 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000049 BIES-49-DF 05/19/2021 06:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 12:56 CSG

MARTEL NO. 60102 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000050 BIES-50-CF 05/19/2021 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 12:59 CSG

MARTEL NO. 60102 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000051 BIES-51-DF 05/19/2021 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:02 CSG

MARTEL NO. 60102 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000052 BIES-52-DF 05/19/2021 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:04 CSG

MARTEL NO. 60102 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000053 BIES-53-OT 05/19/2021 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:07 CSG

MARTEL NO. 60102 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000054 BIES-54-DF 05/19/2021 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:18 CSG

MARTEL NO. 60102 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000055 BIES-55-OT 05/19/2021 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:23 CSG

MARTEL NO. 60102 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000056 BIES-56-DF 05/19/2021 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:26 CSG



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000057	BIES-57-DF		05/19/2021 06:22	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:29 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000058	BIES-58-OT		05/19/2021 06:22	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:31 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000059	BIES-59-DF		05/19/2021 06:23	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:34 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000060	BIES-60-OT		05/19/2021 06:23	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:37 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000061	BIES-61-DF		05/19/2021 06:23	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:39 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000062	BIES-62-DF		05/19/2021 06:25	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:42 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
60102	000063	BIES-63-OT		05/19/2021 06:25	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/15/2021 13:44 CSG

MARTEL Chain of Custody

60102

Martel Laboratories IDS, Inc. 1025 Cromwell Bridge Road, Baltimore, Maryland 21286 410 825-7790, Fax 410 821-1054, email: martel@martellabs.com

Charles County PS Drinking Water Lead Testing 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

ALL OUTLETS WERE FLUSHED NIGHT BEFORE SAMPLING AS BELOW:

BETWEEN 5:40 ^{Am} ~~PM~~ and 6:25 ^{Am} ~~PM~~
 Sampling Date : 5/19/21 Relinquished By: Chester Cpl
 Received at Martel by Jm Date/Time: 5/19/21 0:00

Martel Lab No: **60102** 25 Billingsley Elementary School 10069 Billingsley Road White Plains, MD 20695 Location ID # (School-ID-Location on

	Outlet Code	Bldg Floor	Description Location	Time	Sampler Inits	Notes
1	NO		D123 Nurse-Sink	5:40	AEC	
2	IM		D123 Nurse-Ice Machine (Fridge)	↓	AEC	
3	IM		D118 Work Room-Ice Machine (Fridge)	5:41	AEC	
4	TL		D116 Staff Lounge-Sink	↓	AEC	
5	IM		D116 Staff Lounge-Ice Machine (Fridge)	5:42	AEC	
6	DF		C110 Gym-Low Water Fountain	5:45	AEC	
7	OT		C110 Gym-Bottle Filler	NOT WORKING	AEC	NOT WORKING
8	DF		C110 Gym-High Water Fountain	↓	AEC	
9	DF		C120 Café-Low Water Fountain	5:46	AEC	
10	OT		C120 Café-Bottle Filler	↓	AEC	
11	DF		C120 Café-High Water Fountain	↓	AEC	
12	DF		C120 Café-Low Water Fountain	5:47	AEC	
13	OT		C120 Café-Bottle Filler	↓	AEC	
14	DF		C120 Café-High Water Fountain	↓	AEC	
15	OT		Kitchen-Pot Filler	5:50	AEC	
16	KS		Kitchen-Sink (2 Compartment)	5:51	AEC	
17	IM		Kitchen-Ice Machine	↓	AEC	
18	KS		Kitchen - Left Fixture on 3 Comp Sink-Sink - Left fixture	5:52	AEC	
19	KS		Kitchen - Right Fixture on 3 Comp Sink-Sink - Right fixture	↓	AEC	
20	CF		C107-Sink	5:56	AEC	
21	DF		C107 -Bubbler	↓	AEC	
22	CF		C108 Music-Sink	5:57	AEC	
23	DF		C108 Music-Bubbler	↓	AEC	
24	SE		B110 Life Skills (Special education)-Sink	5:58	AEC	
25	IM		B110 Life Skills (Special education)-Ice Machine (Fridge)	↓	AEC	
26	DF		2nd Grade Hall-Water Fountain	6:00	AEC	

MARTEL Chain of Custody

60102

27	OT		2nd Grade Hall-Bottle Filler	6:00	AEC
28	DF		Hallway-Low Water Fountain	6:02	AEC
29	OT		Hallway-Bottle Filler	↓	AEC
30	DF		Hallway-High Water Fountain	↓	AEC
31	DF		1st Grade Hall-Water Fountain	6:04	AEC
32	OT		1st Grade Hall-Bottle Filler	↓	AEC
33	DF		Hallway-Low Water Fountain	6:06	AEC
34	OT		Hallway-Bottle Filler	↓	AEC
35	DF		Hallway-High Water Fountain	↓	AEC
36	SE		A115 (Special education)-Sink	6:08	AEC
37	SE		A111 (Special education)-Sink	↓	AEC
38	CF		A110 Pre-K-Sink	6:09	AEC
39	DF		A110 Pre-K-Bubbler	↓	AEC
40	CF		A121 (Special education)-Sink	6:10	AEC
41	DF		A121 (Special education)-Bubbler	↓	AEC
42	CF		A122-Sink	6:11	AEC
43	DF		A122-Bubbler	↓	AEC
44	CF		A123-Sink	6:12	AEC
45	DF		A123-Bubbler	↓	AEC
46	IM		Pre-K Collaborative Area-Ice Machine (Fridge)	6:13	AEC
47	CR		Pre-K Collaborative Area-Sink	↓	AEC
48	CF		A124-Sink	6:14	AEC
49	DF		A124-Bubbler	↓	AEC
50	CF		A125-Sink	6:15	AEC
51	DF		A125-Bubbler	↓	AEC
52	DF		3rd Grade Hall - (2nd Floor)-Water Fountain	6:19	AEC
53	OT		3rd Grade Hall - (2nd Floor)-Bottle Filler	↓	AEC
54	DF		Hallway - (2nd Floor)-Low Water Fountain	6:20	AEC
55	OT		Hallway - (2nd Floor)-Bottle Filler	↓	AEC
56	DF		Hallway - (2nd Floor)-High Water Fountain	↓	AEC
57	DF		4th Grade Hall - (2nd Floor)-Water Fountain	6:22	AEC
58	OT		4th Grade Hall - (2nd Floor)-Bottle Filler	↓	AEC
59	DF		Hallway - (2nd Floor)-Low Water Fountain	6:23	AEC
60	OT		Hallway - (2nd Floor)-Bottle Filler	↓	AEC
61	DF		Hallway - (2nd Floor)-High Water Fountain	↓	AEC
62	DF		5th Grade Hall - (2nd Floor)-Water Fountain	6:25	AEC

MARTEL Chain of Custody

60102

63	OT		5th Grade Hall - (2nd Floor)-Bottle Filler	6:25	AEC	

MARTEL SCHOOL FLUSHING FORM

60102

Martel Laboratories JDS, Inc. 1025 Cromwell Bridge Road, Baltimore, Maryland 21286 410 825-7790, Fax 410 821-1054, email: martel@martellabs.com

Charles County PS Drinking Water Lead Testing Flushing

Flushing by Martel Personnel

BETWEEN 6:00 PM and 7:30 PM

Flushing Date : 5/18/21 Performed by: Amanda Champlin

Martel Lab No: **60102** 25 Billingsley Elementary School 10069 Billingsley Road White Plains, MD 20695 Location ID # (School-ID-Location on

	Outlet Code	Bldg Floor	Description Location	Flushing Notes/comments
1	NO		D123 Nurse-Sink	
2	IM		D123 Nurse-Ice Machine (Fridge)	
3	IM		D118 Work Room-Ice Machine (Fridge)	
4	TL		D116 Staff Lounge-Sink	
5	IM		D116 Staff Lounge-Ice Machine (Fridge)	
6	DF		C110 Gym-Low Water Fountain	
7	OT		C110 Gym-Bottle Filler	NOT WORKING
8	DF		C110 Gym-High Water Fountain	
9	DF		C120 Café-Low Water Fountain	
10	OT		C120 Café-Bottle Filler	
11	DF		C120 Café-High Water Fountain	
12	DF		C120 Café-Low Water Fountain	
13	OT		C120 Café-Bottle Filler	
14	DF		C120 Café-High Water Fountain	
15	OT		Kitchen-Pot Filler	
16	KS		Kitchen-Sink (2 Compartment)	
17	IM		Kitchen-Ice Machine	
18	KS		Kitchen - Left Fixture on 3 Comp Sink-Sink - Left fixture	
19	KS		Kitchen - Right Fixture on 3 Comp Sink-Sink - Right fixture	
20	CF		C107-Sink	
21	DF		C107 -Bubbler	
22	CF		C108 Music-Sink	
23	DF		C108 Music-Bubbler	
24	SE		B110 Life Skills (Special education)-Sink	
25	IM		B110 Life Skills (Special education)-Ice Machine (Fridge)	
26	DF		2nd Grade Hall-Water Fountain	

MARTEL SCHOOL FLUSHING FORM

60102

27	OT		2nd Grade Hall-Bottle Filler		
28	DF		Hallway-Low Water Fountain		
29	OT		Hallway-Bottle Filler		
30	DF		Hallway-High Water Fountain		
31	DF		1st Grade Hall-Water Fountain		
32	OT		1st Grade Hall-Bottle Filler		
33	DF		Hallway-Low Water Fountain		
34	OT		Hallway-Bottle Filler		
35	DF		Hallway-High Water Fountain		
36	SE		A115 (Special education)-Sink		
37	SE		A111 (Special education)-Sink		
38	CF		A110 Pre-K-Sink		
39	DF		A110 Pre-K-Bubbler		
40	CF		A121 (Special education)-Sink		
41	DF		A121 (Special education)-Bubbler		
42	CF		A122-Sink		
43	DF		A122-Bubbler		
44	CF		A123-Sink		
45	DF		A123-Bubbler		
46	IM		Pre-K Collaborative Area-Ice Machine (Fridge)		
47	CR		Pre-K Collaborative Area-Sink		
48	CF		A124-Sink		
49	DF		A124-Bubbler		
50	CF		A125-Sink		
51	DF		A125-Bubbler		
52	DF		3rd Grade Hall - (2nd Floor)-Water Fountain		
53	OT		3rd Grade Hall - (2nd Floor)-Bottle Filler		
54	DF		Hallway - (2nd Floor)-Low Water Fountain		
55	OT		Hallway - (2nd Floor)-Bottle Filler		
56	DF		Hallway - (2nd Floor)-High Water Fountain		
57	DF		4th Grade Hall - (2nd Floor)-Water Fountain		
58	OT		4th Grade Hall - (2nd Floor)-Bottle Filler		
59	DF		Hallway - (2nd Floor)-Low Water Fountain		
60	OT		Hallway - (2nd Floor)-Bottle Filler		
61	DF		Hallway - (2nd Floor)-High Water Fountain		
62	DF		5th Grade Hall - (2nd Floor)-Water Fountain		

MARTEL SCHOOL FLUSHING FORM

60102

63	OT		5th Grade Hall - (2nd Floor)-Bottle Filler			
----	----	--	--	--	--	--