



Charles County Public Schools

P.O. Box 2770
5980 Radio Station Road
La Plate, MD 20646

Saturday, July 20, 2019

**Certificate of Analysis
FINAL**

Attention:

Report for Lab No: 40807.
Samples picked up by Martel on April 3, 2019.
Project Identification: MD HB 270
School: 20 Mary H. Matula Elementary School PSC #08.032.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40807 000001	MMES-1-KS: kitchen 2 comp-sink on left	03/29/2019 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	10.6 ug/l EPA .200.8	2 06/25/2019 22:16 BJ
40807 000002	MMES-2-KS: kitchen 2 comp-sink on right	03/29/2019 05:02
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	7.87 ug/l EPA .200.8	2 06/25/2019 22:28 BJ
40807 000003	MMES-3-KS: kitchen sink-island sink	03/29/2019 05:04
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	8.81 ug/l EPA .200.8	2 06/25/2019 22:31 BJ
40807 000004	MMES-4-KS: kitchen sink-island sink	03/29/2019 05:04
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	3.02 ug/l EPA .200.8	2 06/25/2019 22:33 BJ
40807 000005	MMES-5-KS: kitchen sink-sink	03/29/2019 05:05
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 06/25/2019 22:36 BJ
40807 000006	MMES-6-IM: kitchen sink-ice maker	03/29/2019 05:07
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 06/25/2019 22:38 BJ



MARTEL NO. 40807 000007 CLIENT SAMPLE IDENTIFICATION MMES-7-DF: kitchen -water fountain Sample Date/Time 03/29/2019 05:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 22:40 BJ

MARTEL NO. 40807 000008 CLIENT SAMPLE IDENTIFICATION MMES-8-DF: hallway-water fountain Sample Date/Time 03/29/2019 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2019 15:55 BJ

MARTEL NO. 40807 000009 CLIENT SAMPLE IDENTIFICATION MMES-9-DF: hallway-water fountain Sample Date/Time 03/29/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2019 16:00 BJ

MARTEL NO. 40807 000010 CLIENT SAMPLE IDENTIFICATION MMES-10-CF: Classroom 133-sink Sample Date/Time 03/29/2019 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.55	ug/l	EPA .200.8	2	07/13/2019 16:02 BJ

MARTEL NO. 40807 000011 CLIENT SAMPLE IDENTIFICATION MMES-11-DF: Classroom 133-bubbler Sample Date/Time 03/29/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2019 16:05 BJ

MARTEL NO. 40807 000012 CLIENT SAMPLE IDENTIFICATION MMES-12-CF: Classroom 132-sink Sample Date/Time 03/29/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.71	ug/l	EPA .200.8	2	07/13/2019 16:07 BJ

MARTEL NO. 40807 000013 CLIENT SAMPLE IDENTIFICATION MMES-13-DF: Classroom 132-bubbler Sample Date/Time 03/29/2019 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2019 16:10 BJ

MARTEL NO. 40807 000014 CLIENT SAMPLE IDENTIFICATION MMES-14-CF: Classroom 116-sink Sample Date/Time 03/29/2019 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.07	ug/l	EPA .200.8	2	07/13/2019 16:12 BJ



MARTEL NO. 40807 000015 CLIENT SAMPLE IDENTIFICATION MMES-15-DF: Classroom 116-bubbler Sample Date/Time 03/29/2019 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2019 16:14 BJ

MARTEL NO. 40807 000016 CLIENT SAMPLE IDENTIFICATION MMES-16-CF: Classroom 117-sink Sample Date/Time 03/29/2019 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.41	ug/l	EPA .200.8	2	07/13/2019 16:17 BJ

MARTEL NO. 40807 000017 CLIENT SAMPLE IDENTIFICATION MMES-17-DF: Classroom 117-bubbler Sample Date/Time 03/29/2019 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2019 16:19 BJ

MARTEL NO. 40807 000018 CLIENT SAMPLE IDENTIFICATION MMES-18-CF: Classroom 131-sink Sample Date/Time 03/29/2019 05:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.22	ug/l	EPA .200.8	2	07/18/2019 21:29 BJ

MARTEL NO. 40807 000019 CLIENT SAMPLE IDENTIFICATION MMES-19-DF: Classroom 131-bubbler Sample Date/Time 03/29/2019 05:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 21:41 BJ

MARTEL NO. 40807 000020 CLIENT SAMPLE IDENTIFICATION MMES-20-CF: Classroom 130-sink Sample Date/Time 03/29/2019 05:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.18	ug/l	EPA .200.8	2	07/18/2019 21:43 BJ

MARTEL NO. 40807 000021 CLIENT SAMPLE IDENTIFICATION MMES-21-DF: Classroom 130-bubbler Sample Date/Time 03/29/2019 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 21:46 BJ

MARTEL NO. 40807 000022 CLIENT SAMPLE IDENTIFICATION MMES-22-CF: Classroom 118A-sink Sample Date/Time 03/29/2019 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.69	ug/l	EPA .200.8	2	07/18/2019 21:48 BJ



MARTEL NO. 40807 000023 CLIENT SAMPLE IDENTIFICATION MMES-23-DF: Classroom 118A-bubbler Sample Date/Time 03/29/2019 05:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.17	ug/l	EPA .200.8	2	07/18/2019 21:50 BJ

MARTEL NO. 40807 000024 CLIENT SAMPLE IDENTIFICATION MMES-24-IM: Activity Room 203 ice maker Sample Date/Time 03/29/2019 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 21:53 BJ

MARTEL NO. 40807 000025 CLIENT SAMPLE IDENTIFICATION MMES-25-CR: Classroom 100-sink Sample Date/Time 03/29/2019 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.10	ug/l	EPA .200.8	2	07/18/2019 21:55 BJ

MARTEL NO. 40807 000026 CLIENT SAMPLE IDENTIFICATION MMES-26-CF: Classroom 119-sink Sample Date/Time 03/29/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.96	ug/l	EPA .200.8	2	07/18/2019 21:58 BJ

MARTEL NO. 40807 000027 CLIENT SAMPLE IDENTIFICATION MMES-27-DF: Classroom 119-bubbler Sample Date/Time 03/29/2019 05:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 22:00 BJ

MARTEL NO. 40807 000028 CLIENT SAMPLE IDENTIFICATION MMES-28-CF: Classroom 129-sink Sample Date/Time 03/29/2019 05:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.48	ug/l	EPA .200.8	2	07/18/2019 17:36 BJ

MARTEL NO. 40807 000029 CLIENT SAMPLE IDENTIFICATION MMES-29-DF: Classroom 129-bubbler Sample Date/Time 03/29/2019 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 17:48 BJ

MARTEL NO. 40807 000030 CLIENT SAMPLE IDENTIFICATION MMES-30-CF: Classroom 128-sink Sample Date/Time 03/29/2019 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.08	ug/l	EPA .200.8	2	07/18/2019 17:50 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000031	MMES-31-DF: Classroom 128-bubbler	03/29/2019 05:08			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 17:53 BJ	
40807	000032	MMES-32-CF: Classroom 120-sink	03/29/2019 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	6.13	ug/l	EPA .200.8	2	07/18/2019 17:55 BJ	
40807	000033	MMES-33-DF: Classroom 120-bubbler	03/29/2019 05:12			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	06/25/2019 22:43 BJ	
40807	000034	MMES-34-CF: Classroom 121-sink	03/29/2019 05:14			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	7.41	ug/l	EPA .200.8	2	07/18/2019 17:58 BJ	
40807	000035	MMES-35-DF: Classroom 121-bubbler	03/29/2019 05:16			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.69	ug/l	EPA .200.8	2	07/18/2019 18:00 BJ	
40807	000036	MMES-36-CF: Classroom 127-sink	03/29/2019 05:18			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.94	ug/l	EPA .200.8	2	07/18/2019 18:02 BJ	
40807	000037	MMES-37-DF: Classroom 127-bubbler	03/29/2019 05:19			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 18:05 BJ	
40807	000038	MMES-38-CF: Classroom 126-sink	03/29/2019 05:20			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.30	ug/l	EPA .200.8	2	07/18/2019 18:07 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40807 000039	MMES-39-DF: Classroom 126-bubbler	03/29/2019 05:22			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 18:17 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40807 000040	MMES-40-CF: Classroom 122-sink	03/29/2019 05:24			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.29	ug/l	EPA .200.8	2	07/18/2019 18:22 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40807 000041	MMES-41-DF: Classroom 122-bubbler	03/29/2019 05:26			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.34	ug/l	EPA .200.8	2	07/18/2019 18:24 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40807 000042	MMES-42-CF: Classroom 123-sink	03/29/2019 05:28			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.64	ug/l	EPA .200.8	2	07/18/2019 18:27 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40807 000043	MMES-43-DF: Classroom 123-bubbler	03/29/2019 05:30			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 18:29 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40807 000044	MMES-44-CF: Classroom 125-sink	03/29/2019 05:32			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.07	ug/l	EPA .200.8	2	07/18/2019 18:32 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40807 000045	MMES-45-DF: Classroom 125-bubbler	03/29/2019 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 18:34 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40807 000046	MMES-46-CF: Classroom 124-sink	03/29/2019 05:36			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.84	ug/l	EPA .200.8	2	07/18/2019 18:36 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000047	MMES-47-DF: Classroom 124-bubbler	03/29/2019 05:38			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 18:39 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000048	MMES-48-DF: hallway-water fountain	03/29/2019 05:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 18:41 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000049	MMES-49-CF: Classroom 111-sink	03/29/2019 05:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.56	ug/l	EPA .200.8	2	07/18/2019 18:53 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000050	MMES-50-DF: Classroom 111-bubbler	03/29/2019 05:45			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.80	ug/l	EPA .200.8	2	06/25/2019 22:45 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000051	MMES-51-DF: hallway-water fountain	03/29/2019 05:48			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 19:05 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000052	MMES-52-CF: Classroom 110-sink	03/29/2019 05:48			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	6.50	ug/l	EPA .200.8	2	07/18/2019 19:08 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000053	MMES-53-DF: Classroom 110-bubbler	03/29/2019 05:50			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	4.17	ug/l	EPA .200.8	2	07/18/2019 19:10 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000054	MMES-54-CF: Classroom 109-sink	03/29/2019 05:52			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	4.80	ug/l	EPA .200.8	2	06/25/2019 22:48 BJ	



MARTEL NO. 40807 CLIENT SAMPLE IDENTIFICATION MMES-55-DF: Classroom 109-bubbler Sample Date/Time 03/29/2019 05:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.07	ug/l	EPA .200.8	2	07/18/2019 19:13 BJ

MARTEL NO. 40807 CLIENT SAMPLE IDENTIFICATION MMES-56-CF: Classroom 103-sink Sample Date/Time 03/29/2019 05:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 19:15 BJ

MARTEL NO. 40807 CLIENT SAMPLE IDENTIFICATION MMES-57-DF: Classroom 103-bubbler Sample Date/Time 03/29/2019 05:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 19:17 BJ

MARTEL NO. 40807 CLIENT SAMPLE IDENTIFICATION MMES-58-CF: Classroom 104-sink Sample Date/Time 03/29/2019 05:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.17	ug/l	EPA .200.8	2	07/18/2019 19:20 BJ

MARTEL NO. 40807 CLIENT SAMPLE IDENTIFICATION MMES-59-DF: Classroom 104-bubbler Sample Date/Time 03/29/2019 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 19:22 BJ

MARTEL NO. 40807 CLIENT SAMPLE IDENTIFICATION MMES-60-CF: Classroom 105-sink Sample Date/Time 03/29/2019 06:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.18	ug/l	EPA .200.8	2	07/18/2019 19:25 BJ

MARTEL NO. 40807 CLIENT SAMPLE IDENTIFICATION MMES-61-DF: Classroom 105-bubbler Sample Date/Time 03/29/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 19:34 BJ

MARTEL NO. 40807 CLIENT SAMPLE IDENTIFICATION MMES-62-CF: Classroom 108-sink Sample Date/Time 03/29/2019 05:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.40	ug/l	EPA .200.8	2	07/18/2019 19:39 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000063	MMES-63-DF: Classroom 108-bubbler	03/29/2019 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 19:41 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000064	MMES-64-CF: Classroom 107-sink	03/29/2019 05:04			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	6.36	ug/l	EPA .200.8	2	07/18/2019 19:44 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000065	MMES-65-DF: Classroom 107-bubbler	03/29/2019 05:05			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 19:46 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000066	MMES-66-CF: Classroom 106-sink	03/29/2019 05:06			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.31	ug/l	EPA .200.8	2	07/18/2019 19:49 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000067	MMES-67-DF: Classroom 106-bubbler	03/29/2019 05:08			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 19:51 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000068	MMES-68-CR: 203 activity Room-sink	03/29/2019 05:10			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 19:53 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000069	MMES-69-CF: Classroom 210-sink	03/29/2019 05:12			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 19:56 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000070	MMES-70-DF: Classroom 210-bubbler	03/29/2019 05:14			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 19:58 BJ	



MARTEL NO. 40807 000071 CLIENT SAMPLE IDENTIFICATION MMES-71-CF: Classroom 209-sink Sample Date/Time 03/29/2019 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 20:11 BJ

MARTEL NO. 40807 000072 CLIENT SAMPLE IDENTIFICATION MMES-72-DF: Classroom 209-bubbler Sample Date/Time 03/29/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 20:23 BJ

MARTEL NO. 40807 000073 CLIENT SAMPLE IDENTIFICATION MMES-73-CF: Classroom 204-sink Sample Date/Time 03/29/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 20:25 BJ

MARTEL NO. 40807 000074 CLIENT SAMPLE IDENTIFICATION MMES-74-DF: Classroom 204-bubbler Sample Date/Time 03/29/2019 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 20:27 BJ

MARTEL NO. 40807 000075 CLIENT SAMPLE IDENTIFICATION MMES-75-CF: Classroom 206-sink Sample Date/Time 03/29/2019 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 20:30 BJ

MARTEL NO. 40807 000076 CLIENT SAMPLE IDENTIFICATION MMES-76-DF: Classroom 206-bubbler Sample Date/Time 03/29/2019 05:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 20:32 BJ

MARTEL NO. 40807 000077 CLIENT SAMPLE IDENTIFICATION MMES-77-CF: Classroom 207-sink Sample Date/Time 03/29/2019 05:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 20:35 BJ

MARTEL NO. 40807 000078 CLIENT SAMPLE IDENTIFICATION MMES-78-DF: Classroom 207-bubbler Sample Date/Time 03/29/2019 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 20:37 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000079	MMES-79-CR: Classroom 103-sink	03/29/2019 05:32			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.40	ug/l	EPA .200.8	2	07/18/2019 20:39 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000080	MMES-80-CF: Classroom 102-sink	03/29/2019 05:34			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 20:42 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000081	MMES-81-DF: Classroom 102-bubbler	03/29/2019 05:36			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 20:52 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000082	MMES-82-CF: Classroom 112-sink	03/29/2019 05:38			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	8.59	ug/l	EPA .200.8	2	07/18/2019 20:57 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000083	MMES-83-DF: Classroom 112-bubbler	03/29/2019 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 20:59 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000084	MMES-84-CF: Classroom 101-sink	03/29/2019 05:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 21:02 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000085	MMES-85-DF: Classroom 101-bubbler	03/29/2019 05:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 21:04 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40807	000086	MMES-86-CF: Classroom 100-sink	03/29/2019 05:46			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.38	ug/l	EPA .200.8	2	07/18/2019 21:06 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40807 000087	MMES-87-DF: Classroom 100-bubbler	03/29/2019 05:48			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 21:09 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40807 000088	MMES-88-TL: teacher lounge-sink	03/29/2019 05:50			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 21:11 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40807 000089	MMES-89-TL: teacher lounge-cold water d	03/29/2019 05:54			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 21:14 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40807 000090	MMES-90-TL: teacher lounge-hot water in	03/29/2019 05:58			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/18/2019 21:16 BJ

Notes and references:

40CFR136=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 136, Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager