



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0928

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Starbucks

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 07/02/2021
Reported: 07/31/2021

Analytical Testing Parameters

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 33, Drinking Water, J1G0928-01, RF - Client, 06/25/2021 7:35.

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.0114.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 44, Drinking Water, J1G0928-02, RF - Client, 06/25/2021 7:38.

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.0112.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 41, Drinking Water, J1G0928-03, RF - Client, 06/25/2021 7:38.

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.00827.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 39, Drinking Water, J1G0928-04, RF - Client, 06/25/2021 7:36.

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.0122.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1G0928

Client Sample ID: 25B	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 06/25/2021 7:35
Lab Sample ID: J1G0928-05	

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0233	0.015 AL	0.00100	mg/L			07/29/21 1528	RPL

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Chicagoland 12006	New York State Department of Health (m)
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.**

Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 07/31/2021 07:25

3821 Buck Drive
 Cortland NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

STARBUCK

Client Information		Billing/Invoices		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Boces					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Health/Safety Dept.					Sample Temp:	
Phone:	315-779-7000					Cooler Seal:	YES NO
Project:						Pickup:	YES NO
Quote ID:	Lead Testing	PO#:				Dropoff:	C W
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req-:				Accepted?	YES NO
Carbon Copy:	Yes					Container Material	
Email Results:	Yes					Container Size (in MI)	
Fax Results:	Yes					Preservative	

Sample Information			Number of Containers for Analysis Requested		Comments/Field Data
Description/Location	Date	Time	Matrix	Type	
333	6/15	7:35	DW	1	
444		7:38			
411		7:38			
339		7:36			
25B		7:35			
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

J 1 G 0 9 2 8
 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks

Print Name and Company

Sampled: [Signature] Date/Time: 06/25/10 7:21 AM

Received: [Signature] Date/Time: 7/2/10 7:12 AM

Received: [Signature] Date/Time: 7/2/10 7:12 AM

Comments:

Microbac Laboratories (MNY) may be unable to perform the requested analysis if the samples are not received in a timely manner.