Water Testing Results - Pleasant Hill School District Action Level is 15 parts per billion (ppb)			
Fixture Location / Description	**Fixture ID #**	**Test Date**	**Test Results (ppb)**
PHHS Billie Shack Boy's Restroom East Sink *RETEST*	20810210-002BF	8/19/2021	35.9
PHHS Billie Shack Boy's Restroom West Sink *RETEST*	20810210-003BF	8/19/2021	26.8
PHHS Billie Shack Girl's Restroom East Sink *RETEST*	20810210-004BF	8/19/2021	25.7
PHES Library West Drinking Fountain *RETEST*	20810109-001DW	8/20/2021	16.4
PHHS Baseball Snack Shack Sink *RETEST*	20810213-003KF	8/20/2021	14.4
ND = Not Dectected - Lead level is below the set detection limits of 2 ppb			