Water Testing Results - Pleasant Hill School District Action Level is 15 parts per billion (ppb)			
Fixture Location / Description	**Fixture ID #**	**Test Date**	**Test Results (ppb)**
PHHS Billie Shack Canteen Sink	20810210-001KF	9/8/2021	17.8
PHHS Billie Shack Boys Restroom East Sink *RETEST*	20810210-002BF	9/8/2021	8.07
PHHS Billie Shack Boys Restroom West Sink *RETEST*	20810210-003BF	9/8/2021	24.3
PHHS Billie Shack Girls Restroom East Sink * RETEST*	20810210-004BF	9/8/2021	15.8
ND = Not Dectected - Lead level is below the set detection limits of 2 ppb			