

Cooper Mountain

Fixture Number	Sample Number	Building	Location / Room No.	Fixture Type	Results (ppb)
001	22401160-001KF21A	Main	Kitchen	Steam Kettle	8.79
002	22431160-002DW21A	Main	Gym	Drinking Fountain	4.86
003	22431160-003CF21A	Main	M-110	Classroom Faucet	10.1
004	22431160-004DW21A	Main	M-110	Drinking Fountain	5.08
005	22431160-005CF21A	Main	M-108	Classroom Faucet	4.54
006	22431160-006DW21A	Main	M-108	Drinking Fountain	3.57
007	22431160-007CF21A	Main	M-102	Classroom Faucet	4.02
008	22431160-008DW21A	Main	M-102	Drinking Fountain	4
009	22431160-009CF21A	Main	M-100	Classroom Faucet	6.08
010	22431160-010DW21A	Main	M-100	Drinking Fountain	2.07
011	22431160-011DW21A	Main	M Commons	Drinking Fountain	2.35
012	22431160-012SF21A	Main	Nurse's Office	Staff Faucet	14.5
013	22431160-013SF21A	Main	Office Storage Room	Staff Faucet	20.1
013	22431160-013SF21A	Main	Office Storage Room	Staff Faucet - Follow Up	19.8
014	22431160-014SF21A	Main	Staff Breakroom	Staff Faucet	ND
015	22431160-015CF21A	Main	A-110	Classroom Faucet	0.597
016	22431160-016DW21A	Main	A-110	Drinking Fountain	0.5
017	22431160-017CF21A	Main	A-100	Classroom Faucet	1.39
018	22431160-018DW21A	Main	A-100	Drinking Fountain	7.48
019	22431160-019CF21A	Main	A-108	Classroom Faucet	2.2
020	22431160-020DW21A	Main	A-108	Drinking Fountain	5
021	22431160-021CF21A	Main	A-106	Classroom Faucet	0.882
022	22431160-022DW21A	Main	A-106	Drinking Fountain	2.56
023	22431160-023CF21A	Main	A-104	Classroom Faucet	1.59
024	22431160-024DW21A	Main	A-104	Drinking Fountain	1.27
025	22431160-025CF21A	Main	A-102	Classroom Faucet	1.19
026	22431160-026DW21A	Main	A-102	Drinking Fountain	7.72
027	22431160-027SF21A	Main	A Workroom	Staff Faucet	3.37
028	22431160-028CF21A	Main	Library	Classroom Faucet	0.817
029	22431160-029WB21A	Main	Hall at Library	Water Bottle Fill	0.409
030	22431160-030DW21A	Main	Hall at Library	Drinking Fountain	ND
031	22431160-031CF21A	Main	C-110	Classroom Faucet	2.73
032	22431160-032DW21A	Main	C-110	Drinking Fountain	1.46
033	22431160-033CF21A	Main	C-108	Classroom Faucet	2.78
034	22431160-034DW21A	Main	C-108	Drinking Fountain	1.04
035	22431160-035CF21A	Main	C-106	Classroom Faucet	7.21
036	22431160-036DW21A	Main	C-106	Drinking Fountain	1.28
037	22431160-037CF21A	Main	C-104	Classroom Faucet	6.7
038	22431160-038DW21A	Main	C-104	Drinking Fountain	1.88
039	22431160-039CF21A	Main	C-102	Classroom Faucet	4.9
040	22431160-040DW21A	Main	C-102	Drinking Fountain	1.95
041	22431160-041CF21A	Main	C-100	Classroom Faucet	4.5
042	22431160-042DW21A	Main	C-100	Drinking Fountain	1.97
043	22431160-043CF21A	Main	B-106	Classroom Faucet	0.314
044	22431160-044DW21A	Main	B-106	Drinking Fountain	2.13
045	22431160-045CF21A	Main	B-104	Classroom Faucet	2.99
046	22431160-046DW21A	Main	B-104	Drinking Fountain	2.25
047	22431160-047CF21A	Main	B-102	Classroom Faucet	2.55
048	22431160-048DW21A	Main	B-102	Drinking Fountain	2.06
049	22431160-049CF21A	Main	B-110	Classroom Faucet	1.29

050	22431160-050DW21A	Main	B-110	Drinking Fountain	13.8
051	22431160-051CF21A	Main	B-108	Classroom Faucet	0.582
052	22431160-052DW21A	Main	B-108	Drinking Fountain	3.5
053	22431160-053SF21A	Main	Workroom B	Staff Faucet	4.85
054	22431160-054CF21A	Main	B-100	Classroom Faucet	2.06
055	22431160-055DW21A	Main	B-100	Drinking Fountain	9.87
056	22431160-056CF21A	Main	A-200	Classroom Faucet	1.77
057	22431160-057DW21A	Main	A-200	Drinking Fountain	9.5
058	22431160-058DW21A	Main	Cafeteria	Drinking Fountain	ND
059	22431160 059 KF21A	Main	Kitchen	Kitchen Prep Sink	0.329