

Sept 17, 2021

Dear Chadds Ford Elementary Community,

As a part of Unionville-Chadds Ford School District's effort to provide students and staff with safe and accessible drinking water, 4 water outlets at your school were re-tested for lead on July 15, 2021. This retesting was a followup after preventive measures were taken to correct previous high level results. A trained technician collected samples from water outlets and the samples were sent to an accredited Pennsylvania laboratory for analysis.


Test results showed drinking water at all outlets sampled had lead concentrations below the action limit of 15 ppb (parts per billion). As such no further action is necessary at this time. If there are any further actions taken on our part, more information will be sent to you at that time.

All test results are shown below:

Sample Date	Sample Id	Outlet Description	Lead Result (ppb)	Action Limit (15 ppb)
07-15-2021	859	Kitchen Faucet; Kitchen - Left	4.6	Below
07-15-2021	860	Classroom Faucet; RM E116	12.8	Below
07-15-2021	861	Kitchen Faucet; Kitchen - Left [FLUSH]	< 1	Below
07-15-2021	862	Classroom Faucet; RM E116 [FLUSH]	< 1	Below

If you have any questions about lead in drinking water and impacts to childrens' health visit [www.pennvestleadtestingprogram.com](http://www.pennvestleadtestingprogram.com) or you may contact me at any time at [jwhitesel@ucfsd.net](mailto:jwhitesel@ucfsd.net). Other resources at your disposal are the Department of Health (DOH) Lead Information Line, 1-800-440-LEAD and the Department of Environmental Protection (DEP), Bureau of Safe Drinking Water (BSDW), Resource account, [RA-EPWIINLEAD@pa.gov](mailto:RA-EPWIINLEAD@pa.gov) and phone number: 717-787-9633.

Sincerely,



James Whitesel, Director of Facilities