

59 N Plains Industrial Road
 Wallingford, CT 06492

Wednesday, September 1, 2021

Voice: (203) 284-0555
 Fax: (203) 284-2064
 Email: eml.ct@snet.net

To: Bethany Town Center
 44 Peck Road
 Bethany, CT 06524

Laboratory Report: Water Quality Testing

Lab Sample Number: 210817-BPS-19467

EDI Batch#: 10586

Coll.Date	Collected By	Facility (Water System)	PWS ID#	Sampling Location	WSF ID	Smp Point
8/17/2021	Burke, Andrew	BETHANY TOWN CENTER	CT0080064	KIT TN HALL MAINSINK	00600	KTHMS

Laboratory Results

	Laboratory Result	Rptg Units	Lab Rpt Lvl	MCL	Standard Method Code	Analysis Completion Date
Dist Total Coliform (DSTC)						
1012 CHLORINE RESIDUAL	nd < 0.05	MG/L	MRL		4500CL-F	8/17/2021
3100 DISTRIBUTION COLIFORM TOTAL	A				9223B	8/18/2021
3014 DISTRIBUTION E.COLI	A				9223B	8/18/2021
Dist Physical Parameters (PPS)						
1905 DISTRIBUTION COLOR	3	CU	n/a		110.3	8/17/2021
1920 DISTRIBUTION ODOR	0	TON	n/a		2150B	8/17/2021
1925 DISTRIBUTION PH (S.U.)	6.26	PH	n/a		4500H-B	8/17/2021
0100 DISTRIBUTION TURBIDITY	0.22	NTU	n/a		2130B	8/17/2021