Water Testing Results - Pleasant Hill School District Action Level is 15 parts per billion (ppb)			
Fixture Location / Description	**Fixture ID #**	**Test Date**	**Test Results (ppb)**
PHHS Billie Shack Canteen Sink	20810210-001KF	9/24/2021	ND
PHHS Billie Shack Boys Restroom West Sink	20810210-003BF	9/24/2021	5.09
PHHS Billie Shack Girls Restroom East Sink	20810210-004BF	9/24/2021	2.83
PHHS Main Gym Girls Team Room Drinking Fountain	20810201-009DW	9/24/2021	58.7
PHES Classroom #2 Drinking Fountain	20810100-009DW	9/24/2021	79.2
ND = Not Dectected - Lead level is below the set detection limits of 2 ppb			