



**ROCKFORD BOARD OF EDUCATION
INVITATION FOR BID ON SUPPLIES, MATERIALS, EQUIPMENT OR SERVICES
FOR SCHOOL DISTRICT NO. 205
ROCKFORD, ILLINOIS**

IFB No. 22-14 Page Park & Stiles School Demolition

DATE: October 18, 2021

RE: **ADDENDUM NO. 2**

To All Bidders:

Included are modifications, clarifications and/or corrections for the Project Manual and are hereby made a part of the contract documents. Please attach this addendum to the Project Manual(s) in your possession. Please note the receipt of this addendum on the bid form. Bidders shall review changes to all portions of this work as changes to one portion may affect the work of another.

If you plan to hand deliver your IFB submission on the due date, please note you must check in on the 2nd floor prior to coming to the bid opening. Please allow time for this as late submission will not be accepted.

Refer all questions relative to the business aspect, Instructions to Bidders, Special Conditions, and questions concerning the technical aspect of the documents to the Director of Purchasing by email at purchasingdeptstaff@rps205.com.

ROCKFORD BOARD OF EDUCATION

By: Dane Youngblood
Director of Purchasing

ADDENDUM TWO

RPS205 IFB No. **22-14**

RLJA Project No.: **21-063-64**

Date: **October 18, 2021**

Subject: **CHANGES to the BIDDING DOCUMENTS**

Project: **PAGE PARK & STILES SCHOOL BUILDING DEMOLITION
ROCKFORD, ILLINOIS**

Bids Due: **2:00PM (CST), TUESDAY, OCTOBER 26, 2021**

From: **RICHARD L. JOHNSON ASSOCIATES, INC.
4703 CHARLES STREET
ROCKFORD, IL 61108**

To: **ALL PROJECT DOCUMENT HOLDERS**

Please reproduce this Addendum as needed and attach to the Project Manuals for the above project.

Bidders shall indicate receipt of this and all Addenda in the space provided on the Bid Form. Failure to do so may be sufficient cause to reject the bid.

Sincerely,
RICHARD L. JOHNSON ASSOCIATES, INC.



Richard L. Johnson, Principal

This Addendum consists of:

- a. Addendum #2, Pages 1 - 2

1. CLARIFICATIONS

- 1.1 There is no percentage requirement for MBE/WBE participation.
- 1.2 No testing of paint film for lead on the CMU walls at Page Park or Stiles Schools was conducted.
- 1.3 Performance and Payment Bond shall be included in the Base Bid for each school.
- 1.4 Contractor to remove water well structures. See Demolition Box Note 20 on Drawing Sheet A101.
- 1.5 Contractor to remove septic structures. See Demolition Box Note 21 on Drawing Sheet A101.
- 1.6 The thickness of gravel below pavement and sidewalks is unknown.
- 1.7 Contractor does not need to provide permits.
- 1.8 Silt fencing is required at each site and shown on Drawing Sheets C101 in each set.
- 1.9 Existing base material may be reused as backfill. See Fill/Compaction Detail @ Building, Removal for Paved Areas and Fill-Detail @ Paved Areas on Drawing Sheet A101.
- 1.10 Excavate existing gravel base below building slabs and install inorganic fill. See Fill-Detail @ Paved Areas on Drawing Sheet A101.
- 1.11 General Utility Note regarding Sanitary Sewer should refer to Demolition Box Note 21 and not 23.

END ADDENDUM NUMBER 2