



OCEANSIDE UNION FREE SCHOOL DISTRICT
145 Merle Avenue, Oceanside, New York 11572-2206

Phyllis Harrington, Ed.D

Superintendent of Schools

Ph: 516-678-1215 Fax: 516-678-7503

pharrington@oceansideschools.org

January 2021

Dear Parent or Legal Guardian:

Prior to any mandate, our School District retained the services of an environmental consultant firm to voluntarily perform sampling of all High Priority Water Outlets that are outlets regularly used for drinking or cooking for the presence of lead. Any drinking water outlets that revealed concentrations above the Federal Guideline action level were immediately removed from service and remedial actions were performed. Water outlets returned to service only after resampling results revealed a concentration of lead below the action level. The laboratory report issued by the environmental consultant for this sampling was posted on the District's website.

On September 6, 2016 the New York State Department of Health (NYS DOH) adopted an emergency regulation entitled *Lead Testing in School Drinking Water* (10 NYCRR Subpart 67-4) mandating school districts perform sampling for the presence of lead of all potable water fixtures currently, or potentially used for drinking or cooking purposes in their buildings. The District has regularly tested all potable water sources on a recurring cycle.

Potable water sources that tested with lead levels above the action level were remediated. In cases where a sink is utilized for hand washing, cleaning or instruction only, a sign was posted at the outlet indicating that the sink is not to be used for drinking. In summary, the ***drinking water outlets currently servicing our district meet the federal and state guidelines and regulations.***

The school district has also implemented various other controls and policies to ensure our continued compliance with the new state emergency regulation, including plans to retest the water again in year 2025. Information about the lead testing program, including copies of all available laboratory results, has been available on the District's website (Buildings & Grounds). If additional information is needed, please contact the District's Facilities Office on weekdays between 8:00 AM and 4:00 PM at (516) 594-2333.

Sincerely,

A handwritten signature in black ink that reads "Phyllis S. Harrington".

Phyllis S. Harrington, Ed.D.

Superintendent of Schools



OCEANSIDE UNION FREE SCHOOL DISTRICT
145 Merle Avenue, Oceanside, New York 11572-2206

Phyllis Harrington, Ed.D

Superintendent of Schools

Ph: 516-678-1215 Fax: 516-678-7503

pharrington@oceansideschools.org

Enero de 2021

Estimado padre o tutor legal:

Antes de cualquier mandato, nuestro distrito escolar contrató los servicios de una empresa consultora ambiental para realizar voluntariamente el muestreo de todos los puntos de venta de agua de alta prioridad que se utilizan regularmente para beber o cocinar para detectar la presencia de plomo. Todas las salidas de agua potable que revelaron concentraciones por encima del nivel de acción de las Directrices Federales se retiraron inmediatamente del servicio y se tomaron medidas correctivas. Las salidas de agua volvieron a funcionar solo después de que los resultados del nuevo muestreo revelaron una concentración de plomo por debajo del nivel de acción. El informe de laboratorio emitido por el consultor ambiental para este muestreo se publicó en el sitio web del Distrito.

El 6 de septiembre de 2016, el Departamento de Salud del Estado de Nueva York (NYS DOH) adoptó un reglamento de emergencia titulado *Prueba de plomo en el agua potable de las escuelas* (10 NYCRR Subparte 67-4) que obliga a los distritos escolares a realizar muestreos para detectar la presencia de plomo en todos los accesorios de agua potable. actualmente o potencialmente utilizados para beber o cocinar en sus edificios. El Distrito ha probado regularmente todas las fuentes de agua potable en un ciclo recurrente.

Las fuentes de agua potable que se analizaron con niveles de plomo por encima del nivel de acción fueron remediadas. En los casos en que se utilice un fregadero para lavarse las manos, limpiar o solo para recibir instrucciones, se colocó un letrero en la salida que indica que el fregadero no debe usarse para beber. En resumen, las ***salidas de agua potable que actualmente dan servicio a nuestro distrito cumplen con las pautas y regulaciones federales y estatales.***

El distrito escolar también ha implementado varios otros controles y políticas para garantizar nuestro cumplimiento continuo con la nueva regulación de emergencia estatal, incluidos los planes para volver a analizar el agua en el año 2025. La información sobre el programa de análisis de plomo, incluidas copias de todos los resultados de laboratorio disponibles, ha estado disponible en el sitio web del Distrito (Edificios y Terrenos). Si se necesita información adicional, comuníquese con la Oficina de Instalaciones del Distrito de lunes a viernes entre las 8:00 a. m. Y las 4:00 p.m. Al (516) 594-2333.

Atentamente,

Phyllis S. Harrington, Ed.D.

Superintendente de escuelas

Oceanside Union Free School District

19-43786

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Florence A. Smith School #2							
OUFSD-0033	2021	Room 22	Classroom Faucet	Nonpotable	10/27/2020	25	Placarded for Non-Drinking Use Until Remediated
OUFSD-0010	2005	Room 15	Water Fountain-No Chiller	Potable	10/27/2020	19	Removed From Service, Pending Remediation
OUFSD-0012	2006	Room 27	Water Fountain-No Chiller	Potable	10/27/2020	28	Removed From Service, Pending Remediation
OUFSD-0013	2007	Room 26	Classroom Faucet	Nonpotable	10/27/2020	16	Placarded for Non-Drinking Use Until Remediated
OUFSD-0015	2008A	Room 16A	Classroom Faucet	Nonpotable	10/27/2020	66	Placarded for Non-Drinking Use Until Remediated
OUFSD-0016	2008A	Room 16A	Water Fountain-No Chiller	Potable	10/27/2020	36	Removed From Service, Pending Remediation
OUFSD-0023	2015B	Library Office	Hand Wash Only	Nonpotable	10/27/2020	72	Placarded for Non-Drinking Use Until Remediated
OUFSD-0029	2019	Room 25	Classroom Faucet	Nonpotable	10/27/2020	16	Placarded for Non-Drinking Use Until Remediated
OUFSD-0006	2003	Room 14	Water Fountain-No Chiller	Potable	10/27/2020	17	Removed From Service, Pending Remediation
OUFSD-0032	2020	Room 21	Water Fountain-No Chiller	Potable	10/27/2020	16	Removed From Service, Pending Remediation
OUFSD-0095	1032C	Stage Storage	Hand Wash Only	Nonpotable	10/27/2020	2300	Placarded for Non-Drinking Use Until Remediated
OUFSD-0034	2021	Room 22	Water Fountain-No Chiller	Potable	10/27/2020	18	Removed From Service, Pending Remediation
OUFSD-0038	2023	Room 23	Water Fountain-No Chiller	Potable	10/27/2020	16	Removed From Service, Pending Remediation

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
OUFSD-0063	1009	Room 6	Classroom Faucet	Nonpotable	10/27/2020	19	Placarded for Non-Drinking Use Until Remediated
OUFSD-0064	1009	Room 6	Water Fountain-No Chiller	Potable	10/27/2020	24	Removed From Service, Pending Remediation
OUFSD-0070	1011	Room 4	Water Fountain-No Chiller	Potable	10/27/2020	16	Removed From Service, Pending Remediation
OUFSD-0077	1018	Nurse's Office	Nurse's Office Sink	Nonpotable	10/27/2020	27	Placarded for Non-Drinking Use Until Remediated
OUFSD-0083	1020B	Main Office Break Room	Kitchen Faucet (Cold)	Potable	10/27/2020	18	Removed From Service, Pending Remediation
OUFSD-0085	1019A1	Principal's Office Bathroom	Bathroom Faucet	Nonpotable	10/27/2020	110	Placarded for Non-Drinking Use Until Remediated
OUFSD-0030	2019	Room 25	Water Fountain-No Chiller	Potable	10/27/2020	94	Removed From Service, Pending Remediation

Oceanside Union Free School District

19-43786

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Oaks School #3							
OUFSD-0163	1018	Gym	Water Fountain-No Chiller	Potable	10/28/2020	16	Removed From Service, Pending Remediation

Oceanside Union Free School District

19-43786

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
South Oceanside Road School #4							
OUFSD-0266	1033	Gym	Water Fountain-No Chiller	Potable	10/29/2020	27	Removed From Service, Pending Remediation

Oceanside Union Free School District

19-43786

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
North Oceanside Road School #5							
OUFSD-0345	1025	Room A2	Water Fountain-No Chiller	Potable	10/30/2020	38	Removed From Service, Pending Remediation
OUFSD-0304	2026	Room A7	Water Fountain-No Chiller	Potable	10/30/2020	24	Removed From Service, Pending Remediation

Oceanside Union Free School District

19-43786

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Oceanside School #6 & Administration							
OUFSD-0582	1007	Rotary Club Office (Accessed Through 1006A)	Bathroom Faucet	Nonpotable	11/6/2020	67	Placarded for Non-Drinking Use Until Remediated
OUFSD-0569	0038D	Room B3 Bathroom	Bathroom Faucet	Nonpotable	11/6/2020	26	Placarded for Non-Drinking Use Until Remediated
OUFSD-0477	2061	Unisex Bathroom	Bathroom Faucet	Nonpotable	11/5/2020	42	Placarded for Non-Drinking Use Until Remediated
OUFSD-0452	2054	Corridor Room W23 To W26	Water Fountain-No Chiller	Potable	11/5/2020	16	Removed From Service, Pending Remediation
OUFSD-0451	2043	Room W25 Game Room	Kitchen Faucet (Cold)	Potable	11/5/2020	25	Removed From Service, Pending Remediation
OUFSD-0448	2041	Girl's Bathroom	Bathroom Faucet	Nonpotable	11/5/2020	37	Placarded for Non-Drinking Use Until Remediated
OUFSD-0442	2032	Room 203	Classroom Faucet	Nonpotable	11/5/2020	24	Placarded for Non-Drinking Use Until Remediated
OUFSD-0431	2022	Room 214 Nature Study	Science Faucet	Nonpotable	11/5/2020	27	Placarded for Non-Drinking Use Until Remediated
OUFSD-0399	2005	Room 218	Water Fountain-No Chiller	Potable	11/5/2020	17	Removed From Service, Pending Remediation
OUFSD-0380	3006A	Women's Bathroom	Bathroom Faucet	Nonpotable	11/5/2020	20	Placarded for Non-Drinking Use Until Remediated
OUFSD-0379	3006A	Women's Bathroom	Bathroom Faucet	Nonpotable	11/5/2020	23	Placarded for Non-Drinking Use Until Remediated

Oceanside Union Free School District

19-43786

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Oceanside High School #7							
OUFSD-0931	1138	Men's Bathroom	Bathroom Faucet	Nonpotable	11/7/2020	22	Placarded for Non-Drinking Use Until Remediated
OUFSD-0893	1074B	Room 122 Kiln Room	Classroom Faucet	Nonpotable	11/7/2020	120	Placarded for Non-Drinking Use Until Remediated
OUFSD-0879	1070	Men's Bathroom	Bathroom Faucet	Nonpotable	11/7/2020	16	Placarded for Non-Drinking Use Until Remediated
OUFSD-0878	1070	Men's Bathroom	Bathroom Faucet	Nonpotable	11/7/2020	46	Placarded for Non-Drinking Use Until Remediated
OUFSD-0877	1067C	Room 126A Photo Lab Art Room	Classroom Faucet	Nonpotable	11/7/2020	120	Placarded for Non-Drinking Use Until Remediated
OUFSD-0876	1067C	Room 126A Photo Lab Art Room	Classroom Faucet	Nonpotable	11/7/2020	24	Placarded for Non-Drinking Use Until Remediated
OUFSD-0875	1067C	Room 126A Photo Lab Art Room	Classroom Faucet	Nonpotable	11/7/2020	220	Placarded for Non-Drinking Use Until Remediated
OUFSD-0725	2060	Women's Bathroom	Bathroom Faucet	Nonpotable	11/7/2020	39	Placarded for Non-Drinking Use Until Remediated

Oceanside Union Free School District

19-43786

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Fulton Avenue School #8							
OUFSD-1018	1018	Nurse's Office	Nurse's Office Sink	Nonpotable	10/31/2020	290	Placarded for Non-Drinking Use Until Remediated
OUFSD-1016	1025	Custodial Office	Kitchen Faucet (Cold)	Potable	10/31/2020	20	Removed From Service, Pending Remediation
OUFSD-1010	1027A	Kitchen	Kitchen Service Area	Potable	10/31/2020	21	Removed From Service, Pending Remediation
OUFSD-0982	1056	Room 23	Classroom Faucet	Nonpotable	10/31/2020	16	Placarded for Non-Drinking Use Until Remediated
OUFSD-0971	1060	Room 27	Classroom Faucet	Nonpotable	10/31/2020	22	Placarded for Non-Drinking Use Until Remediated

Oceanside Union Free School District

19-43786

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Oceanside Middle School #9M & Walter S. Boardman Elementary School #9E							
OUFSD-1184	1046	Women's Bathroom	Bathroom Faucet	Nonpotable	11/11/2020	150	Placarded for Non-Drinking Use Until Remediated
OUFSD-1156	1022	Room A107	Home Economics Faucet (Cold)	Potable	11/11/2020	21	Removed From Service, Pending Remediation
OUFSD-1151	1020	Men's Room	Bathroom Faucet	Nonpotable	11/11/2020	70	Placarded for Non-Drinking Use Until Remediated
OUFSD-1071	3006	Boy's Bathroom	Bathroom Faucet	Nonpotable	11/11/2020	23	Placarded for Non-Drinking Use Until Remediated
OUFSD-1070	3006	Boy's Bathroom	Bathroom Faucet	Nonpotable	11/11/2020	17	Placarded for Non-Drinking Use Until Remediated