

General Environmental Laboratories, Inc.

P.O. Box 21866
Hilton Head Island, SC 29925
Phone 843.208.2006
Fax 843.208.2006

121 Mead Road
Suite E
Hardeeville, SC 29927

REPORT OF ANALYSIS

Client: BEAUFORT COUNTY SCHOOLS
ATTN: ED MILLER
2900 MINK PT. BLVD
BEAUFORT, SC 29902

Report Number: 17-0311
Project Name: BEAUFORT COUNTY SCHOOL DISTRICT
Client Project Number: N/A
Sample Matrix: DRINKING WATER
Sampled By: MAT MILBURN (CLIENT)
Report Date: 04-18-2017

SAMPLE IDENTIFICATION	LAB SAMPLE ID	COLLECTION DATE AND TIME	DATE AND TIME RECEIVED
44-02 DF Main Hall Before Rm. 142	17-0311-1	04/06/17 13:04	04/06/17 13:57
44-05 DF In 300 Bldg by 324	17-0311-2	04/06/17 13:15	04/06/17 13:57
44-7 DF 400 Bldg next to 432	17-0311-3	04/06/17 13:18	04/06/17 13:57
44-10 DF 500 Bldg next to 533	17-0311-4	04/06/17 13:21	04/06/17 13:57

Released by: _____



Sheila Patel
Director of Laboratory Operations

S.C. Laboratory Certification: 27553001

Sample Narrative
Report Number: 17-0311
Project Name: BSCD
Client Project Number: N/A

Comments:

All samples were received in good condition within temperature requirements.
All samples were received within sample holding time for analysis.

Qualifier and Qualifier Description

J = Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

G = Analyzed by SC Laboratory Certification: 98001.

General Environmental Laboratories, Inc.

P.O. Box 21866
Hilton Head Island, SC 29925

Phone 843.208.2006
Fax 843.208.2006

121 Mead Road
Suite E
Hardeeville, SC 29927

REPORT OF ANALYSIS

Lab Sample ID: 17-0311-1
Client Sample ID: 44-02 DF Main Hall before Rm. 142
Sample Matrix: Drinking Water

Date/Time Collected: 04/06/2017 13:04
Date/Time Received: 04/06/2017 13:57

Analyte	Result	Unit	Qualifier	RL	MDL	Analyzed	Dil Fac
Lead	0.097	ug/L	J,G	0.30	0.060	04/12/17 17:43	1
Method: 200.8 – Metals (ICP/MS)							

Lab Sample ID: 17-0311-2
Client Sample ID: 44-05 DF In 300 Bldg. by 324
Sample Matrix: Drinking Water

Date/Time Collected: 04/06/2017 13:15
Date/Time Received: 04/06/2017 13:57

Analyte	Result	Unit	Qualifier	RL	MDL	Analyzed	Dil Fac
Lead	0.14	ug/L	J,G	0.30	0.060	04/12/17 17:37	1
Method: 200.8 – Metals (ICP/MS)							

Lab Sample ID: 17-0311-3
Client Sample ID: 44-7 DF 400 Bldg. next to 432
Sample Matrix: Drinking Water

Date/Time Collected: 04/06/2017 13:18
Date/Time Received: 04/06/2017 13:57

Analyte	Result	Unit	Qualifier	RL	MDL	Analyzed	Dil Fac
Lead	1.2	ug/L	G	0.30	0.060	04/12/17 17:46	1
Method: 200.8 – Metals (ICP/MS)							

General Environmental Laboratories, Inc.

P.O. Box 21866
Hilton Head Island, SC 29925
Phone 843.208.2006
Fax 843.208.2006

121 Mead Road
Suite E
Hardeeville, SC 29927

REPORT OF ANALYSIS

Lab Sample ID: 17-0311-4
Client Sample ID: 44-10 DF 500 Bldg. next to 533
Sample Matrix: Drinking Water

Date/Time Collected: 04/06/2017 13:21
Date/Time Received: 04/06/2017 13:57

Analyte	Result	Unit	Qualifier	RL	MDL	Analyzed	Dil Fac
Lead	0.18	ug/L	J,G	0.30	0.060	04/12/17 17:40	1
Method: 200.8 – Metals (ICP/MS)							

General Environmental Laboratories, Inc.

P.O. Box 21866
Hilton Head Island, SC 29925
Phone 843.208.2006 Fax 843.208.2006

121 Mead Road, Suite B
Hardeeville, SC 29927

CHAIN OF CUSTODY RECORD

PAGE OF

Client: BCSD Project No: 17-0311
 Report Address: Invoice Address:
 Attn: ED MILLER Attn:
 Phone No: Sampled by: Matt Milburn
 Fax No: PO No:
 Contact e-mail: Billing e-mail:

Preservation Used: 1 = None-Cool <6°C; 2 = Na₂S₂O₅/Ice; 3 = H₂SO₄; 4 = HCl; 5 = HNO₃; 6 = Other
 Container Type: P = Plastic; G = Glass

COMPLIANCE MONITORING: YES NO
 Regulatory Non-Regulatory
 24 hours 48 Hours
 5 days Routine

Sample ID	Sample Description	Date Sampled	Time Sampled	No. of Containers	Container Type	Grab	PRESERVATIVE					Analysis Required	
							Composite	Wastewater	Groundwater	Drinking Water	Other:		
1	44-02 DF Main hall before rm 442	4/6/17	1:04 pm	1	P	✓					5	LEAD	
2	44-05 DF In 300 Bldg by 324	4/6/17	1:15 pm	1	✓						1		
3	44-7 DF In 400 Bldg - next to 432	4/6/17	1:18 pm	1	✓						1		
4	44-10 DF 500 Bldg next to 533	4/6/17	1:21 pm	1	✓						1		
Composite Start Date/Time: 4/6/17 1:04 Composite End Date/Time: 4/6/17 1:21		Composite Temp °C		1. Received By: <u>Leah Bell</u>		Date: 4/6/17		Time: 13:57		Date: 4/6/17		Time: 13:57	
1. Relinquished By: <u>Matt Miller</u>		2. Received by GELI: <u>Leah Bell</u>		Received on ice (circle): <u>Yes</u> No		Ice Pack		Receipt Temp °C		11.7			
Comments: <u>SMILES FOR NOV-DECEMBER REPORTING BE CURRENT RESEARCH</u>													