		MCRE water sample comps.		
		Test results ug/L		
Location	Device	4/3/2017	4/14/2017	
Outside café	Drinking fountain	0.11	0.11	
Outside café	Supply to fountain		1600	
Inside café	Drinking fountain	0.16	2.1	old
Inside café	Supply to fountain		6.8	
Outside Mail Rm	Drinking fountain	0.45	0.56	new
Outside Mail Rm	Supply to fountain		2.9	
Media Center	Drinking fountain	0.33	0.45	
Media Center	Supply to fountain		34	
D-111	Drinking fountain	0.15	0.14	
D-111	Supply to fountain		0.15	
E Hall	Drinking fountain	0.2	0.14	new
E Hall	Supply to fountain		1.3	
Kitchen	Drinking fountain	0.54	0.54	
Kitchen	Supply to fountain		8.6	
Mail sink	control		0.26	
Boiler room Hose Bib	control		1.7	
				.