

**November 29, 2021**

**SOLICITATION ADDENDUM NO. 1**  
**ITB 21-0010**  
**Greenway Elementary Roof Replacement**

**THE FOLLOWING CHANGES/ADDITIONS TO THE ABOVE CITED SOLICITATION ARE ANNOUNCED:**

This Addendum modifies the Invitation to Bid (ITB) document(s) only to the extent indicated herein. All other areas not changed or otherwise modified by this Addendum shall remain in full force and effect. This Addendum is hereby made an integral part of the ITB document. Bidder must be responsive to any requirements of this Addendum as if the requirements were set forth in the ITB. Failure to do so may result in Bid rejection. See the ITB regarding requests for clarification or change and protests of this Addendum, and the deadlines for the foregoing.

This addendum is to be acknowledged in the space provided on the Bidder Certification form supplied in the solicitation document. Failure to acknowledge receipt of this addendum may be cause to reject your offer.

The closing date **REMAINS UNCHANGED:**  
**December 2, 2021 at 2:00 PM Pacific Time**

**SUBSTITUTION REQUESTS:**

**Approved:**

**Rejected:**

Mule-Hide TPO Roofing System