

**Water Testing Results - Pleasant Hill School District  
Action Level is 15 parts per billion (ppb)**

Fixture Location / Description	Fixture ID #	Test Date	Test Results (ppb)
PHES K-1 Commons Drinking Fountain	20810100-001DW	11/24/2021	ND
PHES Classroom #2 Drinking Fountain	20810100-009DW	11/24/2021	3.86
PHES 2nd Commons / Title I Drinking Fountain	20810100-012DW	11/24/2021	ND
PHES Classroom #6 Drinking Fountain	20810100-014DW	11/24/2021	ND
PHES Library West Drinking Fountain	20810109-001DW	11/24/2021	28.6
PHHS Main Gym Girls Team Room Drinking Fountain	20810201-009DW	11/24/2021	4.26

ND = Not Detected - Lead level is below the set detection limits of 2 ppb