

EHC ASSOCIATES

ENVIRONMENTAL CONSULTANTS & ABATEMENT CONTRACTORS

November 27, 2018

Mr. Glenn Davis
c/o Lampeter-Strasburg School District
1600 Book Road, P.O. Box 428
Lampeter, PA 17537

Re: Lead In Water Testing Services
Lampeter-Strasburg School District
EHC Project No. 008735-005

Dear Mr. Davis:

Please review the enclosed analytical report in regard to the water samples collected from the Lampeter-Strasburg School District on November 14, 2018. The samples were analyzed for lead content by Suburban Test Laboratory using the EPA 200 Method. The following provides a summary of the results:

LAMPETER-STRASBURG HIGH SCHOOL

<u>Sample Number/Sample Location</u>	<u>Results</u>
#1 Kitchen Sink	0.002 mg/L
#2 Fountain – Outside Gym	<0.001 mg/L
#3 Fountain – Across from Main Office	<0.001 mg/L
#4 Fountain – Outside Room 229	<0.001 mg/L
#5 Sink – Faculty Bathroom	0.001 mg/L

MARTIN MEYLIN MIDDLE SCHOOL

<u>Sample Number/Sample Location</u>	<u>Results</u>
#6 Sink – Kitchen	<0.001 mg/L
#7 Fountain – Grand Hallway	<0.001 mg/L
#8 Fountain – At Room 60	<0.001 mg/L
#9 Sink – Girl's Bathroom at Lobby	0.003 mg/L
#10 Fountain – at Library	0.001 mg/L

2502 HORSESHOE ROAD, LANCASTER, PA 17601 ♦ 717-656-3008 ♦ FAX: 717-656-7134
EMAIL: OFFICE@EHCASSOCIATES.COM ♦ WWW.EHCASSOCIATES.COM

Environmental Design • Consulting • Surveys • IAQ • Monitoring • Abatement & Demolition
Specializing in the removal of Asbestos, Lead, Mold and other hazards in the built environment.

HANS HERR ELEMENTARY SCHOOL

<u>Sample Number/Sample Location</u>	<u>Results</u>
#11 Fountain – At Office	< 0.001 mg/L
#12 Fountain – At Elevator	< 0.001 mg/L
#13 Fountain – At Room 20	< 0.001 mg/L
#14 Fountain – In Room 25	< 0.001 mg/L
#15 Sink – In Faculty Room	< 0.001 mg/L


LAMPETER ELEMENTARY SCHOOL

<u>Sample Number/Sample Location</u>	<u>Results</u>
#16 Fountain – Near Nurse's Office	< 0.001 mg/L
#17 Fountain – At Music Room	< 0.001 mg/L
#18 Fountain – At Room 208	< 0.001 mg/L
#19 Sink – In Kitchen	0.001 mg/L
#20 Fountain – At Cafeteria	< 0.001 mg/L

Laboratory analysis indicates **the water samples collected from all of the above locations are below the recommended action level of 0.015 mg/L.**

Please review the enclosed analytical report and contact our office with questions, or if further information is needed.

Sincerely,



Mark Andrechik
Inspector

Encl.'s: Laboratory Analysis Report
Invoice No.: 008735-005