



Drinking Water Results Report

Order ID: 8113210

EHC Associates, Inc.
2502 Horseshoe Road
Lancaster, PA 17601

Project: [none]

Attn: Barb King

PWSID:

Sample Number: 8113210-01

Site: 1-Kitchen Sink

Sample ID: LS High School

Collector: MA

Collect Date: 11/14/2018 6:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.002	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 13:13	AER
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8113210-02

Site: 2-Fountain Outside Gym

Sample ID: LS High School

Collector: MA

Collect Date: 11/14/2018 6:03 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 13:25	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8113210-03

Site: 3-Fountain Across Main Office

Sample ID: LS High School

Collector: MA

Collect Date: 11/14/2018 6:07 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 13:34	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8113210-04

Site: 4-Fountain Outside Rm 229

Sample ID: LS High School

Collector: MA

Collect Date: 11/14/2018 6:10 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 13:38	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8113210-05

Site: 5-Faculty Bathroom

Sample ID: LS High School

Collector: MA

Collect Date: 11/14/2018 6:13 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 13:42	AER
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Report Generated On: 11/27/2018 1:40 pm
STL_DW_Results Revision #1.78113210
Effective: 07/09/2014



SUBURBAN TESTING LABS

Sample Number: 8113210-06

Site: 6-Sink Kitchen

Sample ID: Martin Meylin Midle School

Collector: MA

Collect Date: 11/14/2018 6:15 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 13:47	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8113210-07

Site: 7-Fountain Grand Hallway

Sample ID: Martin Meylin Midle School

Collector: MA

Collect Date: 11/14/2018 6:17 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 13:51	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8113210-08

Site: 8-Fountain @ Rm 60

Sample ID: Martin Meylin Midle School

Collector: MA

Collect Date: 11/14/2018 6:20 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 14:08	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8113210-09

Site: 9- Sink Girls Bath @ Lobby

Sample ID: Martin Meylin Midle School

Collector: MA

Collect Date: 11/14/2018 6:22 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.003	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 14:12	AER
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8113210-10

Site: 10-Fountain Library

Sample ID: Martin Meylin Midle School

Collector: MA

Collect Date: 11/14/2018 6:25 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 14:16	AER
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8113210-11

Site: 11-Fountain @ Office

Sample ID: Hans Herr Elementary School

Collector: MA

Collect Date: 11/14/2018 6:31 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 14:21	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Report Generated On: 11/27/2018 1:40 pm

8113210

STL_DW_Results Revision #1.7

Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 8113210-12 Site: 12-Fountain @ Elevator Sample ID: Hans Herr Elementary School
Collector: MA Collect Date: 11/14/2018 6:34 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/21/18 AER 11/26/18 14:25 AER

Sample Number: 8113210-13 Site: 13-Fountain @ Rm 20 Sample ID: Hans Herr Elementary School
Collector: MA Collect Date: 11/14/2018 6:36 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/21/18 AER 11/26/18 14:29 AER

Sample Number: 8113210-14 Site: 14- Fountain in Rm 25 Sample ID: Hans Herr Elementary School
Collector: MA Collect Date: 11/14/2018 6:38 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/21/18 AER 11/26/18 14:33 AER

Sample Number: 8113210-15 Site: 15- Faculty Rm Sink Sample ID: Hans Herr Elementary School
Collector: MA Collect Date: 11/14/2018 6:40 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/21/18 AER 11/26/18 14:37 AER

Sample Number: 8113210-16 Site: 16-Fountain Near Nurses Sample ID: Lampeter Elementary School
Collector: MA Collect Date: 11/14/2018 6:45 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/21/18 AER 11/26/18 14:41 AER

Sample Number: 8113210-17 Site: 17-Fountain @ Music Rm Sample ID: Lampeter Elementary School
Collector: MA Collect Date: 11/14/2018 6:47 am Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 11/21/18 AER 11/26/18 14:46 AER

Report Generated On: 11/27/2018 1:40 pm 8113210
STL_DW_Results Revision #1.7 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 8113210-18	Site: 18-Fountain @ Rm 208	Sample ID: Lampeter Elementary School
Collector: MA	Collect Date: 11/14/2018 6:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 15:03	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8113210-19	Site: 19-Sink Kitchen	Sample ID: Lampeter Elementary School
Collector: MA	Collect Date: 11/14/2018 6:52 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 15:07	AER
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 8113210-20	Site: 20-Fountain @ Cafeteria	Sample ID: Lampeter Elementary School
Collector: MA	Collect Date: 11/14/2018 6:55 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	11/21/18	AER	11/26/18 15:11	AER
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH*, *Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

MCL: Maximum Contaminant Level based on 40CFR part 141 and 143. MCL and Pass/Fail are provided for reference only.

RL: Reporting Limit. The lowest concentration reported for this sample. Results below the RL are considered Non-Detected.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:


Ryan F Knerr
Project Manager II

Report Generated On: 11/27/2018 1:40 pm 8113210
STL_DW_Results Revision #1.7 Effective: 07/09/2014



4
610

Chain of Custody Record

8113210
Ryan F KnerrTAT (Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID:

Client Name: EHC Associates

Address: 2502 Horseshoe Road

Lancaster PA

Contact Name: Mark Andrechik

Fax:

Email: labresults@ehcassociates.com

e: LS High School

Payment / P.O. Info: 008735-005

Comments:

Standard TAT

Page 1 of 4

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	1- Kitchen Sink	11/14/18	0600	MA	1st Draw - Lead in Water	1		G	P	H	} PH < 2.0
	2- Fountain - outside Gym	11/14/18	0603	MA	1st Draw - Lead in Water	1		G	P	H	
	3- Fountain - across main office	11/14/18	0607	MA	1st Draw - Lead in Water	1		G	P	H	
	4- Fountain - outside Rm 229	11/14/18	0610	MA	1st Draw - Lead in Water	1		G	P	H	
	5- Sink - Faculty bathroom	11/14/18	0613	MA	1st Draw - Lead in Water	1		G	P	H	


Relinquished By:	Date: 11/14/18 Time: 0800		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By:	Date: 11-14-18 Time: 09:05	Temp °C: 3.9°C Acceptable: Y/N	Submitted with COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N Number of containers match number on COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N All containers in tact? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N Tests within holding times <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N 40 mL VOA vials free of headspace? <input type="checkbox"/> Y / <input type="checkbox"/> N	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	<input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
Relinquished By:	Date: 11-14-18 Time: 12:50	Temp °C: 3.8°C Acceptable: Y/N				
Received in Lab By:	Date: 11-14-18 Time: 1250	Temp °C: 3.8°C Acceptable: Y/N				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.

PH < 2.0 11-14-18



SUBURBAN
TESTING LABS



8113210
Ryan F Knerr

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates

Address: 2502 Horseshoe Road

Lancaster PA

Contact Name: Mark Andrechik

Fax: _____

Email: labresults@ehcassociates.com

Name: Martin Meylin Middle School

Address: _____

Payment / P.O. Info: 008735-005

Comments:

Standard TAT

Page 2 of 4

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	6-Sink - Kitchen	11/14/18	0615	MA	1st Draw - Lead in Water	1		G	P	H	} PH = 2.0
	7-Fountain - Grand Hallway	11/14/18	0617	MA	1st Draw - Lead in Water	1		G	P	H	
	8-Fountain @ Rm 60	11/14/18	0620	MA	1st Draw - Lead in Water	1		G	P	H	
	9-Sink - Girl's bath @ Lobby	11/14/18	0622	MA	1st Draw - Lead in Water	1		G	P	H	
	10-Fountain - Library	11/14/18	0625	MA	1st Draw - Lead in Water	1		G	P	H	

Relinquished By: _____	Date: <u>11/17</u> Time: <u>0800</u>		Sample Conditions Submitted with COC? <u>Y</u> / N Number of containers match number on COC? <u>Y</u> / N All containers in tact? <u>Y</u> / N Tests within holding times? <u>Y</u> / N 40 mL VOA vials free of headspace? <u>Y</u> / N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
Received By: _____	Date: <u>11-14-18</u> Time: <u>09:05</u>	Temp °C: <u>3.9</u> Acceptable: <u>Y</u> / N				
Relinquished By: _____	Date: <u>11-14-18</u> Time: <u>12:50</u>	Temp °C: <u>3.8</u> Acceptable: <u>Y</u> / N				
Received in Lab By: <u>KKW</u>	Date: <u>11-14-18</u> Time: <u>1250</u>	Temp °C: <u>3.8</u> Acceptable: <u>Y</u> / N				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



SUBURBAN
TESTING LABS



8113210
Ryan F Knerr

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates

Address: 2502 Horseshoe Road

Lancaster PA

Contact Name: Mark Andrechik

Fax: _____

Email: labresults@ehcassociates.com

Name: Hans Herr Elementary School

Payment / P.O. Info: 008735-005

Comments:

Standard TAT

Page 3 of 4

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	11-Fountain @ Office	11/14/18	0631	MA	1st Draw - Lead in Water	1		G	P	H	} pH = 2.0
	12-Fountain @ Elevator	11/14/18	0634	MA	1st Draw - Lead in Water	1		G	P	H	
	13-Fountain @ Rm 20	11/14/18	0636	MA	1st Draw - Lead in Water	1		G	P	H	
	14-Fountain in Rm 25	11/14/18	0638	MA	1st Draw - Lead in Water	1		G	P	H	
	15-Faculty Rm Sink	11/14/18	0640	MA	1st Draw - Lead in Water	1		G	P	H	

Relinquished By: _____	Date: <u>11/14</u> Time: <u>0800</u>		Sample Conditions Submitted with COC? <u>(Y)</u> N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other <input type="checkbox"/> Return a copy of this form with Report
Received By: _____	Date: <u>11-14-18</u> Time: <u>09:05</u>	Temp °C: <u>3.9</u> Acceptable: <u>(Y)</u> N	Number of containers match number on COC? <u>(Y)</u> N		Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	
Relinquished By: _____	Date: <u>11-14-18</u> Time: <u>12:50</u>	Temp °C: <u>3.8</u> Acceptable: <u>(Y)</u> N	All containers in tact? <u>(Y)</u> N	Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite		
Received in Lab By: <u>KKW</u>	Date: <u>11-14-18</u> Time: <u>1250</u>	Temp °C: <u>3.8</u> Acceptable: <u>(Y)</u> N	Tests within holding times? <u>(Y)</u> N	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence		
			40 mL VOA vials free of headspace? <u>(Y)</u> N			

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.

pH = 2.0 11-14-18



SUBURBAN
TESTING LABS



8113210
Ryan F Knerr

TAT(Check One): ☒ Standard ☐ 24hr ☐ 48hr ☐ 72hr ☐ Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: EHC Associates

Address: 2502 Horseshoe Road

Lancaster PA

Contact Name: Mark Andrechik

Phone: 717-299-0000

Fax: _____

Email: labresults@ehcassociates.com

ame: Lampeter Elementary School

Address: _____

Payment / P.O. Info: 008735-005

Comments:

Standard TAT

Page 4 of 4

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	16 - Fountain - near Nurse's	11/14/18	0645	MA	1st Draw - Lead in Water	1		G	P	H	
	17 - Fountain - @ Music Rm	11/14/18	0647	MA	1st Draw - Lead in Water			G	P	H	
	18 - Fountain @ Rm 208	11/14/18	0650	MA	1st Draw - Lead in Water			G	P	H	
	19 - Sink - Kitchen	11/14/18	0652	MA	1st Draw - Lead in Water			G	P	H	
	20 Fountain @ Cafeteria	11/14/18	0655	MA	1st Draw - Lead in Water			G	P	H	

Relinquished By:	Date: <u>11/14</u> Time: <u>0800</u>		Sample Conditions	Matrix Key	Bottle Type Key	Reporting Options
Received By:	Date: <u>11-14-18</u> Time: <u>09:05</u>	Temp °C: <u>3.8</u> Acceptable: <u>Y/N</u>	Submitted with COC? <u>Y/N</u> Number of containers match number on COC? <u>Y/N</u> All containers in tact? <u>Y/N</u> Tests within holding times <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample Sample Type Key: G = Grab, 8HC = 8 Hr. Composite, 24HC = 24 Hr. Composite SDWA Sample Types: D = Distribution, E = Entry Point, R = Raw, C = Check, S = Special, M = Maximum Residence	P = Plastic, G = Glass, O = Other Preservative Key: N = Sodium Thiosulfate, A = Ascorbic Acid, H = HNO ₃ , C = HCl, S = H ₂ SO ₄ , OH = NaOH, O = Other, NA = None Required	<input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Relinquished By:	Date: <u>11-14-18</u> Time: <u>12:50</u>	Temp °C: <u>3.8</u> Acceptable: <u>Y/N</u>				
Received in Lab By: <u>KKW</u>	Date: <u>11-14-18</u> Time: <u>1250</u>	Temp °C: <u>3.8</u> Acceptable: <u>Y/N</u>				

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.

PHC 200 11-14-18